

SYRACUSE CITY SCHOOL DISTRICT

ROBERTS PK-GRADE 8 SCHOOL

SAMPLE DATE: 09/24/2016 ANALYSIS DATE: 11/22/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 115 - Staff Bathroom	Sink	Secured - SCSD Staff Only	RS-027	RS-S200	< 1.0	None
Rm. 118 - Art Room	Sink	Public Access	RS-028	RS-S201A	< 1.0	None
Rm. 118 - Art Room	Sink	Public Access	RS-030	RS-S202A	< 1.0	None
Rm. 122 - Receiving Room	Sink	Secured - SCSD Staff Only	RS-053	RS-S311	< 1.0	None
Rm. 122A - Kitchen Staff Bathroom	Sink	Secured - SCSD Staff Only	RS-052	RS-S310	< 1.0	None
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	RS-048	RS-S306	5.0	None
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	RS-049	RS-S307	3.0	None
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	RS-050	RS-S308	1.0	None
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	RS-051	RS-S309	1.0	None
Rm. 132 - Hallway/Vestibule	Sink	Public Access	RS-043	RS-S301	< 1.0	None
Rm. 132 - Hallway/Vestibule	Sink	Public Access	RS-044	RS-S302	< 1.0	None
Rm. 132 - Hallway/Vestibule	Sink	Public Access	RS-045	RS-S303	< 1.0	None
Rm. 132 - Hallway/Vestibule	Sink	Public Access	RS-046	RS-S304	< 1.0	None
Rm. 132 - Hallway/Vestibule	Sink	Public Access	RS-047	RS-S305	< 1.0	None
Rm. 132 - Hallway/Corridor	Fountain	Public Access	RS-080	RS-F301	< 1.0	None
Rm. 132 - Hallway/Corridor	Fountain	Public Access	RS-081	RS-F302	< 1.0	None
Rm. 150B - Boiler/Meter Room	Sink	Secured - SCSD Staff Only	RS-001	RS-S100	3.7	None
Rm. 151A - Kitchen	Sink	Secured - SCSD Staff Only	RS-011	RS-S110	2.5	None
Rm. 151B - Kitchen Staff Bathroom	Sink	Secured - SCSD Staff Only	RS-012	RS-S111	< 1.0	None
Rm. 152A - Staff Bathroom	Sink	Secured - SCSD Staff Only	RS-010	RS-S109	2.4	None
Rm. 158 - Classroom	Sink	Public Access	RS-006	RS-S105	< 1.0	None
Rm. 158 - Classroom	Fountain	Public Access	RS-068	RS-F102	< 1.0	None
Rm. 158C - Classroom Bathroom	Sink	Public Access	RS-007	RS-S106	< 1.0	None
Rm. 159 - Classroom	Sink	Public Access	RS-004	RS-S103	5.0	None
Rm. 159 - Classroom	Fountain	Public Access	RS-067	RS-F101	< 1.0	None
Rm. 159C - Classroom Bathroom	Sink	Public Access	RS-005	RS-S104	< 1.0	None
Rm. 160 - Classroom	Sink	Public Access	RS-002	RS-S101	< 1.0	None
Rm. 160 - Classroom	Fountain	Public Access	RS-066	RS-F100	< 1.0	None
Rm. 160C - Classroom Bathroom	Sink	Public Access	RS-003	RS-S102	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT

ROBERTS PK-GRADE 8 SCHOOL

SAMPLE DATE: 09/24/2016 ANALYSIS DATE: 11/22/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 161 - Classroom	Sink	Public Access	RS-008	RS-S107	< 1.0	None
Rm. 161 - Classroom	Fountain	Public Access	RS-069	RS-F103	< 1.0	None
Rm. 161C - Classroom Bathroom	Sink	Public Access	RS-009	RS-S108	< 1.0	None
Rm. 274 - Classroom	Sink	Public Access	RS-013	RS-S112	< 1.0	None
Rm. 211 - Classroom	Sink	Public Access	RS-036	RS-S207	2.3	None
Rm. 211 - Classroom	Fountain	Public Access	RS-077	RS-F203	< 1.0	None
Rm. 211D - Classroom Bathroom	Sink	Public Access	RS-035	RS-S206	1.6	None
Rm. 214 - Classroom	Sink	Public Access	RS-038	RS-S209	< 1.0	None
Rm. 214 - Classroom	Fountain	Public Access	RS-078	RS-F204	< 1.0	None
Rm. 214D - Classroom Bathroom	Sink	Public Access	RS-037	RS-S208	2.1	None
Rm. 215 - Hallway/Corridor	Fountain	Public Access	RS-075	RS-F201	< 1.0	None
Rm. 215 - Hallway/Corridor	Fountain	Public Access	RS-076	RS-F202	< 1.0	None
Rm. 219 - Teacher's Lounge	Fountain	Public Access	RS-074	RS-F108	< 1.0	None
Rm. 220 - Hallway/Vestibule	Sink	Public Access	RS-031	RS-S202B	< 1.0	None
Rm. 220 - Hallway/Vestibule	Sink	Public Access	RS-032	RS-S203	< 1.0	None
Rm. 220 - Hallway/Vestibule	Sink	Public Access	RS-033	RS-S204	< 1.0	None
Rm. 220 - Hallway/Vestibule	Sink	Public Access	RS-034	RS-S205	< 1.0	None
Rm. 220 - Hallway/Vestibule	Sink	Public Access	RS-029	RS-S201B	< 1.0	None
Rm. 224A - Staff Bathroom	Sink	Secured - SCSD Staff Only	RS-022	RS-S121	< 1.0	None
Rm. 224B - Staff Bathroom	Sink	Secured - SCSD Staff Only	RS-023	RS-S122	3.2	None
Rm. 229A - Gym Office Bathroom	Sink	Public Access	RS-042	RS-S213	11.0	None
Rm. 229B - Gym Bathroom	Sink	Public Access	RS-041	RS-S212	< 1.0	None
Rm. 237 - Staff Bathroom	Sink	Secured - SCSD Staff Only	RS-039	RS-S210	18.0	SCSD to replace fixture
Rm. 239 - Hallway/Corridor	Fountain	Public Access	RS-079	RS-F205	< 1.0	None
Rm. 239 - Hallway/Corridor	Fountain	Public Access	RS-073	RS-F107	< 1.0	None
Rm. 244 - Office	Sink	Secured - SCSD Staff Only	RS-040	RS-S211	1.8	None
Rm. 252 - Office Staff Bathroom	Bathroom Sink	Secured - SCSD Staff Only	RS-024	RS-S123	< 1.0	None
Rm. 253 - Office Staff Bathroom	Bathroom Sink	Secured - SCSD Staff Only	RS-025	RS-S124	1.1	None
Rm. 255 - Office Kitchenette	Sink	Secured - SCSD Staff Only	RS-026	RS-S125	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT

ROBERTS PK-GRADE 8 SCHOOL

SAMPLE DATE: 09/24/2016 ANALYSIS DATE: 11/22/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 263 - Nurse's Room	Sink	Public Access	RS-019	RS-S118	1.0	None
Rm. 263A - Nurse's Bathroom	Sink	Public Access	RS-020	RS-S119	2.7	None
Rm. 267 - Kitchen/Teacher's Lounge	Sink	Secured - SCSD Staff Only	RS-021	RS-S120	1.3	None
Rm. 269B - Classroom Bathroom	Sink	Public Access	RS-014	RS-S113	3.2	None
Rm. 270B - Classroom Bathroom	Sink	Public Access	RS-016	RS-S115	8.2	None
Rm. 271B - Classroom Bathroom	Sink	Public Access	RS-018	RS-S117	3.0	None
Rm. 272 - Classroom	Sink	Public Access	RS-017	RS-S116	< 1.0	None
Rm. 272 - Classroom	Fountain	Public Access	RS-072	RS-F106	< 1.0	None
Rm. 273 - Classroom	Sink	Public Access	RS-015	RS-S114	< 1.0	None
Rm. 273 - Classroom	Fountain	Public Access	RS-071	RS-F105	< 1.0	None
Rm. 274 - Classroom	Fountain	Public Access	RS-070	RS-F104	< 1.0	None
Rm. 311 - Staff Bathroom	Sink	Secured - SCSD Staff Only	RS-054	RS-S312	< 1.0	None
Rm. 311 - Classroom	Sink	Public Access	RS-063	RS-S322	2.4	None
Rm. 311 - Classroom	Sink	Public Access	RS-064	RS-S323	4.9	None
Rm. 311 - Classroom	Sink	Public Access	RS-065	RS-S324	1.9	None
Rm. 313 - Classroom	Sink	Public Access	RS-061	RS-S320	5.7	None
Rm. 313 - Classroom	Sink	Public Access	RS-062	RS-S321	6.2	None
Rm. 325 - Hallway/Vestibule	Sink	Public Access	RS-058	RS-S317	< 1.0	None
Rm. 325 - Hallway/Vestibule	Sink	Public Access	RS-059	RS-S318	< 1.0	None
Rm. 325 - Hallway/Vestibule	Sink	Public Access	RS-060	RS-S319	< 1.0	None
Rm. 327 - Hallway/Vestibule	Sink	Public Access	RS-055	RS-S314	< 1.0	None
Rm. 327 - Hallway/Vestibule	Sink	Public Access	RS-056	RS-S315	< 1.0	None
Rm. 327 - Hallway/Vestibule	Sink	Public Access	RS-057	RS-S316	< 1.0	None
Rm. 329 - Hallway/Corridor	Fountain	Public Access	RS-082	RS-F303	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1616294
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

