

SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 101 - Classroom	Fountain	Public Access	DRWE-120	DW-F101	< 1.0	None
Rm. 101 - Classroom	Sink	Public Access	DRWE-006	DW-S105	< 1.0	None
Rm. 101 - Classroom	Sink	Public Access	DRWE-007	DW-S106	< 1.0	None
Rm. 101B - Classroom Bathroom	Sink	Public Access	DRWE-008	DW-S107	< 1.0	None
Rm. 102 - Classroom	Sink	Public Access	DRWE-004	DW-S103	< 1.0	None
Rm. 102 - Classroom	Sink	Public Access	DRWE-005	DW-S104	< 1.0	None
Rm. 102 - Classroom	Fountain	Public Access	DRWE-119	DW-F100	< 1.0	None
Rm. 102A - Classroom Bathroom	Sink	Public Access	DRWE-003	DW-S102	< 1.0	None
Rm. 103 - Hallway/Corridor	Fountain	Public Access	DRWE-121	DW-F102	< 1.0	None
Rm. 103 - Hallway/Corridor	Fountain	Public Access	DRWE-122	DW-F103	< 1.0	None
Rm. 106 - Art Room	Sink	Public Access	DRWE-001	DW-S100	7.5	None
Rm. 106 - Art Room	Sink	Public Access	DRWE-002	DW-S101	3.4	None
Rm. 110 - Hallway/Corridor	Fountain	Public Access	DRWE-140	DW-F205	< 1.0	None
Rm. 110 - Hallway/Corridor	Fountain	Public Access	DRWE-141	DW-F206	< 1.0	None
Rm. 113 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-138	DW-S204	3.1	None
Rm. 114 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-048	DW-S203	1.4	None
Rm. 115 - Classroom	Fountain	Public Access	DRWE-135	DW-F201	4.7	None
Rm. 115 - Classroom	Sink	Public Access	DRWE-046	DW-S201	6.1	None
Rm. 115 - Classroom	Sink	Public Access	DRWE-047	DW-S202	5.7	None
Rm. 116 - Storage Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	DRWE-045	DW-S200	2.4	None
Rm. 119 - Hallway/Corridor	Fountain	Public Access	DRWE-136	DW-F202	< 1.0	None
Rm. 119 - Hallway/Corridor	Fountain	Public Access	DRWE-137	DW-F203	< 1.0	None
Rm. 124 - Girl's Locker Room	Sink	Public Access	DRWE-049	DW-S205	6.2	None
Rm. 125 - Boy's Locker Room	Sink	Public Access	DRWE-050	DW-S206	2.1	None
Rm. 128 - Gym Office	Sink	Secured - SCSD Staff Only	DRWE-051	DW-S207	1.3	None
Rm. 129 - Pool	Fountain	Public Access	DRWE-139	DW-F204	3.0	None
Rm. 132 - Teacher's Room	Sink	Secured - SCSD Staff Only	DRWE-052	DW-S208	< 1.0	None
Rm. 134 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-053	DW-S209	1.1	None
Rm. 135 - Hallway/Corridor	Fountain	Public Access	DRWE-145	DW-F210A	1.9	None

SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 135 - Hallway/Corridor	Fountain	Public Access	DRWE-146	DW-F210B	1.6	None
Rm. 136 - Classroom	Sink	Public Access	DRWE-055	DW-S211	6.1	None
Rm. 136 - Classroom	Fountain	Public Access	DRWE-142	DW-F207	2.6	None
Rm. 136A - Classroom Bathroom	Sink	Public Access	DRWE-054	DW-S210	2.3	None
Rm. 137 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-060	DW-S216	1.0	None
Rm. 138 - Hallway/Vestibule	Sink	Public Access	DRWE-058	DW-S214	1.9	None
Rm. 139 - Hallway/Vestibule	Sink	Public Access	DRWE-059	DW-S215	< 1.0	None
Rm. 140 - Classroom	Sink	Public Access	DRWE-057	DW-S213	4.3	None
Rm. 140 - Classroom	Fountain	Public Access	DRWE-143	DW-F208	4.9	None
Rm. 140A - Classroom Bathroom	Sink	Public Access	DRWE-056	DW-S212	3.4	None
Rm. 141 - Classroom	Sink	Public Access	DRWE-062	DW-S218	1.5	None
Rm. 141 - Classroom	Fountain	Public Access	DRWE-144	DW-F209	2.5	None
Rm. 141A - Classroom Bathroom	Sink	Public Access	DRWE-061	DW-S217	1.4	None
Rm. 146 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	DRWE-064	DW-S220	3.0	None
Rm. 147 - Classroom	Sink	Public Access	DRWE-063	DW-S219	1.7	None
Rm. 148 - Classroom	Sink	Public Access	DRWE-066	DW-S222	1.9	None
Rm. 148 - Classroom	Fountain	Public Access	DRWE-147	DW-F211A	< 1.0	None
Rm. 148A - Classroom Bathroom	Sink	Public Access	DRWE-065	DW-S221	< 1.0	None
Rm. 149 - Classroom	Sink	Public Access	DRWE-068	DW-S224	3.8	None
Rm. 149 - Classroom	Fountain	Public Access	DRWE-148	DW-F211B	< 1.0	None
Rm. 149A - Classroom Bathroom	Sink	Public Access	DRWE-067	DW-S223	1.8	None
Rm. 151 - Classroom	Sink	Public Access	DRWE-069	DW-S225	3.3	None
Rm. 152 - Classroom	Sink	Public Access	DRWE-071	DW-S227	2.0	None
Rm. 152 - Classroom	Fountain	Public Access	DRWE-149	DW-F212	1.5	None
Rm. 152A - Classroom Bathroom	Sink	Public Access	DRWE-070	DW-S226	1.7	None
Rm. 154 - Classroom	Sink	Public Access	DRWE-028	DW-S126B	< 1.0	None
Rm. 154 - Classroom	Fountain	Public Access	DRWE-131	DW-F111	< 1.0	None
Rm. 154A - Classroom Bathroom	Sink	Public Access	DRWE-027	DW-S126A	1.4	None
Rm. 156 - Classroom	Sink	Public Access	DRWE-072	DW-S228	8.3	None

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 157 - Classroom	Sink	Public Access	DRWE-026	DW-S125	< 1.0	None
Rm. 157 - Classroom	Fountain	Public Access	DRWE-130	DW-F110	1.1	None
Rm. 157A - Classroom Bathroom	Sink	Public Access	DRWE-025	DW-S124	< 1.0	None
Rm. 158 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-024	DW-S123	1.4	None
Rm. 159 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-023	DW-S122	1.8	None
Rm. 160 - Classroom	Sink	Public Access	DRWE-022	DW-S121	3.3	None
Rm. 160 - Classroom	Fountain	Public Access	DRWE-129	DW-F109	1.9	None
Rm. 160A - Classroom Bathroom	Sink	Public Access	DRWE-021	DW-S120	< 1.0	None
Rm. 162 - Classroom	Fountain	Public Access	DRWE-128	DW-F108	< 1.0	None
Rm. 162 - Classroom	Sink	Public Access	DRWE-020	DW-S119	1.9	None
Rm. 162A - Classroom Bathroom	Sink	Public Access	DRWE-019	DW-S118	1.1	None
Rm. 165 - Classroom	Sink	Public Access	DRWE-018	DW-S117	2.7	None
Rm. 165 - Classroom	Fountain	Public Access	DRWE-127	DW-F107	< 1.0	None
Rm. 165A - Classroom Bathroom	Sink	Public Access	DRWE-017	DW-S116	1.3	None
Rm. 166 - Classroom	Sink	Public Access	DRWE-016	DW-S115	< 1.0	None
Rm. 166 - Classroom	Fountain	Public Access	DRWE-126	DW-F106B	1.1	None
Rm. 166A - Classroom Bathroom	Sink	Public Access	DRWE-015	DW-S114	1.3	None
Rm. 168 - Hallway/Vestibule	Sink	Public Access	DRWE-029	DW-S128	6.8	None
Rm. 168 - Hallway/Vestibule	Sink	Public Access	DRWE-030	DW-S129	2.9	None
Rm. 167 - Classroom	Sink	Public Access	DRWE-032	DW-S131	1.1	None
Rm. 167A - Classroom Bathroom	Sink	Public Access	DRWE-031	DW-S130	1.2	None
Rm. 173A - Classroom Bathroom	Sink	Public Access	DRWE-033	DW-S132	1.4	None
Rm. 174 - Classroom	Sink	Public Access	DRWE-014	DW-S113	< 1.0	None
Rm. 174 - Classroom	Fountain	Public Access	DRWE-125	DW-F106A	< 1.0	None
Rm. 174A - Classroom Bathroom	Sink	Public Access	DRWE-013	DW-S112	2.0	None
Rm. 176 - Classroom	Sink	Public Access	DRWE-012	DW-S111	1.5	None
Rm. 176 - Classroom	Fountain	Public Access	DRWE-124	DW-F105	< 1.0	None
Rm. 176A - Classroom Bathroom	Sink	Public Access	DRWE-011	DW-S110	< 1.0	None
Rm. 177 - Classroom	Sink	Public Access	DRWE-010	DW-S109	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 177 - Classroom	Fountain	Public Access	DRWE-123	DW-F104	1.1	None
Rm. 177A - Classroom Bathroom	Sink	Public Access	DRWE-009	DW-S108	< 1.0	None
Rm. 203 - Kitchen	Sink	Secured - SCSD Staff Only	DRWE-110	DW-S321	1.6	None
Rm. 204 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-101	DW-S312	1.5	None
Rm. 210 - Exam Room	Sink	Public Access	DRWE-103	DW-S314	< 1.0	None
Rm. 211 - Exam Room Bathroom	Sink	Public Access	DRWE-105	DW-S316	1.3	None
Rm. 212 - Dental Room	Sink	Public Access	DRWE-106	DW-S317	1.6	None
Rm. 213 - Clinic Room	Sink	Public Access	DRWE-102	DW-S313	1.5	None
Rm. 214 - Exam Room	Sink	Public Access	DRWE-104	DW-S315	4.8	None
Rm. 216 - Treatment Room	Sink	Public Access	DRWE-107	DW-S318	< 1.0	None
Rm. 217 - Nurse's Room	Sink	Public Access	DRWE-108	DW-S319	1.9	None
Rm. 217A - Exam Room Bathroom	Sink	Public Access	DRWE-109	DW-S320	1.2	None
Rm. 221 - Kitchen	Sink	Secured - SCSD Staff Only	DRWE-094	DW-S305	2.5	None
Rm. 221 - Kitchen	Sink	Secured - SCSD Staff Only	DRWE-095	DW-S306	< 1.0	None
Rm. 221B - Kitchen	Sink	Secured - SCSD Staff Only	DRWE-096	DW-S307	1.6	None
Rm. 221B - Kitchen	Sink	Secured - SCSD Staff Only	DRWE-097	DW-S308	< 1.0	None
Rm. 222 - Receiving Room	Sink	Secured - SCSD Staff Only	DRWE-098	DW-S309	1.5	None
Rm. 222 - Receiving Room	Sink	Secured - SCSD Staff Only	DRWE-099	DW-S310	6.3	None
Rm. 222B - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-100	DW-S311	1.3	None
Rm. 223 - Cafeteria	Fountain	Public Access	DRWE-153	DW-F301	< 1.0	None
Rm. 223 - Cafeteria	Fountain	Public Access	DRWE-154	DW-F302	< 1.0	None
Rm. 223 (225) - Hallway/Vestibule	Sink	Public Access	DRWE-091	DW-S302	< 1.0	None
Rm. 223 (224) - Hallway/Vestibule	Sink	Public Access	DRWE-092	DW-S303	< 1.0	None
Rm. 234A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	DRWE-093	DW-S304	< 1.0	None
Rm. 228 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-090	DW-S301	1.5	None
Rm. 240 - Teacher's Room	Sink	Secured - SCSD Staff Only	DRWE-088	DW-S244	2.1	None
Rm. 241 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-087	DW-S243	2.4	None
Rm. 243 - Hallway/Corridor	Fountain	Public Access	DRWE-150	DW-F213	< 1.0	None
Rm. 243 - Hallway/Corridor	Fountain	Public Access	DRWE-151	DW-F214	< 1.0	None

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 244 (256) - Hallway/Vestibule	Sink	Public Access	DRWE-073	DW-S229	< 1.0	None
Rm. 244 (257) - Hallway/Vestibule	Sink	Public Access	DRWE-074	DW-S230	< 1.0	None
Rm. 244 (237) - Hallway/Vestibule	Sink	Public Access	DRWE-083	DW-S239	< 1.0	None
Rm. 244 (238) - Hallway/Vestibule	Sink	Public Access	DRWE-082	DW-S238	2.9	None
Rm. 245 - Classroom	Sink	Public Access	DRWE-086	DW-S242	2.4	None
Rm. 245 - Classroom	Fountain	Public Access	DRWE-152	DW-F215	< 1.0	None
Rm. 245A - Classroom Bathroom	Sink	Public Access	DRWE-085	DW-S241	1.3	None
Rm. 246 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-084	DW-S240	2.5	None
Rm. 250 - Classroom	Sink	Public Access	DRWE-081	DW-S237	2.8	None
Rm. 251 - Classroom	Sink	Public Access	DRWE-080	DW-S236	3.3	None
Rm. 252 - Classroom	Sink	Public Access	DRWE-079	DW-S235	2.1	None
Rm. 253 - Classroom	Sink	Public Access	DRWE-078	DW-S234	2.5	None
Rm. 254 - Classroom	Sink	Secured - SCSD Staff Only	DRWE-077	DW-S233	2.7	None
Rm. 255B - Work Room	Sink	Secured - SCSD Staff Only	DRWE-075	DW-S231	3.4	None
Rm. 255E - Media Center Bathroom	Sink	Public Access	DRWE-089	DW-S245	< 1.0	None
Rm. 258 - Classroom	Sink	Public Access	DRWE-076	DW-S232	2.8	None
Rm. 261 - Classroom	Sink	Public Access	DRWE-034	DW-S133	2.7	None
Rm. 262 - Classroom	Sink	Public Access	DRWE-035	DW-S134	< 1.0	None
Rm. 262 - Classroom	Fountain	Public Access	DRWE-132	DW-F112	< 1.0	None
Rm. 262A - Classroom Bathroom	Sink	Public Access	DRWE-036	DW-S135	1.5	None
Rm. 265 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-044	DW-S143	1.0	None
Rm. 267 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-043	DW-S142	1.2	None
Rm. 268 - Classroom	Sink	Public Access	DRWE-037	DW-S136	1.7	None
Rm. 270 - Hallway/Vestibule	Sink	Public Access	DRWE-041	DW-S140	< 1.0	None
Rm. 270 - Hallway/Vestibule	Sink	Public Access	DRWE-042	DW-S141	1.1	None
Rm. 270 - Hallway/Corridor	Fountain	Public Access	DRWE-133	DW-F113	< 1.0	None
Rm. 270 - Hallway/Corridor	Fountain	Public Access	DRWE-134	DW-F114	< 1.0	None
Rm. 273 - Classroom	Sink	Public Access	DRWE-038	DW-S137	2.4	None
Rm. 274 - Classroom	Sink	Public Access	DRWE-039	DW-S138	2.6	None

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 275 - Classroom	Sink	Public Access	DRWE-040	DW-S139	1.2	None
Rm. 277 - Classroom	Sink	Public Access	DRWE-118	DW-S329	3.9	None
Rm. 278 - Classroom	Sink	Public Access	DRWE-117	DW-S328	1.3	None
Rm. 279 - Classroom	Sink	Public Access	DRWE-115	DW-S326	1.3	None
Rm. 279 - Classroom	Fountain	Public Access	DRWE-157	DW-F305	1.2	None
Rm. 279A - Classroom Bathroom	Sink	Public Access	DRWE-116	DW-S327	< 1.0	None
Rm. 280 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-114	DW-S325	1.6	None
Rm. 281 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-113	DW-S324	< 1.0	None
Rm. 283 - Hallway/Corridor	Fountain	Public Access	DRWE-155	DW-F303	< 1.0	None
Rm. 283 - Hallway/Corridor	Fountain	Public Access	DRWE-156	DW-F304	< 1.0	None
Rm. 291 - Mail Room	Sink	Secured - SCSD Staff Only	DRWE-112	DW-S323	2.4	None
Rm. 294 - Office Staff Bathroom	Sink	Secured - SCSD Staff Only	DRWE-111	DW-S322	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-003
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1619734
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.