

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

SAMPLE DATE: 09/29/2016 ANALYSIS DATES: 11/27/2016 11/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 100D - Office Kitchenette	Sink	Secured - SCSD Staff Only	McKinley-056	MY-S231	< 1.0	None
Rm. 100T - Principal's Bathroom	Sink	Secured - SCSD Staff Only	McKinley-055	MY-S230	1.0	None
Rm. 103T - Main Office Bathroom	Sink	Secured - SCSD Staff Only	McKinley-054	MY-S229	1.1	None
Rm. 105 - Nurse's Office	Sink	Public Access	McKinley-050	MY-S225	< 1.0	None
Rm. 105A - Exam Room	Sink	Public Access	McKinley-051	MY-S226	1.2	None
Rm. 105B - Nurse's Office Changing Room	Sink	Public Access	McKinley-053	MY-S228	< 1.0	None
Rm. 105T - Nurse's Office Bathroom	Sink	Public Access	McKinley-052	MY-S227	< 1.0	None
Rm. 107 - Classroom	Sink	Public Access	McKinley-037	MY-S211	< 1.0	None
Rm. 107 - Classroom	Sink	Public Access	-	MY-S212	-	Fixture not operating
Rm. 107 - Classroom	Fountain	Public Access	McKinley-109	MY-F203	< 1.0	None
Rm. 108 - Staff Bathroom	Sink	Secured - SCSD Staff Only	McKinley-038	MY-S213	3.8	None
Rm. 111 - Classroom	Sink	Public Access	McKinley-036	MY-S210	< 1.0	None
Rm. 111 - Classroom	Sink	Public Access	McKinley-035	MY-S209	< 1.0	None
Rm. 111 - Classroom	Fountain	Public Access	McKinley-108	MY-F202	< 1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	McKinley-030	MY-S204	< 1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	McKinley-031	MY-S205	< 1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	McKinley-032	MY-S206	< 1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	McKinley-033	MY-S207	< 1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	McKinley-034	MY-S208	3.9	None
Rm. 112B - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	McKinley-029	MY-S203	< 1.0	None
Rm. 113 - Classroom	Sink	Public Access	-	MY-S201	-	Fixture not operating
Rm. 113 - Classroom	Sink	Public Access	McKinley-028	MY-S202	< 1.0	None
Rm. 113 - Classroom	Fountain	Public Access	McKinley-107	MY-F201	< 1.0	None
Rm. 119 - Community Room	Sink	Public Access	McKinley-043	MY-S218	< 1.0	None
Rm. 120B - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	McKinley-044	MY-S219	< 1.0	None
Rm. 121T - Boy's Bathroom	Sink	Public Access	McKinley-045	MY-S220	3.3	None
Rm. 121T - Boy's Bathroom	Sink	Public Access	McKinley-046	MY-S221	4.4	None
Rm. 122T - PE Office Bathroom	Sink	Secured - SCSD Staff Only	McKinley-049	MY-S224	2.0	None
Rm. 123T - Girl's Bathroom	Sink	Public Access	McKinley-047	MY-S222	1.2	None

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

SAMPLE DATE: 09/29/2016 ANALYSIS DATES: 11/27/2016 11/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 123T - Girl's Bathroom	Sink	Public Access	McKinley-048	MY-S223	< 1.0	None
Rm. 126 - Classroom	Sink	Public Access	-	MY-S131	-	Fixture not operating
Rm. 126 - Classroom	Sink	Public Access	McKinley-026	MY-S132	< 1.0	None
Rm. 126 - Classroom	Fountain	Public Access	McKinley-106	MY-F114	< 1.0	None
Rm. 127 - Classroom	Sink	Public Access	McKinley-024	MY-S129	6.7	None
Rm. 127 - Classroom	Sink	Public Access	McKinley-025	MY-S130	< 1.0	None
Rm. 127 - Classroom	Fountain	Public Access	McKinley-105	MY-F113	< 1.0	None
Rm. 128 - Classroom	Sink	Public Access	--	MY-S125	--	Fixture not operating
Rm. 128 - Classroom	Sink	Public Access	McKinley-021	MY-S126	< 1.0	None
Rm. 128 - Classroom	Fountain	Public Access	McKinley-104	MY-F112	< 1.0	None
Rm. 130 - Classroom	Sink	Public Access	McKinley-020	MY-S124	< 1.0	None
Rm. 130 - Classroom	Sink	Public Access	McKinley-019	MY-S123	2.1	None
Rm. 130 - Classroom	Sink	Public Access	McKinley-020	MY-S124	< 1.0	None
Rm. 130 - Classroom	Fountain	Public Access	McKinley-103	MY-F111	< 1.0	None
Rm. 131 - Classroom	Sink	Public Access	McKinley-018	MY-S122	2.3	None
Rm. 131 - Classroom	Fountain	Public Access	McKinley-102	MY-F110	< 1.0	None
Rm. 131T - Classroom Bathroom	Sink	Public Access	McKinley-017	MY-S121	< 1.0	None
Rm. 132 - Art Room	Sink	Public Access	McKinley-015	MY-S119	1.1	None
Rm. 132 - Art Room	Sink	Public Access	McKinley-016	MY-S120	< 1.0	None
Rm. 136 - Staff Bathroom	Sink	Secured - SCSD Staff Only	McKinley-013	MY-S116	< 1.0	None
Rm. 137 - Classroom	Sink	Public Access	-	MY-S117	-	Fixture not operating
Rm. 137 - Classroom	Sink	Public Access	McKinley-014	MY-S118	< 1.0	None
Rm. 137 - Classroom	Fountain	Public Access	McKinley-101	MY-F109	< 1.0	None
Rm. 138 - Classroom	Fountain	Public Access	McKinley-092	MY-F100	< 1.0	None
Rm. 138 - Classroom	Sink	Public Access	McKinley-002	MY-S101	< 1.0	None
Rm. 138T - Classroom Bathroom	Sink	Public Access	McKinley-001	MY-S100	2.3	None
Rm. 139 - Classroom	Sink	Public Access	McKinley-003	MY-S103	< 1.0	None
Rm. 139 - Classroom	Fountain	Public Access	McKinley-093	MY-F101	< 1.0	None
Rm. 139T - Classroom	Sink	Public Access	-	MY-S102	-	Fixture not operating

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

SAMPLE DATE: 09/29/2016 ANALYSIS DATES: 11/27/2016 11/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 140 - Classroom	Sink	Public Access	McKinley-004	MY-S105	< 1.0	None
Rm. 140 - Classroom	Fountain	Public Access	McKinley-094	MY-F102	< 1.0	None
Rm. 140T - Classroom	Sink	Public Access	-	MY-S104	-	Fixture not operating
Rm. 141 - Classroom	Sink	Public Access	McKinley-005	MY-S106	< 1.0	None
Rm. 141 - Classroom	Sink	Public Access	McKinley-006	MY-S107	< 1.0	None
Rm. 141 - Classroom	Fountain	Public Access	McKinley-095	MY-F103	< 1.0	None
Rm. 142 - Classroom	Sink	Public Access	-	MY-S110	-	Fixture not operating
Rm. 142 - Classroom	Sink	Public Access	McKinley-009	MY-S111	< 1.0	None
Rm. 142 - Classroom	Fountain	Public Access	McKinley-098	MY-F106	< 1.0	None
Rm. 146 - Classroom	Sink	Public Access	-	MY-S112	-	Fixture not operating
Rm. 146 - Classroom	Fountain	Public Access	McKinley-099	MY-F107	< 1.0	None
Rm. 146 - Classroom	Sink	Public Access	McKinley-010	MY-S113	< 1.0	None
Rm. 150 - Classroom	Sink	Public Access	McKinley-012	MY-S115	< 1.0	None
Rm. 150 - Classroom	Fountain	Public Access	McKinley-100	MY-F108	< 1.0	None
Rm. 150T - Classroom Bathroom	Sink	Public Access	McKinley-011	MY-S114	< 1.0	None
Rm. 151A - Work Office	Sink	Secured - SCSD Staff Only	McKinley-022	MY-S127	3.0	None
Rm. 151T - Library Bathroom	Sink	Public Access	McKinley-023	MY-S128	2.0	None
Rm. 166 - Hallway/Vestibule	Sink	Public Access	McKinley-007	MY-S108	< 1.0	None
Rm. 166 - Hallway/Vestibule	Sink	Public Access	McKinley-008	MY-S109	< 1.0	None
Rm. 166 - Hallway/Vestibule	Fountain	Public Access	McKinley-096	MY-F104	< 1.0	None
Rm. 166 - Hallway/Vestibule	Fountain	Public Access	McKinley-097	MY-F105	< 1.0	None
Rm. 174 - Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	McKinley-027	MY-M200	2800	SCSD to post sign
Rm. 178 - Hallway/Vestibule	Sink	Public Access	McKinley-039	MY-S214	< 1.0	None
Rm. 178 - Hallway/Vestibule	Sink	Public Access	McKinley-040	MY-S215	< 1.0	None
Rm. 178 - Hallway/Vestibule	Sink	Public Access	McKinley-041	MY-S216	< 1.0	None
Rm. 178 - Hallway/Vestibule	Sink	Public Access	McKinley-042	MY-S217	< 1.0	None
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	McKinley-110	MY-F204	< 1.0	None
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	McKinley-111	MY-F205	< 1.0	None
Rm. 200 - Science Room	Sink	Public Access	McKinley-080	MY-S324	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

SAMPLE DATE: 09/29/2016 ANALYSIS DATES: 11/27/2016 11/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 202 - Science Room	Sink	Public Access	McKinley-081	MY-S325	1.1	None
Rm. 203 - Faculty Lounge	Sink	Secured - SCSD Staff Only	McKinley-082	MY-S326	1.7	None
Rm. 203A - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	McKinley-083	MY-S327	< 1.0	None
Rm. 203B - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	McKinley-084	MY-S328	1.7	None
Rm. 204 - Science Room	Sink	Public Access	McKinley-086	MY-S330	< 1.0	None
Rm. 205T - Classroom Bathroom	Sink	Public Access	McKinley-085	MY-S329	2.0	None
Rm. 210 - Staff Bathroom	Sink	Secured - SCSD Staff Only	McKinley-087	MY-S331	1.1	None
Rm. 217 - Classroom	Sink	Public Access	McKinley-079	MY-S323	1.4	None
Rm. 217 - Classroom	Sink	Public Access	--	MY-S341	--	Fixture not operating
Rm. 217 - Classroom	Fountain	Public Access	--	MY-F314	--	Fixture not operating
Rm. 218 - Classroom	Sink	Public Access	McKinley-078	MY-S322	< 1.0	None
Rm. 218 - Classroom	Sink	Public Access	--	MY-S340	--	None
Rm. 218 - Classroom	Fountain	Public Access	McKinley-122	MY-F311	< 1.0	None
Rm. 219 - Office	Sink	Secured - SCSD Staff Only	McKinley-076	MY-S320	8.1	None
Rm. 219 - Office	Sink	Secured - SCSD Staff Only	McKinley-077	MY-S321	1.0	None
Rm. 219 - Office	Fountain	Secured - SCSD Staff Only	McKinley-121	MY-F310	< 1.0	None
Rm. 221 - Classroom	Sink	Public Access	McKinley-074	MY-S318	3.0	None
Rm. 221 - Classroom	Sink	Public Access	McKinley-075	MY-S319	< 1.0	None
Rm. 221 - Classroom	Fountain	Public Access	McKinley-120	MY-F309	< 1.0	None
Rm. 222 - Classroom	Sink	Public Access	McKinley-072	MY-S316	< 1.0	None
Rm. 222 - Classroom	Fountain	Public Access	McKinley-119	MY-F308	< 1.0	None
Rm. 222T - Classroom Bathroom	Sink	Public Access	McKinley-073	MY-S317	< 1.0	None
Rm. 223 - Classroom	Sink	Public Access	McKinley-071	MY-S315	< 1.0	None
Rm. 223 - Classroom	Sink	Public Access	--	MY-S338	--	Fixture not operating
Rm. 223 - Classroom	Fountain	Public Access	McKinley-118	MY-F307	< 1.0	None
Rm. 224 - Resource Room	Sink	Public Access	McKinley-070	MY-S314	< 1.0	None
Rm. 226 - Staff Bathroom	Sink	Secured - SCSD Staff Only	McKinley-068	MY-S312	< 1.0	None
Rm. 227 - Classroom	Sink	Public Access	McKinley-069	MY-S313	< 1.0	None
Rm. 227 - Classroom	Sink	Public Access	--	MY-S337	--	Fixture not operating

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

SAMPLE DATE: 09/29/2016 ANALYSIS DATES: 11/27/2016 11/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 227 - Classroom	Fountain	Public Access	McKinley-117	MY-F306	< 1.0	None
Rm. 228 - Classroom	Sink	Public Access	McKinley-063	MY-S307	< 1.0	None
Rm. 228 - Classroom	Sink	Public Access	--	MY-S336	--	Fixture not operating
Rm. 228 - Classroom	Fountain	Public Access	McKinley-114	MY-F303	< 1.0	None
Rm. 232 - Classroom	Sink	Public Access	McKinley-060	MY-S304	< 1.0	None
Rm. 233 - Classroom	Sink	Public Access	McKinley-059	MY-S303	< 1.0	None
Rm. 234 - Classroom	Sink	Public Access	McKinley-058	MY-S302	< 1.0	None
Rm. 235 - Classroom	Sink	Public Access	McKinley-057	MY-S301	< 1.0	None
Rm. 236 - Classroom	Sink	Public Access	McKinley-064	MY-S308	< 1.0	None
Rm. 236 - Classroom	Sink	Public Access	--	MY-S339	--	Fixture not operating
Rm. 236 - Classroom	Fountain	Public Access	McKinley-115	MY-F304	< 1.0	None
Rm. 238 - Resource Room	Sink	Public Access	McKinley-067	MY-S311	< 1.0	None
Rm. 239 - Classroom	Sink	Public Access	McKinley-065	MY-S309	< 1.0	None
Rm. 239 - Classroom	Sink	Public Access	McKinley-066	MY-S310	< 1.0	None
Rm. 239 - Classroom	Fountain	Public Access	McKinley-116	MY-F305	< 1.0	None
Rm. 247 - Hallway/Vestibule	Sink	Public Access	McKinley-088	MY-S332	< 1.0	None
Rm. 247 - Hallway/Vestibule	Sink	Public Access	McKinley-089	MY-S333	< 1.0	None
Rm. 247 - Hallway/Vestibule	Sink	Public Access	McKinley-090	MY-S334	< 1.0	None
Rm. 247 - Hallway/Vestibule	Sink	Public Access	McKinley-091	MY-S335	< 1.0	None
Rm. 247 - Hallway/Vestibule	Fountain	Public Access	McKinley-123	MY-F312	< 1.0	None
Rm. 247 - Hallway/Vestibule	Fountain	Public Access	McKinley-124	MY-F313	< 1.0	None
Rm. 256 - Hallway/Vestibule	Sink	Public Access	McKinley-061	MY-S305	< 1.0	None
Rm. 256 - Hallway/Vestibule	Sink	Public Access	McKinley-062	MY-S306	< 1.0	None
Rm. 256 - Hallway/Vestibule	Fountain	Public Access	McKinley-112	MY-F301	< 1.0	None
Rm. 256 - Hallway/Vestibule	Fountain	Public Access	McKinley-113	MY-F302	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-025
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1619295
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

