

SYRACUSE CITY SCHOOL DISTRICT

HW SMITH PK - GRADE 8 SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATES: 12/15/2016 and 12/16/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. A-A - Classroom	Sink	Public Access	HWS-045	HW-S308	2.8	None
Rm. A-A - Classroom	Sink	Public Access	HWS-046	HW-S309	2.4	None
Rm. A-01 - ESL Room	Sink	Public Access	HWS-043	HW-S306	< 1.0	None
Rm. A-01 - ESL Room	Sink	Public Access	HWS-044	HW-S307	< 1.0	None
Rm. A-02 - Classroom	Sink	Public Access	--	HW-S312	--	Fixture not operating
Rm. A-02 - Classroom	Sink	Public Access	HWS-049	HW-S313	1.7	None
Rm. A-03 - Classroom	Sink	Public Access	HWS-051	HW-S315	1.2	None
Rm. A-03 - Classroom	Fountain	Public Access	HWS-122	HW-F302	1.7	None
Rm. A-03B - Classroom Bathroom	Sink	Public Access	HWS-050	HW-S314	1.0	None
Rm. A-04 - Classroom	Sink	Public Access	HWS-052	HW-S316	2.4	None
Rm. A-04 - Classroom	Fountain	Public Access	HWS-123	HW-F303	1.3	None
Rm. A-04B - Classroom Bathroom	Sink	Public Access	HWS-053	HW-S317	< 1.0	None
Rm. A-05 - Classroom	Sink	Public Access	HWS-055	HW-S319	1.4	None
Rm. A-05 - Classroom	Fountain	Public Access	HWS-125	HW-F305	1.9	None
Rm. A-05B - Classroom Bathroom	Sink	Public Access	HWS-054	HW-S318	1.0	None
Rm. A-06 - Classroom	Sink	Public Access	HWS-058	HW-S322	1.2	None
Rm. A-06 - Classroom	Fountain	Public Access	HWS-126	HW-F306	< 1.0	None
Rm. A-06B - Classroom Bathroom	Sink	Public Access	HWS-057	HW-S321	< 1.0	None
Rm. A-07 - Classroom	Sink	Public Access	HWS-060	HW-S324	1.4	None
Rm. A-07 - Classroom	Fountain	Public Access	HWS-127	HW-F307	< 1.0	None
Rm. A-07B - Classroom Bathroom	Sink	Public Access	HWS-059	HW-S323	1.1	None
Rm. A-12 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	HWS-056	HW-S320	2.9	None
Rm. A-16 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-048	HW-S311	110.0	SCSD removed fixture from service and is to replace
Rm. A-17 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-047	HW-S310	2.3	None
Rm. A-22D - Storage Room	Sink	Secured - SCSD Staff Only	HWS-040	HW-S303	3.7	None
Rm. A-30A - Hallway/Corridor	Fountain	Public Access	HWS-124	HW-F304	< 1.0	None
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	HWS-038	HW-S301	< 1.0	None
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	HWS-039	HW-S302	2.0	None
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	HWS-041	HW-S304	2.4	None

SYRACUSE CITY SCHOOL DISTRICT

HW SMITH PK - GRADE 8 SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATES: 12/15/2016 and 12/16/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	HWS-042	HW-S305	< 1.0	None
Rm. A-30H - Hallway/Corridor	Fountain	Public Access	HWS-121	HW-F301	< 1.0	None
Rm. A-33 - Classroom	Sink	Public Access	HWS-005	HW-S104	< 1.0	None
Rm. A-33 - Classroom	Fountain	Public Access	HWS-113	HW-F101	< 1.0	None
Rm. A-33B - Classroom Bathroom	Sink	Public Access	HWS-004	HW-S103	< 1.0	None
Rm. A-34 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-006	HW-S105	1.2	None
Rm. A-35 - Classroom	Sink	Public Access	HWS-003	HW-S102	< 1.0	None
Rm. A-35 - Classroom	Fountain	Public Access	HWS-112	HW-F100	20.0	This is a new fixture. SCSD has removed fixture from service, will flush and resample for confirmation.
Rm. A-35B - Classroom Bathroom	Sink	Public Access	HWS-002	HW-S101	1.1	None
Rm. A100B - Girl's Bathroom	Sink	Public Access	HWS-007	HW-S106	< 1.0	None
Rm. A100C - Girl's Bathroom	Sink	Public Access	HWS-008	HW-S107	1.1	None
Rm. A100D - Boy's Bathroom	Sink	Public Access	HWS-009	HW-S108	6.5	None
Rm. A100E - Boy's Bathroom	Sink	Public Access	HWS-010	HW-S109	2.0	None
Rm. A100J - Hallway/Corridor	Fountain	Public Access	HWS-128	HW-F308	< 1.0	None
Rm. A100K - Hallway/Corridor	Fountain	Public Access	HWS-114	HW-F102	< 1.0	None
Rm. A100K - Hallway/Corridor	Fountain	Public Access	HWS-115	HW-F103	< 1.0	None
Rm. A104 - Office	Sink	Secured - SCSD Staff Only	HWS-011	HW-S110	< 1.0	None
Rm. A106 - Copy Room	Sink	Secured - SCSD Staff Only	HWS-013	HW-S112	2.9	None
Rm. A106A - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-012	HW-S111	< 1.0	None
Rm. A106A - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-076	HW-S341	1.4	None
Rm. A108 - Art Room	Sink	Public Access	HWS-014	HW-S113	3.7	None
Rm. A108 - Art Room	Sink	Public Access	HWS-015	HW-S114	6.0	None
Rm. A108 - Art Room	Sink	Public Access	HWS-016	HW-S115	4.1	None
Rm. A108C - Home & Careers Room	Sink	Public Access	HWS-072	HW-S337	< 1.0	None
Rm. A108C - Home & Careers Room	Sink	Public Access	HWS-073	HW-S338	1.4	None
Rm. A108C - Home & Careers Room	Sink	Public Access	HWS-074	HW-S339	1.5	None
Rm. A108C - Home & Careers Room	Sink	Public Access	HWS-075	HW-S340	3.5	None
Rm. A109 - Science Room	Sink	Public Access	HWS-068	HW-S333	9.4	None

SYRACUSE CITY SCHOOL DISTRICT

HW SMITH PK - GRADE 8 SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATES: 12/15/2016 and 12/16/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. A109 - Science Room	Sink	Public Access	HWS-069	HW-S334	3.4	None
Rm. A109 - Science Room	Sink	Public Access	HWS-070	HW-S335	1.3	None
Rm. A109B - Boy's Bathroom	Sink	Public Access	HWS-066	HW-S331	1.4	None
Rm. A110 - Technology Shop	Sink	Public Access	HWS-071	HW-S336	< 1.0	None
Rm. A112 - Classroom	Sink	Public Access	HWS-077	HW-S342	1.4	None
Rm. A112B - Girl's Bathroom	Sink	Public Access	HWS-064	HW-S329	< 1.0	None
Rm. A113 - Science Room	Sink	Public Access	HWS-061	HW-S326	< 1.0	None
Rm. A113 - Science Room	Sink	Public Access	HWS-062	HW-S327	1.0	None
Rm. A113 - Science Room	Sink	Public Access	HWS-063	HW-S328	5.7	None
Rm. A113B - Boy's Bathroom	Sink	Public Access	HWS-067	HW-S332	1.1	None
Rm. A120A - Girl's Bathroom	Sink	Public Access	HWS-065	HW-S330	1.0	None
Rm. A122 - Classroom	Sink	Public Access	HWS-078	HW-S343	1.9	None
Rm. A123 - Classroom	Sink	Public Access	HWS-079	HW-S344	1.7	None
Rm. A125 - Classroom	Sink	Public Access	HWS-080	HW-S345	2.9	None
Rm. A200 - Girl's Bathroom	Sink	Public Access	HWS-103	HW-S369	< 1.0	None
Rm. A200B - Hallway/Corridor	Fountain	Public Access	HWS-131	HW-F311	< 1.0	None
Rm. A200B - Hallway/Corridor	Fountain	Public Access	HWS-132	HW-F312	< 1.0	None
Rm. A200C - Girl's Bathroom	Sink	Public Access	HWS-102	HW-S368	< 1.0	None
Rm. A200D - Boy's Bathroom	Sink	Public Access	HWS-101	HW-S367	< 1.0	None
Rm. A200E - Boy's Bathroom	Sink	Public Access	HWS-099	HW-S365	1.0	None
Rm. A202B - Classroom	Sink	Public Access	HWS-100	HW-S366	3.3	None
Rm. A205A - Hallway/Corridor	Fountain	Public Access	HWS-130	HW-F310	< 1.0	None
Rm. A206B - Staff's Bathroom	Sink	Secured - SCSD Staff Only	HWS-098	HW-S364	1.7	None
Rm. A208A - Copy Room	Sink	Secured - SCSD Staff Only	HWS-097	HW-S363	1.9	None
Rm. A209B - Boy's Bathroom	Sink	Public Access	HWS-096	HW-S362	1.0	None
Rm. A214A - Girl's Bathroom	Sink	Public Access	HWS-094	HW-S360	1.0	None
Rm. A215B - Boy's Bathroom	Sink	Public Access	HWS-095	HW-S361	< 1.0	None
Rm. A216B - Girl's Bathroom	Sink	Public Access	HWS-093	HW-S359	1.2	None
Rm. B-03 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-001	HW-S100	5.6	None

SYRACUSE CITY SCHOOL DISTRICT

HW SMITH PK - GRADE 8 SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATES: 12/15/2016 and 12/16/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. B104 - Hallway/Corridor	Fountain	Public Access	HWS-129	HW-F309	< 1.0	None
Rm. B106 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-026	HW-S126	< 1.0	None
Rm. B106 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-027	HW-S127	1.1	None
Rm. B109 - Boy's Locker Room	Fountain	Public Access	HWS-117	HW-F105	< 1.0	None
Rm. B112 - Boy's Bathroom	Sink	Public Access	HWS-017	HW-S116	31.0	SCSD removed fixture from service and is to replace
Rm. B116A - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	HWS-018	HW-S117	2.7	None
Rm. B119A - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	HWS-019	HW-S118	< 1.0	None
Rm. B123 - Girl's Bathroom	Sink	Public Access	--	HW-S119	--	Fixture not operating
Rm. B126 - Girl's Locker Room	Fountain	Public Access	HWS-118	HW-F106	< 1.0	None
Rm. B128 - OT/PT Room	Sink	Public Access	HWS-021	HW-S121	< 1.0	None
Rm. B128A - OT/PT Room Bathroom	Sink	Public Access	HWS-020	HW-S120	< 1.0	None
Rm. B131 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-082	HW-S347	2.4	None
Rm. B132 - Dental Room	Sink	Public Access	HWS-081	HW-S346	< 1.0	None
Rm. B133 - Health Center Bathroom	Sink	Public Access	HWS-084	HW-S349	2.1	None
Rm. B134 - Hallway/Corridor	Fountain	Public Access	HWS-116	HW-F104	< 1.0	None
Rm. B135B - Exam Room	Sink	Public Access	HWS-087	HW-S353	2.1	None
Rm. B136 - Health Center	Sink	Public Access	HWS-083	HW-S348	1.1	None
Rm. B138 - Nurse's Room	Sink	Public Access	HWS-086	HW-S352	1.4	None
Rm. B138A - Nurse's Bathroom	Sink	Public Access	HWS-085	HW-S351	8.0	None
Rm. B147 - Staff Office Bathroom	Sink	Secured - SCSD Staff Only	HWS-090	HW-S356	2.5	None
Rm. B149 - Main Office	Sink	Secured - SCSD Staff Only	HWS-091	HW-S357	8.2	None
Rm. B164 - Library Bathroom	Sink	Public Access	HWS-092	HW-S358	< 1.0	None
Rm. B168 - Conference Room	Sink	Secured - SCSD Staff Only	HWS-089	HW-S355	1.7	None
Rm. B171 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-088	HW-S354	< 1.0	None
Rm. B172 - Work Room	Sink	Secured - SCSD Staff Only	HWS-025	HW-S125	< 1.0	None
Rm. B173 - Work Room Bathroom	Sink	Secured - SCSD Staff Only	HWS-024	HW-S124	< 1.0	None
Rm. B174 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-023	HW-S123	< 1.0	None
Rm. B176 - Classroom Bathroom	Sink	Public Access	HWS-022	HW-S122	1.4	None
Rm. B204 - Hallway/Corridor	Fountain	Public Access	HWS-120	HW-F108	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT

HW SMITH PK - GRADE 8 SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATES: 12/15/2016 and 12/16/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. B209 - Hallway/Corridor	Fountain	Public Access	HWS-119	HW-F107	< 1.0	None
Rm. B210 - Girl's Bathroom	Sink	Public Access	HWS-032	HW-S132	1.6	None
Rm. B210 - Girl's Bathroom	Sink	Public Access	HWS-033	HW-S133	1.3	None
Rm. B210 - Girl's Bathroom	Sink	Public Access	HWS-034	HW-S134	1.8	None
Rm. B211 - Boy's Bathroom	Sink	Public Access	HWS-035	HW-S135	1.2	None
Rm. B211 - Boy's Bathroom	Sink	Public Access	HWS-036	HW-S136	2.0	None
Rm. B220 - Band Room	Sink	Public Access	HWS-037	HW-S137	2.4	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-104	HW-S370	< 1.0	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-105	HW-S371	4.3	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-106	HW-S372	2.5	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-107	HW-S373	1.5	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-108	HW-S374	< 1.0	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-109	HW-S375	< 1.0	None
Rm. B222B - Kitchen Serving Area	Sink	Secured - SCSD Staff Only	HWS-111	HW-S377	< 1.0	None
Rm. B224 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	HWS-110	HW-S376	2.3	None
Rm. B231A - Classroom Bathroom	Sink	Public Access	HWS-031	HW-S131	< 1.0	None
Rm. B232A - Classroom Bathroom	Sink	Public Access	HWS-030	HW-S130	< 1.0	None
Rm. B233A - Classroom Bathroom	Sink	Public Access	HWS-029	HW-S129	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620560
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.