

SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	01/13/18 RESAMPLE RESULTS (ppb)	01/13/18 RESAMPLE ACTIONS
Rm. B-2 - Storage Room	Sink	Secured - SCSD Staff Only	GT-069	GT-S204	1.5	None	--	--
Rm. B-13 - Girl's Locker Room Bathroom	Sink	Public Access	GT-067	GT-S202	160.0	*See Note 6	<1.0	None
Rm. B-13 - Girl's Locker Room Bathroom	Sink	Public Access	GT-068	GT-S203	15.0	*See Note 6	<1.0	None
Rm. B-16 - Boy's Locker Room	Fountain	Public Access	GT-104	GT-F201	3.6	None	--	--
Rm. B-18 - Boy's Locker Room Bathroom	Sink	Public Access	GT-065	GT-S(M)200	25.0	*See Note 7	<1.0	None
Rm. B-18 - Boy's Locker Room Bathroom	Sink	Public Access	GT-066	GT-S201	7.8	*See Note 6	--	--
Rm. 107D - Office Bathroom	Sink	Secured - SCSD Staff Only	GT-081	GT-S216	4.7	None	--	--
Rm. 108B - Exam Room	Sink	Public Access	GT-082	GT-S217	3.5	None	--	--
Rm. 109 - Nurse's Office	Sink	Public Access	GT-083	GT-S218	2.8	None	--	--
Rm. 109A - Nurse's Office Bathroom	Sink	Public Access	GT-084	GT-S219	1.6	None	--	--
Rm. 110 - Classroom	Sink	Public Access	GT-085	GT-S220	2.8	None	--	--
Rm. 115 - Music Room	Sink	Public Access	GT-091	GT-S226	19.0	*See Note 7	10.0	None
Rm. 117 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	GT-088	GT-S223	6.2	None	--	--
Rm. 118 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	GT-087	GT-S222	2.8	None	--	--
Rm. 120 - Hallway/Corridor	Fountain	Public Access	GT-107	GT-F206	< 1.0	None	--	--
Rm. 120 - Hallway/Corridor	Fountain	Public Access	--	GT-F204	--	*See Note 8	<1.0	None
Rm. 120 - Hallway/Corridor	Fountain	Public Access	--	GT-F205	--	*See Note 8	<1.0	None
Rm. 123 - Work Room	Sink	Secured - SCSD Staff Only	GT-086	GT-S221	5.8	None	--	--
Rm. 131 - Serving Room	Sink	Secured - SCSD Staff Only	GT-077	GT-S212	1.8	None	--	--
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	GT-010	GT-S109	< 1.0	None	--	--
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	GT-013	GT-S112	< 1.0	None	--	--
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	GT-014	GT-S113	< 1.0	None	--	--
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	GT-015	GT-S114	2.7	None	--	--
Rm. 132B - Dental Office	Sink	Public Access	GT-016	GT-S115	3.0	None	--	--
Rm. 132B - Dental Office	Sink (Chair)	Public Access	GT-017	GT-S116	< 1.0	None	--	--
Rm. 132F - Examination Room	Sink	Public Access	GT-012	GT-S111	< 1.0	None	--	--
Rm. 132G - Medical Assistance Bathroom	Sink	Public Access	GT-011	GT-S110	< 1.0	None	--	--
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-071	GT-S206	1.2	None	--	--
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-072	GT-S207	15.0	*See Note 7	1.2	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-073	GT-S208	1.4	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	01/13/18 RESAMPLE RESULTS (ppb)	01/13/18 RESAMPLE ACTIONS
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-074	GT-S209	< 1.0	None	--	--
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-075	GT-S210	3.6	None	--	--
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-078	GT-S213	< 1.0	None	--	--
Rm. 134A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	GT-076	GT-S211	6.4	None	--	--
Rm. 137 - Girl's Locker Room Bathroom	Sink	Public Access	GT-018	GT-S117	5.7	None	--	--
Rm. 139 - Hallway/Corridor	Fountain	Public Access	GT-105	GT-F202	< 1.0	None	--	--
Rm. 139 - Hallway/Corridor	Fountain	Public Access	GT-106	GT-F203	< 1.0	None	--	--
Rm. 140 - Boy's Locker Room Bathroom	Sink	Public Access	GT-019	GT-S118	8.6	None	--	--
Rm. 140B - Swimming Pool Office	Sink	Secured - SCSD Staff Only	GT-020	GT-S119	5.6	None	--	--
Rm. 151 - Hallway/Vestibule	Fountain	Public Access	GT-057	GT-F100	< 1.0	None	--	--
Rm. 151 - Hallway/Vestibule	Sink	Public Access	GT-001	GT-S100	21.0	*See Note 7	<1.0	None
Rm. 151 - Hallway/Vestibule	Sink	Public Access	GT-002	GT-S101	2.3	None	--	--
Rm. 162 - Hallway/Vestibule	Sink	Public Access	GT-092	GT-S227	1.1	None	--	--
Rm. 162 - Hallway/Vestibule	Sink	Public Access	GT-093	GT-S228	3.4	None	--	--
Rm. 169 - Work Room	Sink	Secured - SCSD Staff Only	GT-089	GT-S224	3.8	None	--	--
Rm. 170 - Audio/Video Storage	Sink	Secured - SCSD Staff Only	GT-090	GT-S225	16.0	*See Note 7	<1.0	None
Rm. 175 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	GT-070	GT-S205	3.6	None	--	--
Rm. 177A - Computer Lab Bathroom	Sink	Public Access	GT-096	GT-S231	7.3	None	--	--
Rm. 177B - Computer Lab Bathroom	Sink	Public Access	GT-097	GT-S232	15.0	*See Note 7	<1.0	None
Rm. 182 - Classroom	Sink	Public Access	GT-004	GT-S103	< 1.0	None	--	--
Rm. 182A - Nurse's Waiting Room	Sink	Public Access	GT-007	GT-S106	< 1.0	None	--	--
Rm. 182B - Classroom Office	Sink	Public Access	GT-005	GT-S104	5.5	None	--	--
Rm. 182D - Examination Room	Sink	Public Access	GT-009	GT-S108	5.8	None	--	--
Rm. 182E - Nurse's Office Bathroom	Sink	Public Access	GT-008	GT-S107	< 1.0	None	--	--
Rm. 182G - Sick/Rest Waiting Room	Sink	Public Access	GT-006	GT-S105	< 1.0	None	--	--
Rm. 183 - Girl's Bathroom	Sink	Public Access	GT-079	GT-S214	3.7	None	--	--
Rm. 183 - Girl's Bathroom	Sink	Public Access	GT-080	GT-S215	3.2	None	--	--
Rm. 184 - Swimming Pool	Fountain	Public Access	GT-058	GT-F101	3.7	None	--	--
Rm. 185C - Office	Sink	Secured - SCSD Staff Only	GT-003	GT-S102	3.3	None	--	--
Rm. 189 - Boy's Bathroom	Sink	Public Access	GT-094	GT-S229	1.4	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	01/13/18 RESAMPLE RESULTS (ppb)	01/13/18 RESAMPLE ACTIONS
Rm. 189 - Boy's Bathroom	Sink	Public Access	GT-095	GT-S230	1.1	None	--	--
Rm. 203 - Classroom	Sink	Public Access	GT-025	GT-S124	1.7	None	--	--
Rm. 204 - Classroom Bathroom	Sink	Public Access	GT-024	GT-S123	3.4	None	--	--
Rm. 207 - Girl's Bathroom	Sink	Public Access	GT-033	GT-S132	6.1	None	--	--
Rm. 208 - Hallway/Corridor	Fountain	Public Access	GT-061	GT-F104	< 1.0	None	--	--
Rm. 211 - Girl's Locker Room	Sink	Public Access	GT-031	GT-S130	8.4	None	--	--
Rm. 211 - Girl's Locker Room	Sink	Public Access	GT-032	GT-S131	5.5	None	--	--
Rm. 212 - Girl's Coach Office	Sink	Secured - SCSD Staff Only	GT-030	GT-S129	5.0	None	--	--
Rm. 214 - Boy's Bathroom	Sink	Public Access	GT-034	GT-S133	26.0	*See Note 7	<1.0	None
Rm. 218 - Hallway/Vestibule	Sink	Public Access	GT-047	GT-S146	7.7	None	--	--
Rm. 218 - Hallway/Vestibule	Sink	Public Access	GT-048	GT-S147	5.4	None	--	--
Rm. 227 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	GT-043	GT-S142	2.0	None	--	--
Rm. 227B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	GT-041	GT-S140	13.0	None	--	--
Rm. 228A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	GT-042	GT-S141	8.9	None	--	--
Rm. 234A - Art Storage Room	Sink	Public Access	GT-046	GT-S145	12.0	None	--	--
Rm. 238A - Classroom Bathroom	Sink	Public Access	GT-037	GT-S136	5.4	None	--	--
Rm. 242A - Work Room	Sink	Secured - SCSD Staff Only	GT-049	GT-S148	10.0	None	--	--
Rm. 242A - Work Room	Sink	Secured - SCSD Staff Only	GT-050	GT-S149	24.0	*See Note 9	--	--
Rm. 250 - Boy's Bathroom	Sink	Public Access	GT-044	GT-S143	5.9	None	--	--
Rm. 250 - Boy's Bathroom	Sink	Public Access	GT-045	GT-S144	8.0	None	--	--
Rm. 255 - Hallway/Corridor	Fountain	Public Access	GT-062	GT-F105	< 1.0	None	--	--
Rm. 255 - Hallway/Corridor	Fountain	Public Access	GT-063	GT-F106	< 1.0	None	--	--
Rm. 260 - Girl's Bathroom	Sink	Public Access	GT-038	GT-S137	5.2	None	--	--
Rm. 260 - Girl's Bathroom	Sink	Public Access	GT-039	GT-S138	4.5	None	--	--
Rm. 260 - Girl's Bathroom	Sink	Public Access	GT-040	GT-S139	5.7	None	--	--
Rm. 262 - Hallway/Vestibule	Sink	Public Access	GT-035	GT-S134	4.8	None	--	--
Rm. 262 - Hallway/Vestibule	Sink	Public Access	GT-036	GT-S135	2.3	None	--	--
Rm. 270 - Hallway/Vestibule	Fountain	Public Access	GT-059	GT-F102	< 1.0	None	--	--
Rm. 272 - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	GT-028	GT-S127	8.3	None	--	--
Rm. 273 - Boy's Locker Room Bathroom	Sink	Public Access	GT-029	GT-S128	2.7	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	01/13/18 RESAMPLE RESULTS (ppb)	01/13/18 RESAMPLE ACTIONS
Rm. 275 - Boy's Locker Room	Fountain	Public Access	GT-060	GT-F103	1.8	None	--	--
Rm. 294 - Home & Careers Room	Sink	Public Access	GT-026	GT-S125	2.3	None	--	--
Rm. 294 - Home & Careers Room	Sink	Public Access	GT-027	GT-S126	3.8	None	--	--
Rm. 296 - Home & Careers Room	Sink	Public Access	GT-021	GT-S120	11.0	None	--	--
Rm. 296 - Home & Careers Room	Sink	Public Access	GT-022	GT-S121	2.2	None	--	--
Rm. 296 - Home & Careers Room	Sink	Public Access	GT-023	GT-S122	< 1.0	None	--	--
Rm. 308 - Hallway/Corridor	Fountain	Public Access	GT-064	GT-F107	< 1.0	None	--	--
Rm. 308 - Hallway/Corridor	Fountain	Public Access	GT-110	GT-F209	< 1.0	None	--	--
Rm. 308 - Hallway/Corridor	Fountain	Public Access	GT-111	GT-F210	< 1.0	None	--	--
Rm. 315 - Hallway/Vestibule	Sink	Public Access	GT-051	GT-S150	4.7	None	--	--
Rm. 315 - Hallway/Vestibule	Sink	Public Access	GT-052	GT-S151	1.9	None	--	--
Rm. 315 - Hallway/Vestibule	Sink	Public Access	GT-098	GT-S233	2.0	None	--	--
Rm. 315 - Hallway/Vestibule	Sink	Public Access	GT-099	GT-S234	3.2	None	--	--
Rm. 317 - Work Room	Sink	Secured - SCSD Staff Only	GT-102	GT-S237	5.3	None	--	--
Rm. 317 - Work Room	Sink	Secured - SCSD Staff Only	GT-103	GT-S238	14.0	None	--	--
Rm. 319 - Art Storage Room	Sink	Public Access	GT-056	GT-S155	1200.0	*See Note 6	--	--
Rm. 326 - Hallway/Corridor	Fountain	Public Access	GT-108	GT-F207	1.2	None	--	--
Rm. 326 - Hallway/Corridor	Fountain	Public Access	GT-109	GT-F208	< 1.0	None	--	--
Rm. 344 - Girl's Bathroom	Sink	Public Access	GT-053	GT-S152	7.7	None	--	--
Rm. 344 - Girl's Bathroom	Sink	Public Access	GT-054	GT-S153	2.6	None	--	--
Rm. 344 - Girl's Bathroom	Sink	Public Access	GT-055	GT-S154	7.8	None	--	--
Rm. 375 - Boy's Bathroom	Sink	Public Access	GT-100	GT-S235	3.7	None	--	--
Rm. 375 - Boy's Bathroom	Sink	Public Access	GT-101	GT-S236	7.2	None	--	--

Original Notes (October 7, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-043
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1621052
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to permanently remove from service.
7. SCSD to remove and replace fixture.
8. Fixture not operating.
9. SCSD to post warning sign.

Resampling Notes (January 13, 2018 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-043
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1800746; January 19, 2018
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.