

**SYRACUSE CITY SCHOOL DISTRICT  
WESTSIDE ACADEMY AT BLODGETT SCHOOL**

SAMPLE DATE: 10/25/2016 ANALYSIS DATES: 12/27/2016, 12/28/2016, 12/29/2016, 01/02/2017, 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 101 - Boy's Bathroom	Sink	Public Access	BT2-017	BT-S414	23.0	SCSD removed fixture from service and is to replace
Rm. 101 - Boy's Bathroom	Sink	Public Access	BT2-018	BT-S415	23.0	SCSD removed fixture from service and is to replace
Rm. 102 - Classroom	Sink	Public Access	BT2-003	BT-S400	9.6	None
Rm. 106 - Classroom	Sink	Public Access	BT2-011	BT-S408	34.0	SCSD removed fixture from service and is to replace
Rm. 106 - Classroom	Sink	Public Access	BT2-015	BT-S412	4.6	None
Rm. 106 - Classroom	Sink	Public Access	BT2-016	BT-S413	11.0	None
Rm. 116 - Classroom	Fountain	Public Access	BT2-035	BT-F401	< 1.0	None
Rm. 110 - Parent Room	Sink	Secured - SCSD Staff Only	BT2-013	BT-S410	1.3	None
Rm. 110 - Parent Room	Sink	Secured - SCSD Staff Only	BT2-014	BT-S411	< 1.0	None
Rm. 115 - Girl's Bathroom	Sink	Public Access	BT-007	BT-S404	44.0	SCSD removed fixture from service and is to replace
Rm. 115 - Girl's Bathroom	Sink	Public Access	BT2-008	BT-S405	19.0	SCSD removed fixture from service and is to replace
Rm. 115 - Girl's Bathroom	Sink	Public Access	BT2-009	BT-S406	28.0	SCSD removed fixture from service and is to replace
Rm. 118 - Art Room	Sink	Public Access	BT2-021	BT-S418	< 1.0	None
Rm. 119 - Lounge	Sink	Secured - SCSD Staff Only	BT2-020	BT-S417	4.6	None
Rm. 124 - Classroom	Sink	Public Access	BT2-006	BT-S403	< 1.0	None
Rm. 133 - Boiler/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	BT2-002	BT-M400	8.9	None
Rm. 136 - Classroom Bathroom	Sink	Public Access	BT2-010	BT-S407	6.9	None
Rm. 142A - Classroom	Sink	Public Access	BT2-012	BT-S409	7.2	None
Rm. 145A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	BT2-025	BT-S422	< 1.0	None
Rm. 147A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	BT2-026	BT-S423	< 1.0	None
Rm. 149A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	BT2-029	BT-S426	3.9	None
Rm. 159 - Hallway/Corridor	Fountain	Public Access	BT2-037	BT-F403	50.0	SCSD removed fixture from service and is to replace
Rm. 159 - Hallway/Corridor	Fountain	Public Access	BT2-036	BT-F402	< 1.0	None
Rm. 161 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT2-027	BT-S424	3.6	None
Rm. 161 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT2-028	BT-S425	2.8	None
Rm. 163 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT2-023	BT-S420	2.5	None
Rm. 163 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT2-024	BT-S421	3.2	None
Rm. 164 - Classroom	Sink	Public Access	BT2-004	BT-S401	27.0	SCSD removed fixture from service and is to replace
Rm. 168 - Classroom Bathroom	Sink	Public Access	BT2-005	BT-S402	4.1	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**WESTSIDE ACADEMY AT BLODGETT SCHOOL**

SAMPLE DATE: 10/25/2016 ANALYSIS DATES: 12/27/2016, 12/28/2016, 12/29/2016, 01/02/2017, 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 175A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	BT2-022	BT-S419	2.9	None
Rm. 184 - Hallway/Corridor	Fountain	Public Access	BT2-034	BT-F400	< 1.0	None
Rm. 192 - Hallway/Passageway	Sink	Public Access	BT2-019	BT-S416	10.0	None
Rm. 202 - Classroom	Sink	Public Access	BT1-009	BT-S324	1.7	None
Rm. 203 - Girl's Bathroom	Sink	Public Access	BT1-004	BT-S319	83.0	SCSD removed fixture from service and is to replace
Rm. 203 - Girl's Bathroom	Sink	Public Access	BT1-005	BT-S320	23.0	SCSD removed fixture from service and is to replace
Rm. 203 - Girl's Bathroom	Sink	Public Access	BT1-006	BT-S321	48.0	SCSD removed fixture from service and is to replace
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-010	BT-S325	1.9	None
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-011	BT-S326	1.7	None
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-012	BT-S327	1.9	None
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-013	BT-S328	33.0	SCSD removed fixture from service and is to replace
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-014	BT-S329	3.2	None
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-015	BT-S330	19.0	SCSD removed fixture from service and is to replace
Rm. 206 - Health Center	Sink	Public Access	BT1-016	BT-S331	2.0	None
Rm. 206 - Health Center	Sink	Public Access	BT1-017	BT-S332	1.7	None
Rm. 206 - Health Center Bathroom	Sink	Public Access	BT1-018	BT-S333	1.4	None
Rm. 207 - Office Bathroom	Sink	Secured - SCSD Staff Only	BT1-019	BT-S334	1.9	None
Rm. 215 - Cafeteria	Sink	Secured - SCSD Staff Only	BT2-001	BT-S337	16.0	SCSD permanently removed fixture from service
Rm. 217A - Boy's Bathroom	Sink	Public Access	BT1-020	BT-S335	6.4	None
Rm. 217A - Boy's Bathroom	Sink	Public Access	BT1-021	BT-S336	4.9	None
Rm. 221 - Hallway/Corridor	Fountain	Secured - SCSD Staff Only	BT1-008	BT-F323	1.0	None
Rm. 221A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT1-007	BT-S322	18.0	SCSD removed fixture from service and is to replace
Rm. 226 - Cafeteria	Fountain	Public Access	BT2-038	BT-F404	53.0	SCSD removed fixture from service and is to replace
Rm. 226 - Cafeteria	Sink	Public Access	BT2-030	BT-S427	22.0	SCSD removed fixture from service and is to replace
Rm. 227B - Storage Room	Sink	Secured - SCSD Staff Only	BT2-032	BT-S429	3.9	None
Rm. 227B - Storage Room	Sink	Secured - SCSD Staff Only	BT2-033	BT-S430	1.2	None
Rm. 227E - Serving Room	Sink	Secured - SCSD Staff Only	BT2-031	BT-S428	5.5	None
Rm. 303 - Girl's Bathroom	Sink	Public Access	BT1-031	BT-S310	5.4	None
Rm. 303 - Girl's Bathroom	Sink	Public Access	BT1-032	BT-S311	7.3	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**WESTSIDE ACADEMY AT BLODGETT SCHOOL**

SAMPLE DATE: 10/25/2016 ANALYSIS DATES: 12/27/2016, 12/28/2016, 12/29/2016, 01/02/2017, 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 303 - Girl's Bathroom	Sink	Public Access	BT1-033	BT-S312	6.5	None
Rm. 309 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT1-036	BT-S315	3.5	None
Rm. 309 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT1-001	BT-S316	4.1	None
Rm. 310 - Classroom	Sink	Public Access	BT1-034	BT-S313	16.0	SCSD removed fixture from service and is to replace
Rm. 311 - Boy's Bathroom	Sink	Public Access	BT1-002	BT-S317	18.0	SCSD removed fixture from service and is to replace
Rm. 311 - Boy's Bathroom	Sink	Public Access	BT1-003	BT-S318	11.0	None
Rm. 318 - Hallway/Corridor	Fountain	Public Access	BT1-035	BT-F314	1.2	None
Rm. 400 - Classroom	Sink	Public Access	BT1-023	BT-S302	1.2	None
Rm. 401 - Classroom	Sink	Public Access	BT1-022	BT-S301	3.3	None
Rm. 411 - Classroom	Sink	Public Access	BT1-028	BT-S307	10.0	None
Rm. 413 - Girl's Bathroom	Sink	Public Access	BT1-024	BT-S303	23.0	SCSD removed fixture from service and is to replace
Rm. 413 - Girl's Bathroom	Sink	Public Access	BT1-025	BT-S304	7.9	None
Rm. 413 - Girl's Bathroom	Sink	Public Access	BT1-026	BT-S305	7.0	None
Rm. 423 - Hallway/Corridor	Fountain	Public Access	BT1-027	BT-F306	< 1.0	None
Rm. 430 - Boy's Bathroom	Sink	Public Access	BT1-029	BT-S308	2.2	None
Rm. 430 - Boy's Bathroom	Sink	Public Access	BT1-030	BT-S309	2.3	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620943, 1620944
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.