

**SYRACUSE CITY SCHOOL DISTRICT
PORTER ELEMENTARY SCHOOL**

SAMPLE DATE: 09/27/2016 ANALYSIS DATES: 12/19/2016 and 12/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 001 - Hallway/Corridor	Fountain	Public Access	064	PR-F303	< 1.0	None
Rm. 001C - Hallway/Corridor	Fountain	Public Access	063	PR-F302	< 1.0	None
Rm. 001C - Hallway/Corridor	Fountain	Public Access	062	PR-F301	< 1.0	None
Rm. 003 - Custodian's Office	Sink	Secured - SCSD Staff Only	014	PR-S313	3.0	None
Rm. 004A - Classroom Bathroom	Sink	Public Access	012	PR-S311	1.9	None
Rm. 005A - Classroom Bathroom	Sink	Public Access	011	PR-S310	2.0	None
Rm. 007 - Boy's Bathroom	Sink	Public Access	004	PR-S303	1.3	None
Rm. 007 - Boy's Bathroom	Sink	Public Access	005	PR-S304	< 1.0	None
Rm. 009 - Girl's Bathroom	Sink	Public Access	002	PR-S301	5.6	None
Rm. 009 - Girl's Bathroom	Sink	Public Access	003	PR-S302	1.1	None
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	007	PR-S306	< 1.0	None
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	008	PR-S307	2.0	None
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	009	PR-S308	2.0	None
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	010	PR-S309	6.1	None
Rm. 010C - Staff Bathroom	Sink	Secured - SCSD Staff Only	006	PR-S305	6.2	None
Rm. 014A - Classroom Bathroom	Sink	Public Access	013	PR-S312	6.1	None
Rm. 021A - Classroom Bathroom	Sink	Public Access	020	PR-S319	29.0	SCSD removed fixture from service and is to replace
Rm. 022 - Classroom	Fountain	Public Access	066	PR-F305	< 1.0	None
Rm. 022B - Classroom Bathroom	Sink	Public Access	023	PR-S322	7.6	None
Rm. 024 - Classroom	Sink	Public Access	022	PR-S321	2.8	None
Rm. 024 - Classroom	Fountain	Public Access	065	PR-F304	< 1.0	None
Rm. 024A - Classroom Bathroom	Sink	Public Access	021	PR-S320	3.7	None
Rm. 025A - Classroom Bathroom	Sink	Public Access	019	PR-S318	3.2	None
Rm. 026 - Staff's Lounge	Sink	Secured - SCSD Staff Only	015	PR-S314	2.3	None
Rm. 026A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	016	PR-S315	1.8	None
Rm. 026A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	017	PR-S316	7.4	None
Rm. 026B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	018	PR-S317	3.4	None
Rm. 036B - Hallway/Corridor	Fountain	Public Access	067	PR-F306	< 1.0	None
Rm. 037 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	024	PR-S323	42.0	SCSD removed fixture from service and is to replace

**SYRACUSE CITY SCHOOL DISTRICT
PORTER ELEMENTARY SCHOOL**

SAMPLE DATE: 09/27/2016 ANALYSIS DATES: 12/19/2016 and 12/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 038 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	026	PR-S325	24.0	SCSD removed fixture from service and is to replace
Rm. 041A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	025	PR-S324	8.0	None
Rm. 044 - Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	001	PR-S300	28.0	SCSD to post warning sign
Rm. 101 - Hallway/Corridor	Fountain	Public Access	068	PR-F307	< 1.0	None
Rm. 102D - Principal's Bathroom	Sink	Secured - SCSD Staff Only	037	PR-S336	140.0	SCSD removed fixture from service and is to replace
Rm. 102I - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	035	PR-S334	67.0	SCSD removed fixture from service and is to replace
Rm. 102J - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	036	PR-S335	8.5	None
Rm. 103A Assist. Principal's Bathroom	Sink	Secured - SCSD Staff Only	034	PR-S333	7.4	None
Rm. 104A - Office Bathroom	Sink	Secured - SCSD Staff Only	033	PR-S332	6.4	None
Rm. 106 - Classroom	Sink	Public Access	032	PR-S331	9.2	None
Rm. 107 - Boy's Bathroom	Sink	Public Access	030	PR-S329	< 1.0	None
Rm. 107 - Boy's Bathroom	Sink	Public Access	031	PR-S330	< 1.0	None
Rm. 109 - Girl's Bathroom	Sink	Public Access	028	PR-S327	18.0	SCSD removed fixture from service and is to replace
Rm. 109 - Girl's Bathroom	Sink	Public Access	029	PR-S328	< 1.0	None
Rm. 110A - Library Office	Sink	Secured - SCSD Staff Only	027	PR-S326	2.6	None
Rm. 116 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	039	PR-S338	12.0	None
Rm. 118C - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	042	PR-S341	4.2	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	043	PR-S342	< 1.0	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	044	PR-S343	3.3	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	045	PR-S344	1.5	None
Rm. 125A - Exam Room	Sink	Public Access	041	PR-S340	1.4	None
Rm. 125B - Exam Room Bathroom	Sink	Public Access	040	PR-S339	10.0	None
Rm. 127 - Parent's Room	Sink	Public Access	038	PR-S337	1.7	None
Rm. 201 - Hallway/Corridor	Fountain	Public Access	069	PR-F308	< 1.0	None
Rm. 202A - Resource Room Bathroom	Sink	Public Access	053	PR-S352	23.0	SCSD removed fixture from service and is to replace
Rm. 203 - Classroom	Sink	Public Access	052	PR-S351	3.7	None
Rm. 206 - Classroom	Sink	Public Access	051	PR-S350	1.5	None
Rm. 207 - Boy's Bathroom	Sink	Public Access	048	PR-S347	3.2	None
Rm. 207 - Boy's Bathroom	Sink	Public Access	049	PR-S348	< 1.0	None

**SYRACUSE CITY SCHOOL DISTRICT
PORTER ELEMENTARY SCHOOL**

SAMPLE DATE: 09/27/2016 ANALYSIS DATES: 12/19/2016 and 12/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 209 - Girl's Bathroom	Sink	Public Access	046	PR-S345	< 1.0	None
Rm. 209 - Girl's Bathroom	Sink	Public Access	047	PR-S346	1.2	None
Rm. 212 - Classroom	Sink	Public Access	050	PR-S349	29.0	SCSD removed fixture from service and is to replace
Rm. 218 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	057	PR-S356	3.5	None
Rm. 220A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	058	PR-S357	15.0	SCSD removed fixture from service and is to replace
Rm. 221 - Hallway/Vestibule	Sink	Public Access	059	PR-S358	2.3	None
Rm. 221 - Hallway/Vestibule	Sink	Public Access	060	PR-S359	11.0	None
Rm. 221 - Hallway/Vestibule	Sink	Public Access	061	PR-S360	< 1.0	None
Rm. 226 - Classroom	Sink	Public Access	056	PR-S355	6.4	None
Rm. 228 - Art Room	Sink	Public Access	054	PR-S353	72.0	SCSD permanently removed fixture from service
Rm. 228 - Art Room	Sink	Public Access	055	PR-S354	30.0	SCSD permanently removed fixture from service

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-021
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620702
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.