

**SYRACUSE CITY SCHOOL DISTRICT**  
**JOHNSON VOCATIONAL CENTER SCHOOL**  
SAMPLE DATE: 10/28/2016 ANALYSIS DATES: 12/20/2016 and 01/04/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. B05 - Mechanical/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	JN-001	JN-M300	1300.0	SCSD to post warning sign
Rm. 104 - Principal's Office	Sink	Secured - SCSD Staff Only	JN-013	JN-S312	2.5	None
Rm. 105 - Main Office	Sink	Secured - SCSD Staff Only	JN-012	JN-S311	5.6	None
Rm. 107 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	JN-015	JN-S314	3.7	None
Rm. 108 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	JN-014	JN-S313	3.8	None
Rm. 115 - Classroom	Sink	Public Access	JN-016	JN-S315	1.0	None
Rm. 115 - Classroom	Sink	Public Access	JN-017	JN-S316	1.2	None
Rm. 115B - Kitchen	Sink	Secured - SCSD Staff Only	JN-020	JN-S319	1.3	None
Rm. 115E - Classroom Bathroom	Sink	Public Access	JN-018	JN-S317	2.3	None
Rm. 115E - Classroom Bathroom	Sink	Public Access	JN-019	JN-S318	4.0	None
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	JN-021	JN-S320	15.0	SCSD removed fixture from service and is to replace
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	JN-022	JN-S321	5.1	None
Rm. 123 - Hallway/Corridor	Sink	Public Access	JN-023	JN-S322	< 1.0	None
Rm. 125 - Hallway/Corridor	Fountain	Public Access	JN-024	JN-F323	< 1.0	None
Rm. 128 - Technology Shop	Sink	Public Access	JN-025	JN-S324	1.0	None
Rm. 132 - Technology Shop Bathroom	Sink	Public Access	JN-026	JN-S325	1.1	None
Rm. 141 - Auto Shop	Fountain	Public Access	JN-030	JN-F329	2.6	None
Rm. 141 - Auto Shop	Sink	Public Access	JN-029	JN-S328	2.5	None
Rm. 142 - Welding Shop	Sink	Public Access	JN-027	JN-S326	5.7	None
Rm. 142 - Welding Shop	Sink	Public Access	JN-028	JN-S327	5.7	None
Rm. 207 - Hallway/Vestibule	Sink	Public Access	JN-005	JN-S304	1.4	None
Rm. 207 - Hallway/Vestibule	Sink	Public Access	JN-006	JN-S305	1.4	None
Rm. 211 - Nurse's Office Bathroom	Sink	Public Access	JN-003	JN-S302	1.9	None
Rm. 213 - Laundry Room	Sink	Secured - SCSD Staff Only	JN-004	JN-S303	54.0	SCSD removed fixture from service and is to replace
Rm. 214 - Nurse's Office	Sink	Public Access	JN-002	JN-S301	4.0	None
Rm. 218A - Cosmetology Room	Sink	Public Access	JN-009	JN-S308	6.6	None
Rm. 218C - Classroom	Sink	Public Access	JN-008	JN-S307	2.6	None
Rm. 219 - Hallway/Corridor	Fountain	Public Access	JN-007	JN-F306	1.9	None
Rm. 222A - Lounge	Sink	Secured - SCSD Staff Only	JN-011	JN-S310	6.8	None
Rm. 227 - Classroom	Sink	Public Access	JN-010	JN-S309	6.4	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**JOHNSON VOCATIONAL CENTER SCHOOL**  
SAMPLE DATE: 10/28/2016 ANALYSIS DATES: 12/20/2016 and 01/04/2017

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620739
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.