

**SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL**

SAMPLE DATES: 10/09/2016, 10/21/2016 and 10/27/2016 ANALYSIS DATES: 11/28/2016, 12/26/2016, 12/27/2016, 12/29/2016 and 01/06/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'A'						
Rm. A8 - Mechanical/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	CN-001	CN-M400	4.7	None
Rm. A100C - Conference Room	Sink	Public Access	CN-027	CN-S425	5.8	None
Rm. A105 - Kitchenette (Between Classrooms)	Sink	Public Access	CN-025	CN-S423	< 1.0	None
Rm. A106 - Kitchen	Ice Machine	Secured - SCSD Staff Only	CN-002	CN-S400	< 1.0	None
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-003	CN-S401	8.3	None
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-004	CN-S402	3.2	None
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-005	CN-S403	2.7	None
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-006	CN-S404	3.7	None
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-007	CN-S405	2.5	None
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-008	CN-S406	2.5	None
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-009	CN-S407	5.2	None
Rm. A106/A157 - Kitchen	Sink	Secured - SCSD Staff Only	CN-010	CN-S408	7.8	None
Rm. A109 - Clinic Office	Sink	Public Access	CN-011	CN-S409	< 1.0	None
Rm. A111 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	CN-014	CN-S412	2.0	None
Rm. A111 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-020	CN-S418	1.4	None
Rm. A113 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-019	CN-S417	1.5	None
Rm. A114 - Girl's Bathroom	Sink	Public Access	CN-015	CN-S413	1.7	None
Rm. A114 - Girl's Bathroom	Sink	Public Access	CN-016	CN-S414	1.8	None
Rm. A114 - Girl's Bathroom	Sink	Public Access	CN-017	CN-S415	1.2	None
Rm. A114 - Girl's Bathroom	Sink	Public Access	CN-018	CN-S416	2.4	None
Rm. A116 - Classroom	Sink	Public Access	CN-024	CN-S422	2.4	None
Rm. A117 - Classroom	Sink	Public Access	CN-026	CN-S424	11.0	None
Rm. A121 - Exam Room Bathroom	Sink	Public Access	CN-012	CN-S410	3.0	None
Rm. A122 - Clinic Office Bathroom	Sink	Public Access	CN-013	CN-S411	3.3	None
Rm. A142 - Main Office Men's Bathroom	Sink	Secured - SCSD Staff Only	CN-029	CN-S427	1.5	None
Rm. A143 - Main Office Women's Bathroom	Sink	Secured - SCSD Staff Only	CN-028	CN-S426	1.6	None
Rm. A151 - Hallway/Corridor	Fountain	Public Access	CN-051	CN-F402	7.7	None
Rm. A155 - Cafeteria	Fountain	Public Access	CN-049	CN-F400	12.0	None

**SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL**

SAMPLE DATES: 10/09/2016, 10/21/2016 and 10/27/2016 ANALYSIS DATES: 11/28/2016, 12/26/2016, 12/27/2016, 12/29/2016 and 01/06/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'A', Cont.						
Rm. A155 - Cafeteria	Fountain	Public Access	CN-050	CN-F401	16.0	SCSD removed fixture from service and is to replace
Rm. A170 - Staff Locker Room Bathroom	Sink	Secured - SCSD Staff Only	CN-030	CN-S428	4.7	None
Rm. A180 - Boy's Bathroom	Sink	Public Access	CN-021	CN-S419	1.8	None
Rm. A180 - Boy's Bathroom	Sink	Public Access	CN-022	CN-S420	< 1.0	None
Rm. A180 - Boy's Bathroom	Sink	Public Access	CN-023	CN-S421	< 1.0	None
Rm. A216 - Office	Sink	Secured - SCSD Staff Only	CN-035	CN-S433	66.0	SCSD removed fixture from service and is to replace
Rm. A218A - Library	Fountain	Public Access	CN-052	CN-F403	2.0	None
Rm. A225 - Copy Room	Sink	Secured - SCSD Staff Only	CN-036	CN-S434	1.6	None
Rm. A231 - Hallway/Corridor	Fountain	Public Access	CN-053	CN-F404	6.2	None
Rm. A234 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-039	CN-S437	3.1	None
Rm. A238 - Girl's Bathroom	Sink	Public Access	CN-037	CN-S435	7.4	None
Rm. A238 - Girl's Bathroom	Sink	Public Access	CN-038	CN-S436	1.7	None
Rm. A243 - Boy's Bathroom	Sink	Public Access	CN-032	CN-S430	3.1	None
Rm. A243 - Boy's Bathroom	Sink	Public Access	CN-033	CN-S431	2.4	None
Rm. A243 - Boy's Bathroom	Sink	Public Access	CN-034	CN-S432	2.8	None
Rm. A244 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-031	CN-S429	2.2	None
Rm. A324 - Girl's Bathroom	Sink	Public Access	CN-044	CN-S442	4.4	None
Rm. A324 - Girl's Bathroom	Sink	Public Access	CN-045	CN-S443	3.3	None
Rm. A324 - Girl's Bathroom	Sink	Public Access	CN-046	CN-S444	2.2	None
Rm. A328 - Classroom	Sink	Public Access	CN-048	CN-S446	14.0	None
Rm. A330 - Hallway/Corridor	Fountain	Public Access	CN-054	CN-F405	3.9	None
Rm. A335 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-047	CN-S445	2.4	None
Rm. A345 - Boy's Bathroom	Sink	Public Access	CN-041	CN-S439	3.9	None
Rm. A345 - Boy's Bathroom	Sink	Public Access	CN-042	CN-S440	4.6	None
Rm. A345 - Boy's Bathroom	Sink	Public Access	CN-043	CN-S441	3.6	None
Rm. A347 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-040	CN-S438	2.8	None
Rm. A355 - Hallway/Corridor	Fountain	Public Access	CN-055	CN-F406	9.1	None

**SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL**

SAMPLE DATES: 10/09/2016, 10/21/2016 and 10/27/2016 ANALYSIS DATES: 11/28/2016, 12/26/2016, 12/27/2016, 12/29/2016 and 01/06/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'B'						
Rm. B003 - Hallway/Corridor	Fountain	Public Access	CN-045	CN-F101	8.6	None
Rm. B04 - Storage Room	Sink	Secured - SCSD Staff Only	CN-004	CN-S103	170.0	SCSD removed fixture from service and is to replace
Rm. B4 - Art Room	Fountain	Public Access	CN-046	CN-F102	10.0	None
Rm. B11A - Boy's Bathroom	Ice Machine	Public Access	CN-022	CN-S120	< 1.0	None
Rm. B11A - Boy's Bathroom	Sink	Public Access	CN-016	CN-S114	11.0	None
Rm. B11A - Boy's Bathroom	Sink	Public Access	CN-017	CN-S115	6.6	None
Rm. B11B - Girl's Bathroom	Sink	Public Access	CN-015	CN-S113	17.0	SCSD removed fixture from service and is to replace
Rm. B17 - Boy's Bathroom	Sink	Public Access	CN-005	CN-S104	4.6	None
Rm. B17 - Boy's Bathroom	Sink	Public Access	CN-006	CN-S105	4.8	None
Rm. B18 - Girl's Bathroom	Sink	Public Access	CN-007	CN-S106	8.1	None
Rm. B18 - Girl's Bathroom	Sink	Public Access	CN-008	CN-S107	2.4	None
Rm. B33 - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	CN-011	CN-S109B	11.0	None
Rm. B35 - Girl's Locker Room	Fountain	Public Access	CN-047	CN-F103	74.0	SCSD removed fixture from service and is to replace
Rm. B36 - Girl's Locker Room Bathroom	Sink	Public Access	CN-009	CN-S108	1.8	None
Rm. B36 - Girl's Locker Room Bathroom	Sink	Public Access	CN-010	CN-S109A	3.5	None
Rm. B43 - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	CN-014	CN-S112	6.8	None
Rm. B45A - Boy's Locker Room Bathroom	Sink	Public Access	CN-012	CN-S110	1.8	None
Rm. B45A - Boy's Locker Room Bathroom	Sink	Public Access	CN-013	CN-S111	1.6	None
Rm. B51 - Staff's Locker Room	Fountain	Secured - SCSD Staff Only	CN-050	CN-F106	80.0	SCSD removed fixture from service and is to replace
Rm. B52 - Staff Locker Room Bathroom	Sink	Secured - SCSD Staff Only	CN-018	CN-S116	2.3	None
Rm. B54 - Hallway/Corridor	Fountain	Public Access	CN-048	CN-F104	< 1.0	None
Rm. B54 - Hallway/Corridor	Fountain	Public Access	CN-049	CN-F105	4.2	None
Rm. B55 - Hallway/Corridor	Fountain	Public Access	CN-051	CN-F107	3.3	None
Rm. B61 - Pool	Fountain	Public Access	CN-052	CN-F108	13.0	None
Rm. B101 - Hallway/Corridor	Fountain	Public Access	CN-055	CN-F111	< 1.0	None
Rm. B102 - Home & Careers Room	Sink	Public Access	CN-030	CN-S507	5.2	None
Rm. B102 - Home & Careers Room	Sink	Public Access	CN-031	CN-S508	5.2	None
Rm. B104 - Home & Careers Room	Sink	Public Access	CN-026	CN-S503	69.0	SCSD removed fixture from service and is to replace

**SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL**

SAMPLE DATES: 10/09/2016, 10/21/2016 and 10/27/2016 ANALYSIS DATES: 11/28/2016, 12/26/2016, 12/27/2016, 12/29/2016 and 01/06/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'B', Cont.						
Rm. B104 - Home & Careers Room	Sink	Public Access	CN-027	CN-S504	2.6	None
Rm. B104 - Home & Careers Room	Sink	Public Access	CN-028	CN-S505	4.9	None
Rm. B104 - Home & Careers Room	Sink	Public Access	CN-029	CN-S506	17.0	SCSD to post warning sign
Rm. B104 - Hallway/Corridor	Fountain	Public Access	CN-043	CN-F520	13.0	None
Rm. B107 - Classroom	Sink	Public Access	CN-025	CN-S502	59.0	SCSD permanently removed fixture from service
Rm. B108 - Classroom	Sink	Public Access	CN-024	CN-S501	62.0	SCSD permanently removed fixture from service
Rm. B109 - Classroom	Sink	Public Access	CN-042	CN-S519	2.8	None
Rm. B109B - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	CN-023	CN-S500	7.8	None
Rm. B111 - Classroom	Sink	Public Access	CN-040	CH-S517	8.4	None
Rm. B112 - Classroom	Sink	Public Access	CN-041	CN-S518	4.1	None
Rm. B113 - Classroom	Sink	Public Access	CN-039	CN-S516	9.2	None
Rm. B117 - Girl's Locker Room	Fountain	Public Access	CN-054	CN-F110	< 1.0	None
Rm. B119 - Girl's Locker Room Bathroom	Sink	Public Access	CN-021	CN-S119	3.3	None
Rm. B122 - Boy's Locker Room Bathroom	Sink	Public Access	CN-020	CN-S118	6.9	None
Rm. B122 - Boy's Locker Room	Fountain	Public Access	CN-053	CN-F109	< 1.0	None
Rm. B125 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	CN-019	CN-S117	2.4	None
Rm. B213 - Girl's Bathroom	Sink	Public Access	CN-036	CN-S513	5.6	None
Rm. B213 - Girl's Bathroom	Sink	Public Access	CN-037	CN-S514	6.7	None
Rm. B214 - Boy's Bathroom	Sink	Public Access	CN-038	CN-S515	4.0	None
Rm. B216 - Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-034	CN-S511	290.0	SCSD removed fixture from service and is to replace
Rm. B221 - Boy's Bathroom	Sink	Public Access	CN-033	CN-S510	6.4	None
Rm. B222 - Girl's Bathroom	Sink	Public Access	CN-032	CN-S509	9.5	None
Rm. B224 - Hallway/Corridor	Fountain	Public Access	CN-035	CN-F512	1.1	None
BUILDING SECTION 'C'						
Rm. C108 - Hallway/Corridor	Fountain	Public Access	CN-044	CN-F100	< 1.0	None
Rm. C111 - Boy's Locker Bathroom	Sink	Public Access	CN-002	CN-S101	4.5	None
Rm. C113 - Girl's Locker Bathroom	Sink	Public Access	CN-001	CN-S100	3.4	None
Rm. C114 - Storage Room	Sink	Secured - SCSD Staff Only	CN-003	CN-S102	2000.0	SCSD permanently removed fixture from service

SYRACUSE CITY SCHOOL DISTRICT CORCORAN HIGH SCHOOL

SAMPLE DATES: 10/09/2016, 10/21/2016 and 10/27/2016 ANALYSIS DATES: 11/28/2016, 12/26/2016, 12/27/2016, 12/29/2016 and 01/06/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
FIELD HOUSE/CONCESSION STAND						
Outside Wall Mount	Fountain	Public Access	CNFH-016	CNFH-F100	< 1.0	None
Outside Wall Mount	Fountain	Public Access	CNFH-017	CNFH-F101	< 1.0	None
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-001	CNFH-S100	30.0	SCSD removed fixture from service and is to replace
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-002	CNFH-S101	5.9	None
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-003	CNFH-S102	2.8	None
Rm. A1 - Concession Stand	Hose Bib	Secured - SCSD Staff Only	CNFH-004	CNFH-S103	1.6	None
Rm. A3 - Men's Bathroom	Sink	Public Access	CNFH-005	CNFH-S104	1.5	None
Rm. A3 - Men's Bathroom	Sink	Public Access	CNFH-006	CNFH-S105	1.6	None
Rm. A4 - Women's Bathroom	Sink	Public Access	--	CNFH-S106	--	Fixture not operating
Rm. A4 - Women's Bathroom	Sink	Public Access	CNFH-007	CNFH-S107	1.0	None
Rm. A5 - Home Team Locker Room	Sink	Public Access	CNFH-008	CNFH-S108	3.0	None
Rm. A5 - Home Team Locker Room	Sink	Public Access	CNFH-009	CNFH-S109	< 1.0	None
Rm. A5 - Home Team Locker Room	Ice Machine	Public Access	CNFH-010	CNFH-S110	< 1.0	None
Rm. A5 - Home Team Locker Room	Hose Bib	Public Access	CNFH-011	CNFH-S111	< 1.0	None
Rm. A8 - Visiting Team Locker Room	High Hose Bib	Public Access	CNFH-012	CNFH-S112	< 1.0	None
Rm. A8 - Visiting Team Locker Room	Sink	Public Access	CNFH-013	CNFH-S113	1.2	None
Rm. A8 - Visiting Team Locker Room	Sink	Public Access	--	CNFH-S114	--	Fixture not operating
Rm. A8 - Visiting Team Locker Room	Low Hose Bib	Public Access	CNFH-014	CNFH-S115	< 1.0	None
Rm. A12 - Official's Bathroom/Lounge	Sink	Secured - SCSD Staff Only	CNFH-015	CNFH-S116	1.3	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project Nos. 2016068-028, 2016068-040 and 2016068-045
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620840, 1620735, 1619197
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.