

SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL

SAMPLE DATE: 10/09/2016 ANALYSIS DATE: 12/21/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 001 - Classroom	Sink	Public Access	HR-093	HR-S513	2.4	None
Rm. 002 - Technology Shop	Sink	Public Access	HR-092	HR-S512	7.6	None
Rm. 003 - Technology Room	Sink	Public Access	HR-094	HR-S514	3.7	None
Rm. 003 - Technology Room	Sink	Public Access	HR-095	HR-S515	500.0	SCSD removed fixture from service and is to replace
Rm. 004 - Technology Shop	Sink	Public Access	HR-096	HR-S516	< 1.0	None
Rm. 004 - Technology Shop	Sink	Public Access	HR-097	HR-S517	1.0	None
Rm. 007 - Classroom	Sink	Public Access	HR-090	HR-S510	3.3	None
Rm. 008 - Classroom	Sink	Public Access	HR-089	HR-S509	1.1	None
Rm. 009 - Staff Women's Locker Bathroom	Sink	Secured - SCSD Staff Only	HR-098	HR-S518	4.2	None
Rm. 009 - Staff Women's Locker Bathroom	Sink	Secured - SCSD Staff Only	HR-099	HR-S519	4.4	None
Rm. 017 - Storage Room	Sink	Secured - SCSD Staff Only	HR-091	HR-S511	1.1	None
Rm. 020 - Staff Men's Locker Bathroom	Sink	Secured - SCSD Staff Only	HR-100	HR-S520	16.0	SCSD removed fixture from service and is to replace
Rm. 020 - Staff Men's Locker Bathroom	Sink	Secured - SCSD Staff Only	HR-101	HR-S521	2.7	None
Rm. 030 - Mechanical/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	HR-059	HR-M200	11.0	None
Rm. 044 - Hallway/Corridor	Fountain	Public Access	HR-127	HR-F504	< 1.0	None
Rm. 044 - Hallway/Corridor	Fountain	Public Access	HR-128	HR-F505	2.0	None
Rm. Rm. 047A - Hallway/Vestibule	Fountain	Public Access	HR-126	HR-F503	1.1	None
Rm. 047B - Hallway/Vestibule	Fountain	Public Access	HR-124	HR-F501	1.1	None
Rm. 049 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-085	HR-S500	1.8	None
Rm. 049 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-086	HR-S506	1.2	None
Rm. 050 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-087	HR-S507	< 1.0	None
Rm. 050 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-088	HR-S508	1.9	None
Rm. 051 - Hallway/Corridor	Fountain	Public Access	HR-125	HR-F502	1.4	None
Rm. 064A - Storage Room Bathroom	Sink	Secured - SCSD Staff Only	HR-030	HR-S129	< 1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-031	HR-S130	3.7	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-032	HR-S131	2.7	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-033	HR-S132	1.6	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-034	HR-S133	2.6	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-035	HR-S134	2.5	None

SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL

SAMPLE DATE: 10/09/2016 ANALYSIS DATE: 12/21/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-036	HR-S135	4.2	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-037	HR-S136	3.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-038	HR-S137	1.4	None
Rm. 068 - Kitchen	Steamer	Secured - SCSD Staff Only	HR-039	HR-S138	1.1	None
Rm. 068 - Kitchen	Steamer	Secured - SCSD Staff Only	HR-040	HR-S139	2.8	None
Rm. 069 - Cafeteria 'B'	Fountain	Public Access	HR-115	HR-F106	< 1.0	None
Rm. 069 - Cafeteria 'B'	Fountain	Public Access	HR-116	HR-F107	< 1.0	None
Rm. 071A - Hallway/Corridor	Fountain	Public Access	HR-117	HR-F108	5.3	None
Rm. 072 - Boy's Locker Room	Sink	Public Access	HR-052	HR-S151	9.8	None
Rm. 077 - Boy's Bathroom	Sink	Public Access	HR-050	HR-S149	3.0	None
Rm. 078 - Girl's Locker Room	Sink	Public Access	HR-053	HR-S152	18.0	SCSD permanently removed fixture from service
Rm. 079 - Girl's Bathroom	Sink	Public Access	HR-045	HR-S144	5.7	None
Rm. 086 - Music/Vocal Room	Sink	Public Access	HR-051	HR-S150	5.1	None
Rm. 100A - Office Bathroom	Sink	Secured - SCSD Staff Only	HR-025	HR-S124	4.2	None
Rm. 103 - Classroom	Sink	Public Access	HR-046	HR-S145	4.9	None
Rm. 103 - Classroom	Sink	Public Access	HR-047	HR-S146	4.2	None
Rm. 103 - Classroom	Sink	Public Access	HR-048	HR-S147	11.0	None
Rm. 103 - Classroom	Sink	Public Access	HR-049	HR-S148	2.1	None
Rm. 103A - Work Area	Sink	Public Access	HR-044	HR-S143	4.4	None
Rm. 104 - Home & Careers Room	Sink	Public Access	HR-041	HR-S140	2.5	None
Rm. 104 - Home & Careers Room	Sink	Public Access	HR-042	HR-S141	1.8	None
Rm. 104 - Home & Careers Room	Sink	Public Access	HR-043	HR-S142	3.3	None
Rm. 123A - Career Center Room	Sink	Public Access	HR-028	HR-S127	1.5	None
Rm. 132 - Hallway/Corridor	Fountain	Public Access	HR-109	HR-F100	6.9	None
Rm. 132 - Hallway/Corridor	Fountain	Public Access	HR-110	HR-F101	1.3	None
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-008	HR-S107	5.8	None
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-009	HR-S108	3.0	None
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-010	HR-S109	3.3	None
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-011	HR-S110	2.6	None

SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL

SAMPLE DATE: 10/09/2016 ANALYSIS DATE: 12/21/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-012	HR-S111	2.9	None
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-013	HR-S112	1.9	None
Rm. 135 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-007	HR-S106	3.4	None
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-001	HR-S100	2.5	None
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-002	HE-S101	2.6	None
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-003	HR-S102	3.3	None
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-004	HR-S103	3.8	None
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-005	HR-S104	4.9	None
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-006	HR-S105	3.7	None
Rm. 146 - Clinic Bathroom	Sink	Public Access	HR-021	HR-S120	4.1	None
Rm. 149 - Health Service Room	Sink	Public Access	HR-022	HR-S121	3.4	None
Rm. 159 - Boy's Bathroom	Sink	Public Access	HR-029	HR-S128	1.7	None
Rm. 162 - Girl's Bathroom	Sink	Public Access	HR-026	HR-S125	3.0	None
Rm. 162 - Girl's Bathroom	Sink	Public Access	HR-027	HR-S126	3.5	None
Rm. 163 - Hallway/Corridor	Fountain	Public Access	HR-113	HR-F104	5.2	None
Rm. 163 - Hallway/Corridor	Fountain	Public Access	HR-114	HR-F105	4.8	None
Rm. 177 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-023	HR-S122	4.5	None
Rm. 179 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-024	HR-S123	5.6	None
Rm. 185 - Girl's Bathroom	Sink	Public Access	HR-018	HR-S117	4.1	None
Rm. 185 - Girl's Bathroom	Sink	Public Access	HR-019	HR-S118	3.7	None
Rm. 185 - Girl's Bathroom	Sink	Public Access	HR-020	HR-S119	1.9	None
Rm. 186 Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-017	HR-S116	1.6	None
Rm. 189 - Boy's Bathroom	Sink	Public Access	HR-014	HR-S113	6.5	None
Rm. 189 - Boy's Bathroom	Sink	Public Access	HR-015	HR-S114	3.4	None
Rm. 189 - Boy's Bathroom	Sink	Public Access	HR-016	HR-S115	5.3	None
Rm. 190 - Hallway/Corridor	Fountain	Public Access	HR-111	HR-F102	2.6	None
Rm. 190 - Hallway/Corridor	Fountain	Public Access	HR-112	HR-F103	7.4	None
Rm. 205 - Classroom	Sink	Public Access	HR-083	HR-S225	3.5	None

SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL

SAMPLE DATE: 10/09/2016 ANALYSIS DATE: 12/21/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 207D - Library Storage Room	Sink	Secured - SCSD Staff Only	HR-082	HR-S224	9.0	None
Rm. 207F - Classroom	Sink	Public Access	HR-081	HR-S223	6.1	None
Rm. 211 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-102	HR-S522	6.3	None
Rm. 212 - Classroom	Sink	Public Access	HR-084	HR-S226	1.4	None
Rm. 213 - Classroom	Sink	Public Access	HR-080	HR-S222	10.0	None
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-103	HR-S524	5.5	None
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-104	HR-S525	6.1	None
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-105	HR-S526	5.6	None
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-106	HR-S527	6.8	None
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-107	HR-S528	6.4	None
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-108	HR-S529	6.3	None
Rm. 226C - Hallway/Corridor	Fountain	Public Access	HR-129	HR-F523	< 1.0	None
Rm. 228 - Classroom	Sink	Public Access	HR-073	HR-S215	3.9	None
Rm. 240 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	HR-067	HR-S209	2.0	None
Rm. 240 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	HR-068	HR-S210	92.0	SCSD permanently removed fixture from service
Rm. 242 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-069	HR-S211	1.2	None
Rm. 242 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-070	HR-S212	4.5	None
Rm. 243 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-071	HR-S213	6.4	None
Rm. 243 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-072	HR-S214	2.4	None
Rm. 255 - Girl's Bathroom	Sink	Public Access	HR-077	HR-S219	5.9	None
Rm. 255 - Girl's Bathroom	Sink	Public Access	HR-078	HR-S220	3.9	None
Rm. 255 - Girl's Bathroom	Sink	Public Access	HR-079	HR-S221	3.7	None
Rm. 257 - Boy's Bathroom	Sink	Public Access	HR-074	HR-S216	6.1	None
Rm. 257 - Boy's Bathroom	Sink	Public Access	HR-075	HR-S217	2.9	None
Rm. 257 - Boy's Bathroom	Sink	Public Access	HR-076	HR-S218	2.8	None
Rm. 259 - Hallway/Corridor	Fountain	Public Access	HR-122	HR-F205	3.2	None
Rm. 259 - Hallway/Corridor	Fountain	Public Access	HR-123	HR-F206	5.9	None
Rm. N-5 - Office Bathroom	Sink	Secured - SCSD Staff Only	HR-063	HR-S204	4.1	None
Rm. N-8 - Girl's Locker Room Bathroom	Sink	Public Access	HR-060	HR-S201	3.4	None

SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL

SAMPLE DATE: 10/09/2016 ANALYSIS DATE: 12/21/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. N-8 - Girl's Locker Room Bathroom	Sink	Public Access	HR-061	HR-S202	3.3	None
Rm. N-10 - Girl's Locker Room	Fountain	Public Access	HR-119	HR-F201	8.5	None
Rm. N-15 - Boy's Locker Room	Fountain	Public Access	HR-120A	HR-F203	4.2	None
Rm. N-21 - Laundry Room	Ice Machine	Public Access	--	HR-S207	--	Fixture not operating
Rm. N-23 - Team Room Bathroom	Sink	Public Access	HR-066	HR-S208	4.0	None
Rm. N-25 - Team Room	Fountain	Public Access	HR-121	HR-F204	< 1.0	None
Rm. N-32A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	HR-064	HR-S205	1.5	None
Rm. N-35B - Boy's Locker Room Bathroom	Sink	Public Access	HR-065	HR-S206	2.4	None
Rm. N-40A - Supply Room	Ice Machine	Public Access	HR-062	HR-S203	< 1.0	None
Rm. N-42 - Pool	Fountain	Public Access	--	HR-F202	--	Fixture not operating
FIELD HOUSE/CONCESSION STAND						
Field House - Boy's Bathroom	Sink	Public Access	HR-054	HR-S153	2.2	None
Field House - Boy's Bathroom	Sink	Public Access	HR-055	HR-S154	1.7	None
Field House - Girl's Bathroom	Sink	Public Access	HR-056	HR-S155	1.3	None
Field House - Girl's Bathroom	Sink	Public Access	HR-057	HR-S156	< 1.0	None
Field House - Concession Stand	Fountain	Public Access	HR-118	HR-F109	< 1.0	None
Field House - Concession Stand	Sink	Public Access	HR-058	HR-S157	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620823
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.