

SYRACUSE CITY SCHOOL DISTRICT
ROBERTS PK-GRADE 8 SCHOOL

| ROOM No. & LOCATION | FIXTURE (Sink/Fountain) | ACCESSIBILITY | LABORATORY SAMPLE ID No. | TDK SAMPLE ID No. | 09/24/2016 SAMPLE RESULTS (ppb) | 09/24/2016 ORIGINAL ACTIONS | 03/17/2017 RESAMPLE RESULTS (ppb) | 03/17/2017 RESAMPLE ACTIONS |
|-----------------------------------|----------------------------|---------------------------|-----------------------------|----------------------|---------------------------------------|-----------------------------------|---|--------------------------------|
| Rm. 115 - Staff Bathroom | Sink | Secured - SCSD Staff Only | RS-027 | RS-S200 | < 1.0 | None | -- | -- |
| Rm. 118 - Art Room | Sink | Public Access | RS-028 | RS-S201A | < 1.0 | None | -- | -- |
| Rm. 118 - Art Room | Sink | Public Access | RS-030 | RS-S202A | < 1.0 | None | -- | -- |
| Rm. 122 - Receiving Room | Sink | Secured - SCSD Staff Only | RS-053 | RS-S311 | < 1.0 | None | -- | -- |
| Rm. 122A - Kitchen Staff Bathroom | Sink | Secured - SCSD Staff Only | RS-052 | RS-S310 | < 1.0 | None | -- | -- |
| Rm. 128 - Kitchen | Sink | Secured - SCSD Staff Only | RS-048 | RS-S306 | 5.0 | None | -- | -- |
| Rm. 128 - Kitchen | Sink | Secured - SCSD Staff Only | RS-049 | RS-S307 | 3.0 | None | -- | -- |
| Rm. 128 - Kitchen | Sink | Secured - SCSD Staff Only | RS-050 | RS-S308 | 1.0 | None | -- | -- |
| Rm. 128 - Kitchen | Sink | Secured - SCSD Staff Only | RS-051 | RS-S309 | 1.0 | None | -- | -- |
| Rm. 132 - Hallway/Vestibule | Sink | Public Access | RS-043 | RS-S301 | < 1.0 | None | -- | -- |
| Rm. 132 - Hallway/Vestibule | Sink | Public Access | RS-044 | RS-S302 | < 1.0 | None | -- | -- |
| Rm. 132 - Hallway/Vestibule | Sink | Public Access | RS-045 | RS-S303 | < 1.0 | None | -- | -- |
| Rm. 132 - Hallway/Vestibule | Sink | Public Access | RS-046 | RS-S304 | < 1.0 | None | -- | -- |
| Rm. 132 - Hallway/Vestibule | Sink | Public Access | RS-047 | RS-S305 | < 1.0 | None | -- | -- |
| Rm. 132 - Hallway/Corridor | Fountain | Public Access | RS-080 | RS-F301 | < 1.0 | None | -- | -- |
| Rm. 132 - Hallway/Corridor | Fountain | Public Access | RS-081 | RS-F302 | < 1.0 | None | -- | -- |
| Rm. 150B - Boiler/Meter Room | Sink | Secured - SCSD Staff Only | RS-001 | RS-S100 | 3.7 | None | -- | -- |
| Rm. 151A - Kitchen | Sink | Secured - SCSD Staff Only | RS-011 | RS-S110 | 2.5 | None | -- | -- |
| Rm. 151B - Kitchen Staff Bathroom | Sink | Secured - SCSD Staff Only | RS-012 | RS-S111 | < 1.0 | None | -- | -- |
| Rm. 152A - Staff Bathroom | Sink | Secured - SCSD Staff Only | RS-010 | RS-S109 | 2.4 | None | -- | -- |
| Rm. 158 - Classroom | Sink | Public Access | RS-006 | RS-S105 | < 1.0 | None | -- | -- |
| Rm. 158 - Classroom | Fountain | Public Access | RS-068 | RS-F102 | < 1.0 | None | -- | -- |
| Rm. 158C - Classroom Bathroom | Sink | Public Access | RS-007 | RS-S106 | < 1.0 | None | -- | -- |
| Rm. 159 - Classroom | Sink | Public Access | RS-004 | RS-S103 | 5.0 | None | -- | -- |
| Rm. 159 - Classroom | Fountain | Public Access | RS-067 | RS-F101 | < 1.0 | None | -- | -- |
| Rm. 159C - Classroom Bathroom | Sink | Public Access | RS-005 | RS-S104 | < 1.0 | None | -- | -- |
| Rm. 160 - Classroom | Sink | Public Access | RS-002 | RS-S101 | < 1.0 | None | -- | -- |
| Rm. 160 - Classroom | Fountain | Public Access | RS-066 | RS-F100 | < 1.0 | None | -- | -- |
| Rm. 160C - Classroom Bathroom | Sink | Public Access | RS-003 | RS-S102 | < 1.0 | None | -- | -- |

SYRACUSE CITY SCHOOL DISTRICT
ROBERTS PK-GRADE 8 SCHOOL

| ROOM No. & LOCATION | FIXTURE (Sink/Fountain) | ACCESSIBILITY | LABORATORY SAMPLE ID No. | TDK SAMPLE ID No. | 09/24/2016 SAMPLE RESULTS (ppb) | 09/24/2016 ORIGINAL ACTIONS | 03/17/2017 RESAMPLE RESULTS (ppb) | 03/17/2017 RESAMPLE ACTIONS |
|---------------------------------|----------------------------|---------------------------|-----------------------------|----------------------|---------------------------------------|-----------------------------------|---|--------------------------------|
| Rm. 161 - Classroom | Sink | Public Access | RS-008 | RS-S107 | < 1.0 | None | -- | -- |
| Rm. 161 - Classroom | Fountain | Public Access | RS-069 | RS-F103 | < 1.0 | None | -- | -- |
| Rm. 161C - Classroom Bathroom | Sink | Public Access | RS-009 | RS-S108 | < 1.0 | None | -- | -- |
| Rm. 274 - Classroom | Sink | Public Access | RS-013 | RS-S112 | < 1.0 | None | -- | -- |
| Rm. 211 - Classroom | Sink | Public Access | RS-036 | RS-S207 | 2.3 | None | -- | -- |
| Rm. 211 - Classroom | Fountain | Public Access | RS-077 | RS-F203 | < 1.0 | None | -- | -- |
| Rm. 211D - Classroom Bathroom | Sink | Public Access | RS-035 | RS-S206 | 1.6 | None | -- | -- |
| Rm. 214 - Classroom | Sink | Public Access | RS-038 | RS-S209 | < 1.0 | None | -- | -- |
| Rm. 214 - Classroom | Fountain | Public Access | RS-078 | RS-F204 | < 1.0 | None | -- | -- |
| Rm. 214D - Classroom Bathroom | Sink | Public Access | RS-037 | RS-S208 | 2.1 | None | -- | -- |
| Rm. 215 - Hallway/Corridor | Fountain | Public Access | RS-075 | RS-F201 | < 1.0 | None | -- | -- |
| Rm. 215 - Hallway/Corridor | Fountain | Public Access | RS-076 | RS-F202 | < 1.0 | None | -- | -- |
| Rm. 219 - Teacher's Lounge | Fountain | Public Access | RS-074 | RS-F108 | < 1.0 | None | -- | -- |
| Rm. 220 - Hallway/Vestibule | Sink | Public Access | RS-031 | RS-S202B | < 1.0 | None | -- | -- |
| Rm. 220 - Hallway/Vestibule | Sink | Public Access | RS-032 | RS-S203 | < 1.0 | None | -- | -- |
| Rm. 220 - Hallway/Vestibule | Sink | Public Access | RS-033 | RS-S204 | < 1.0 | None | -- | -- |
| Rm. 220 - Hallway/Vestibule | Sink | Public Access | RS-034 | RS-S205 | < 1.0 | None | -- | -- |
| Rm. 220 - Hallway/Vestibule | Sink | Public Access | RS-029 | RS-S201B | < 1.0 | None | -- | -- |
| Rm. 224A - Staff Bathroom | Sink | Secured - SCSD Staff Only | RS-022 | RS-S121 | < 1.0 | None | -- | -- |
| Rm. 224B - Staff Bathroom | Sink | Secured - SCSD Staff Only | RS-023 | RS-S122 | 3.2 | None | -- | -- |
| Rm. 229A - Gym Office Bathroom | Sink | Public Access | RS-042 | RS-S213 | 11.0 | None | -- | -- |
| Rm. 229B - Gym Bathroom | Sink | Public Access | RS-041 | RS-S212 | < 1.0 | None | -- | -- |
| Rm. 237 - Staff Bathroom | Sink | Secured - SCSD Staff Only | RS-039 / RS-001 | RS-S210 / RS-S210B | 18.0 | *See Note 6 | 5.1 | None |
| Rm. 239 - Hallway/Corridor | Fountain | Public Access | RS-079 | RS-F205 | < 1.0 | None | -- | -- |
| Rm. 239 - Hallway/Corridor | Fountain | Public Access | RS-073 | RS-F107 | < 1.0 | None | -- | -- |
| Rm. 244 - Office | Sink | Secured - SCSD Staff Only | RS-040 | RS-S211 | 1.8 | None | -- | -- |
| Rm. 252 - Office Staff Bathroom | Bathroom Sink | Secured - SCSD Staff Only | RS-024 | RS-S123 | < 1.0 | None | -- | -- |
| Rm. 253 - Office Staff Bathroom | Bathroom Sink | Secured - SCSD Staff Only | RS-025 | RS-S124 | 1.1 | None | -- | -- |
| Rm. 255 - Office Kitchenette | Sink | Secured - SCSD Staff Only | RS-026 | RS-S125 | < 1.0 | None | -- | -- |

SYRACUSE CITY SCHOOL DISTRICT
ROBERTS PK-GRADE 8 SCHOOL

| ROOM No. & LOCATION | FIXTURE (Sink/Fountain) | ACCESSIBILITY | LABORATORY SAMPLE ID No. | TDK SAMPLE ID No. | 09/24/2016 SAMPLE RESULTS (ppb) | 09/24/2016 ORIGINAL ACTIONS | 03/17/2017 RESAMPLE RESULTS (ppb) | 03/17/2017 RESAMPLE ACTIONS |
|------------------------------------|-------------------------|---------------------------|--------------------------|-------------------|---------------------------------|-----------------------------|-----------------------------------|-----------------------------|
| Rm. 263 - Nurse's Room | Sink | Public Access | RS-019 | RS-S118 | 1.0 | None | -- | -- |
| Rm. 263A - Nurse's Bathroom | Sink | Public Access | RS-020 | RS-S119 | 2.7 | None | -- | -- |
| Rm. 267 - Kitchen/Teacher's Lounge | Sink | Secured - SCSD Staff Only | RS-021 | RS-S120 | 1.3 | None | -- | -- |
| Rm. 269B - Classroom Bathroom | Sink | Public Access | RS-014 | RS-S113 | 3.2 | None | -- | -- |
| Rm. 270B - Classroom Bathroom | Sink | Public Access | RS-016 | RS-S115 | 8.2 | None | -- | -- |
| Rm. 271B - Classroom Bathroom | Sink | Public Access | RS-018 | RS-S117 | 3.0 | None | -- | -- |
| Rm. 272 - Classroom | Sink | Public Access | RS-017 | RS-S116 | < 1.0 | None | -- | -- |
| Rm. 272 - Classroom | Fountain | Public Access | RS-072 | RS-F106 | < 1.0 | None | -- | -- |
| Rm. 273 - Classroom | Sink | Public Access | RS-015 | RS-S114 | < 1.0 | None | -- | -- |
| Rm. 273 - Classroom | Fountain | Public Access | RS-071 | RS-F105 | < 1.0 | None | -- | -- |
| Rm. 274 - Classroom | Fountain | Public Access | RS-070 | RS-F104 | < 1.0 | None | -- | -- |
| Rm. 311 - Staff Bathroom | Sink | Secured - SCSD Staff Only | RS-054 | RS-S312 | < 1.0 | None | -- | -- |
| Rm. 311 - Classroom | Sink | Public Access | RS-063 | RS-S322 | 2.4 | None | -- | -- |
| Rm. 311 - Classroom | Sink | Public Access | RS-064 | RS-S323 | 4.9 | None | -- | -- |
| Rm. 311 - Classroom | Sink | Public Access | RS-065 | RS-S324 | 1.9 | None | -- | -- |
| Rm. 313 - Classroom | Sink | Public Access | RS-061 | RS-S320 | 5.7 | None | -- | -- |
| Rm. 313 - Classroom | Sink | Public Access | RS-062 | RS-S321 | 6.2 | None | -- | -- |
| Rm. 325 - Hallway/Vestibule | Sink | Public Access | RS-058 | RS-S317 | < 1.0 | None | -- | -- |
| Rm. 325 - Hallway/Vestibule | Sink | Public Access | RS-059 | RS-S318 | < 1.0 | None | -- | -- |
| Rm. 325 - Hallway/Vestibule | Sink | Public Access | RS-060 | RS-S319 | < 1.0 | None | -- | -- |
| Rm. 327 - Hallway/Vestibule | Sink | Public Access | RS-055 | RS-S314 | < 1.0 | None | -- | -- |
| Rm. 327 - Hallway/Vestibule | Sink | Public Access | RS-056 | RS-S315 | < 1.0 | None | -- | -- |
| Rm. 327 - Hallway/Vestibule | Sink | Public Access | RS-057 | RS-S316 | < 1.0 | None | -- | -- |
| Rm. 329 - Hallway/Corridor | Fountain | Public Access | RS-082 | RS-F303 | < 1.0 | None | -- | -- |

Original Sampling Notes (September 24, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1616294
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to replace fixture.

Resampling Notes (March 17, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1703695
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".