

**SYRACUSE CITY SCHOOL DISTRICT  
VAN DUYN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/24/2016 SAMPLE RESULTS (ppb)	09/24/2016 ORIGINAL ACTIONS	03/17/2017 RESAMPLE RESULTS (ppb)	03/17/2017 RESAMPLE ACTIONS
Rm. 001 - Cafeteria	Fountain	Public Access	069	VN-F100	< 1.0	None	--	--
Rm. 001 - Cafeteria	Fountain	Public Access	070	VN-F101	< 1.0	None	--	--
Rm. B10A - Receiving Room Bathroom	Sink	Secured - SCSD Staff Only	001	VN-S100	1.4	None	--	--
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	002	VN-S101	< 1.0	None	--	--
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	003	VN-S102	< 1.0	None	--	--
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	004	VN-S103	< 1.0	None	--	--
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	005	VN-S104	1.2	None	--	--
Rm. 031 - Hallway/Corridor	Fountain	Public Access	071	VN-F102	< 1.0	None	--	--
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	006	VN-S105	11.0	None	--	--
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	007	VN-S106	< 1.0	None	--	--
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	008	VN-S107	< 1.0	None	--	--
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	009	VN-S108	12.0	None	--	--
Rm. 005 - Classroom	Sink	Public Access	010	VN-S109	< 1.0	None	--	--
Rm. 010A - Office	Sink	Secured - SCSD Staff Only	011	VN-S110	3.6	None	--	--
Rm. 134 - Classroom	Sink	Public Access	012	VN-S111	1.8	None	--	--
Rm. 100M - Hallway/Corridor	Fountain	Public Access	072	VN-F103	< 1.0	None	--	--
Rm. 132 - Classroom	Sink	Public Access	013	VN-S112	1.5	None	--	--
Rm. 135 - Classroom	Sink	Public Access	014	VN-S113	< 1.0	None	--	--
Rm. 133 - Classroom	Sink	Public Access	015	VN-S114	< 1.0	None	--	--
Rm. 128 - Classroom	Sink	Public Access	016	VN-S115A	< 1.0	None	--	--
Rm. 129 - Classroom	Sink	Public Access	017	VN-S115B	< 1.0	None	--	--
Rm. 123 - Classroom	Sink	Public Access	018	VN-S117	1.4	None	--	--
Rm. 123 - Classroom	Fountain	Public Access	073	VN-F104	< 1.0	None	--	--
Rm. 120 - Classroom	Sink	Public Access	019	VN-S118	1.4	None	--	--
Rm. 120A - Classroom Bathroom	Sink	Public Access	020	VN-S119	14.0	None	--	--
Rm. 109 - Nurse's Room	Sink	Public Access	021	VN-S120	1.2	None	--	--
Rm. 109B - Nurse's Bathroom	Sink	Public Access	022	VN-S121	1.1	None	--	--
Rm. 117 - Classroom	Sink	Public Access	023	VN-S122	< 1.0	None	--	--
Rm. 109A - Exam Room	Sink	Public Access	024	VN-S123	2.5	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
VAN DUYN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/24/2016 SAMPLE RESULTS (ppb)	09/24/2016 ORIGINAL ACTIONS	03/17/2017 RESAMPLE RESULTS (ppb)	03/17/2017 RESAMPLE ACTIONS
Rm. 115A - Staff Bathroom	Sink	Secured - SCSD Staff Only	025	VN-S124	4.2	None	--	--
Rm. 115B - Staff Bathroom	Sink	Secured - SCSD Staff Only	026	VN-S125	9.5	None	--	--
Rm. 119D - Work Room	Sink	Secured - SCSD Staff Only	027	VN-S126	2.8	None	--	--
Rm. 115E - Lounge Kitchenette	Sink	Secured - SCSD Staff Only	028	VN-S127	< 1.0	None	--	--
Rm. 004 - Boiler/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	029	VN-S200	10.0	None	--	--
Rm. 0A8 - Hallway/Corridor	Fountain	Public Access	074	VN-F200	< 1.0	None	--	--
Rm. 023 - Classroom	Sink	Public Access	030	VN-S201	< 1.0	None	--	--
Rm. 023 - Classroom	Sink	Public Access	031	VN-S202	< 1.0	None	--	--
Rm. 023A - Classroom	Sink	Public Access	032	VN-S203	< 1.0	None	--	--
Rm. 023A - Classroom	Sink	Public Access	033	VN-S204	< 1.0	None	--	--
Rm. 021 - Kitchen Room	Sink	Secured - SCSD Staff Only	034	VN-S205	< 1.0	None	--	--
Rm. 020A - Classroom	Sink	Public Access	035	VN-S206	< 1.0	None	--	--
Rm. 020A - Classroom	Sink	Public Access	036	VN-S207	< 1.0	None	--	--
Rm. 024 - Classroom	Sink	Public Access	037	VN-S208	< 1.0	None	--	--
Rm. 024 - Classroom	Sink	Public Access	038	VN-S209	< 1.0	None	--	--
Rm. 022 - Classroom	Sink	Public Access	039	VN-S210	< 1.0	None	--	--
Rm. 022 - Classroom	Sink	Public Access	040	VN-S211	< 1.0	None	--	--
Rm. 015 - Art Room	Sink	Public Access	041	VN-S212	1.2	None	--	--
Rm. 015 - Art Room	Sink	Public Access	042	VN-S213	2.2	None	--	--
Rm. 023A - Staff's Bathroom	Sink	Secured - SCSD Staff Only	043	VN-S214	< 1.0	None	--	--
Rm. 018A - Staff Resource Bathroom	Sink	Public Access	044	VN-S215	2.3	None	--	--
Rm. 100P - Hallway/Corridor	Fountain	Public Access	075	VN-F201	< 1.0	None	--	--
Rm. 102A - Boy's Locker Room	Sink	Public Access	045	VN-S216	9.0	None	--	--
Rm. 104A - Girl's Locker Room	Sink	Public Access	046	VN-S217	8.3	None	--	--
Rm. 103 - Gym	Fountain	Public Access	076	VN-F202	< 1.0	None	--	--
Rm. 103 - Gym	Fountain	Public Access	077	VN-F203	< 1.0	None	--	--
Rm. 103D - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	047	VN-S218	7.6	None	--	--
Rm. 108 - Classroom	Sink	Public Access	048	VN-S219	1.5	None	--	--
Rm. 110 - Classroom	Sink	Public Access	049	VN-S220	1.5	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
VAN DUYN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/24/2016 SAMPLE RESULTS (ppb)	09/24/2016 ORIGINAL ACTIONS	03/17/2017 RESAMPLE RESULTS (ppb)	03/17/2017 RESAMPLE ACTIONS
Rm. 111 - Classroom	Sink	Public Access	050	VN-S221	< 1.0	None	--	--
Rm. 113 - Office	Sink	Secured - SCSD Staff Only	051 / 001	VN-S222 / VN-S222B	27.0	*See Note 6	<1.0	None
Rm. 113C - Principal's Bathroom	Sink	Secured - SCSD Staff Only	052	VN-S223	1.6	None	--	--
Rm. 230 - Hallway/Corridor	Fountain	Public Access	078	VN-F301	< 1.0	None	--	--
Rm. 230A - Girl's Bathroom	Sink	Public Access	053	VN-S301	4.7	None	--	--
Rm. 230A - Girl's Bathroom	Sink	Public Access	054	VN-S302	5.7	None	--	--
Rm. 230A - Girl's Bathroom	Sink	Public Access	055	VN-S303	3.8	None	--	--
Rm. 230B - Boy's Bathroom	Sink	Public Access	056	VN-S304	< 1.0	None	--	--
Rm. 230B - Boy's Bathroom	Sink	Public Access	057	VN-S305	6.4	None	--	--
Rm. 230B - Boy's Bathroom	Sink	Public Access	058	VN-S306	8.1	None	--	--
Rm. 207 - Teacher Resource	Sink	Secured - SCSD Staff Only	059	VN-S307	5.2	None	--	--
Rm. 221 - Staff Bathroom	Sink	Secured - SCSD Staff Only	060	VN-S308	< 1.0	None	--	--
Rm. 231 - Hallway/Corridor	Fountain	Public Access	079	VN-F302	< 1.0	None	--	--
Rm. 231B - Boy's Bathroom	Sink	Public Access	061	VN-S309	10.0	None	--	--
Rm. 231B - Boy's Bathroom	Sink	Public Access	062	VN-S310	2.4	None	--	--
Rm. 231B - Boy's Bathroom	Sink	Public Access	063	VN-S311	< 1.0	None	--	--
Rm. 231A - Girl's Bathroom	Sink	Public Access	064	VN-S312	< 1.0	None	--	--
Rm. 231A - Girl's Bathroom	Sink	Public Access	065	VN-S313	7.1	None	--	--
Rm. 231A - Girl's Bathroom	Sink	Public Access	066	VN-S314	3.7	None	--	--
Rm. 227A - Laboratory	Sink	Public Access	067	VN-S315	< 1.0	None	--	--
Rm. 227A - Laboratory	Sink	Public Access	068	VN-S316	1.8	None	--	--

Original Sampling Notes (September 24, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620400
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD removed fixture from service and is to replace.

Resampling Notes (March 17, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1703693
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".