

**SYRACUSE CITY SCHOOL DISTRICT  
JOHNSON VOCATIONAL CENTER SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/28/2016 SAMPLE RESULTS (ppb)	10/28/2016 ORIGINAL ACTIONS	03/23/2017 RESAMPLE RESULTS (ppb)	03/23/2017 RESAMPLE ACTIONS
Rm. B05 - Mechanical/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	JN-001	JN-M300	1300.0	*See Note 6	--	--
Rm. 104 - Principal's Office	Sink	Secured - SCSD Staff Only	JN-013	JN-S312	2.5	None	--	--
Rm. 105 - Main Office	Sink	Secured - SCSD Staff Only	JN-012	JN-S311	5.6	None	--	--
Rm. 107 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	JN-015	JN-S314	3.7	None	--	--
Rm. 108 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	JN-014	JN-S313	3.8	None	--	--
Rm. 115 - Classroom	Sink	Public Access	JN-016	JN-S315	1.0	None	--	--
Rm. 115 - Classroom	Sink	Public Access	JN-017	JN-S316	1.2	None	--	--
Rm. 115B - Kitchen	Sink	Secured - SCSD Staff Only	JN-020	JN-S319	1.3	None	--	--
Rm. 115E - Classroom Bathroom	Sink	Public Access	JN-018	JN-S317	2.3	None	--	--
Rm. 115E - Classroom Bathroom	Sink	Public Access	JN-019	JN-S318	4.0	None	--	--
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	JN-021 / JN-001	JN-S320 / JN-S320B	15.0	*See Note 7	1.4	None
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	JN-022	JN-S321	5.1	None	--	--
Rm. 123 - Hallway/Corridor	Sink	Public Access	JN-023	JN-S322	< 1.0	None	--	--
Rm. 125 - Hallway/Corridor	Fountain	Public Access	JN-024	JN-F323	< 1.0	None	--	--
Rm. 128 - Technology Shop	Sink	Public Access	JN-025	JN-S324	1.0	None	--	--
Rm. 132 - Technology Shop Bathroom	Sink	Public Access	JN-026	JN-S325	1.1	None	--	--
Rm. 141 - Auto Shop	Fountain	Public Access	JN-030	JN-F329	2.6	None	--	--
Rm. 141 - Auto Shop	Sink	Public Access	JN-029	JN-S328	2.5	None	--	--
Rm. 142 - Welding Shop	Sink	Public Access	JN-027	JN-S326	5.7	None	--	--
Rm. 142 - Welding Shop	Sink	Public Access	JN-028	JN-S327	5.7	None	--	--
Rm. 207 - Hallway/Vestibule	Sink	Public Access	JN-005	JN-S304	1.4	None	--	--
Rm. 207 - Hallway/Vestibule	Sink	Public Access	JN-006	JN-S305	1.4	None	--	--
Rm. 211 - Nurse's Office Bathroom	Sink	Public Access	JN-003	JN-S302	1.9	None	--	--
Rm. 213 - Laundry Room	Sink	Secured - SCSD Staff Only	JN-004 / JN-002	JN-S303 / JN-S303B	54.0	*See Note 8	1.7	None
Rm. 214 - Nurse's Office	Sink	Public Access	JN-002	JN-S301	4.0	None	--	--
Rm. 218A - Cosmetology Room	Sink	Public Access	JN-009	JN-S308	6.6	None	--	--
Rm. 218C - Classroom	Sink	Public Access	JN-008	JN-S307	2.6	None	--	--
Rm. 219 - Hallway/Corridor	Fountain	Public Access	JN-007	JN-F306	1.9	None	--	--
Rm. 222A - Lounge	Sink	Secured - SCSD Staff Only	JN-011	JN-S310	6.8	None	--	--
Rm. 227 - Classroom	Sink	Public Access	JN-010	JN-S309	6.4	None	--	--

# SYRACUSE CITY SCHOOL DISTRICT JOHNSON VOCATIONAL CENTER SCHOOL

## Original Sampling Notes (October 28, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620739
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to post warning sign
7. SCSD is to replace fixture
8. SCSD is to replace fixture

## Resampling Notes (March 23, 2017 Event)

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1703989
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".