

**SYRACUSE CITY SCHOOL DISTRICT
MEACHEM ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/27/2016 SAMPLE RESULTS (ppb)	09/27/2016 ORIGINAL ACTIONS	03/23/2017 RESAMPLE RESULTS (ppb)	03/23/2017 RESAMPLE ACTIONS
Rm. 002 - Cafeteria	Fountain	Public Access	060	MM-F100	< 1.0	None	--	--
Rm. 03C - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	003	MM-S101	1.4	None	--	--
Rm. 005 - Hallway/Vestibule	Sink	Public Access	008	MM-S106	8.2	None	--	--
Rm. 005 - Hallway/Vestibule	Sink	Public Access	009	MM-S107	< 1.0	None	--	--
Rm. 005 - Hallway/Vestibule	Sink	Public Access	010	MM-S108	1.9	None	--	--
Rm. 005 - Hallway/Vestibule	Sink	Public Access	011	MM-S109	1.2	None	--	--
Rm. 005 - Hallway/Corridor	Fountain	Public Access	061	MM-F101	< 1.0	None	--	--
Rm. 005 - Hallway/Corridor	Fountain	Public Access	062	MM-F102	< 1.0	None	--	--
Rm. 08A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	002	MM-S100	< 1.0	None	--	--
Rm. 016 - Art Room	Sink	Public Access	012	MM-S110	1.7	None	--	--
Rm. 016 - Art Room	Sink	Public Access	013	MM-S111	< 1.0	None	--	--
Rm. 020C - Unisex Bathroom	Sink	Public Access	014	MM-S112	< 1.0	None	--	--
Rm. 022 - Water Sprinkler/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	001	MM-M100	340.0	*See Note 6	--	--
Rm. 023 - Hallway/Corridor	Fountain	Public Access	063	MM-F103	< 1.0	None	--	--
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	004	MM-S102	< 1.0	None	--	--
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	005	MM-S103	1.1	None	--	--
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	006	MM-S104	1.6	None	--	--
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	007	MM-S105	2.6	None	--	--
Rm. 100C - Hallway/Vestibule	Sink	Public Access	016	MM-S114	1.7	None	--	--
Rm. 100C - Hallway/Vestibule	Sink	Public Access	017	MM-S115	5.1	None	--	--
Rm. 100E - Hallway/Corridor	Fountain	Public Access	064	MM-F104	< 1.0	None	--	--
Rm. 100E - Hallway/Corridor	Fountain	Public Access	065	MM-F105	< 1.0	None	--	--
Rm. 100E - Hallway/Corridor	Fountain	Public Access	066	MM-F106	< 1.0	None	--	--
Rm. 100G - Hallway/Vestibule	Sink	Public Access	018	MM-S116	2.2	None	--	--
Rm. 100G - Hallway/Vestibule	Sink	Public Access	019	MM-S117	< 1.0	None	--	--
Rm. 101B - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	020	MM-S118	2.3	None	--	--
Rm. 103 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	023	MM-S121	< 1.0	None	--	--
Rm. 103C - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	022	MM-S120	< 1.0	None	--	--
Rm. 103D - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	021	MM-S119	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
MEACHEM ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/27/2016 SAMPLE RESULTS (ppb)	09/27/2016 ORIGINAL ACTIONS	03/23/2017 RESAMPLE RESULTS (ppb)	03/23/2017 RESAMPLE ACTIONS
Rm. 104A - Exam Room	Sink	Public Access	025	MM-S123	3.2	None	--	--
Rm. 104B - Nurse's Bathroom	Sink	Public Access	024	MM-S122	< 1.0	None	--	--
Rm. 105 - Computer Lab	Sink	Public Access	026 / 001	MM-S124 / MM-S124B	27.0	*See Note 7	7.1	None
Rm. 108 - Classroom	Sink	Public Access	030	MM-S128	2.4	None	--	--
Rm. 108 - Classroom	Fountain	Public Access	067	MM-F107	1.1	None	--	--
Rm. 108 - Classroom	Sink	Public Access	031	MM-S129	< 1.0	None	--	--
Rm. 108B - Classroom Bathroom	Sink	Public Access	028	MM-S126	< 1.0	None	--	--
Rm. 108B - Classroom Bathroom	Sink	Public Access	029	MM-S127	3.0	None	--	--
Rm. 109F - Main Office Bathroom	Sink	Secured - SCSD Staff Only	027	MM-S125	< 1.0	None	--	--
Rm. 110 - Classroom	Sink	Public Access	033	MM-S131	8.0	None	--	--
Rm. 110 - Classroom	Fountain	Public Access	068	MM-F108	1.4	None	--	--
Rm. 110A - Classroom Bathroom	Sink	Public Access	032	MM-S130	5.5	None	--	--
Rm. 111 - Classroom	Sink	Public Access	042	MM-S140	7.4	None	--	--
Rm. 111 - Classroom	Fountain	Public Access	073	MM-F113	< 1.0	None	--	--
Rm. 112 - Classroom	Sink	Public Access	040 / 002	MM-S138 / MM-S138B	52.0	*See Note 8	<1.0	None
Rm. 112 - Classroom	Fountain	Public Access	071	MM-F111	< 1.0	None	--	--
Rm. 113 - Classroom	Sink	Public Access	043	MM-S141	< 1.0	None	--	--
Rm. 113 - Classroom	Fountain	Public Access	074	MM-F114	< 1.0	None	--	--
Rm. 114 - Classroom	Sink	Public Access	041	MM-S139	1.5	None	--	--
Rm. 114 - Classroom	Fountain	Public Access	072	MM-F112	< 1.0	None	--	--
Rm. 115 - Classroom	Sink	Public Access	044	MM-S142	< 1.0	None	--	--
Rm. 115 - Classroom	Fountain	Public Access	075	MM-F115	< 1.0	None	--	--
Rm. 116 - Classroom	Sink	Public Access	045	MM-S143	< 1.0	None	--	--
Rm. 116 - Classroom	Fountain	Public Access	076	MM-F116	1.4	None	--	--
Rm. 117 - Classroom	Sink	Public Access	046	MM-S144	< 1.0	None	--	--
Rm. 117 - Classroom	Fountain	Public Access	077	MM-F117	1.7	None	--	--
Rm. 119 - Classroom	Sink	Public Access	047	MM-S145	< 1.0	None	--	--
Rm. 119 - Classroom	Fountain	Public Access	078	MM-F118	< 1.0	None	--	--
Rm. 122 - Staff Bathroom	Sink	Secured - SCSD Staff Only	034	MM-S132	1.4	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
MEACHEM ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/27/2016 SAMPLE RESULTS (ppb)	09/27/2016 ORIGINAL ACTIONS	03/23/2017 RESAMPLE RESULTS (ppb)	03/23/2017 RESAMPLE ACTIONS
Rm. 128 - Hallway/Corridor	Fountain	Public Access	069	MM-F109	< 1.0	None	--	--
Rm. 128 - Hallway/Corridor	Fountain	Public Access	070	MM-F110	< 1.0	None	--	--
Rm. 130A - Hallway/Vestibule	Sink	Public Access	035	MM-S133	< 1.0	None	--	--
Rm. 130A - Hallway/Vestibule	Sink	Public Access	036	MM-S134	2.2	None	--	--
Rm. 130A - Hallway/Vestibule	Sink	Public Access	037	MM-S135	1.4	None	--	--
Rm. 130A - Hallway/Vestibule	Sink	Public Access	038	MM-S136	2.8	None	--	--
Rm. 130A - Hallway/Vestibule	Sink	Public Access	039	MM-S137	3.5	None	--	--
Rm. 141 - Group Instruction Room	Sink	Secured - SCSD Staff Only	015	MM-S113	1.4	None	--	--
Rm. 219 - Hallway/Corridor	Fountain	Public Access	081	MM-F121	< 1.0	None	--	--
Rm. 219 - Hallway/Corridor	Fountain	Public Access	082	MM-F122	< 1.0	None	--	--
Rm. 221 - Staff Bathroom	Sink	Secured - SCSD Staff Only	053	MM-S151	1.6	None	--	--
Rm. 223A - Library Office	Sink	Secured - SCSD Staff Only	059	MM-S157	2.3	None	--	--
Rm. 226 - Hallway/Vestibule	Sink	Public Access	054	MM-S152	< 1.0	None	--	--
Rm. 226 - Hallway/Vestibule	Sink	Public Access	055	MM-S153	3.2	None	--	--
Rm. 226 - Hallway/Vestibule	Sink	Public Access	056	MM-S154	1.2	None	--	--
Rm. 226 - Hallway/Vestibule	Sink	Public Access	057	MM-S155	3.0	None	--	--
Rm. 226 - Hallway/Vestibule	Sink	Public Access	058	MM-S156	< 1.0	None	--	--
Rm. 228 - Hallway/Corridor	Fountain	Public Access	079	MM-F119	< 1.0	None	--	--
Rm. 228 - Hallway/Corridor	Fountain	Public Access	080	MM-F120	< 1.0	None	--	--
Rm. 228C - Staff Bathroom	Sink	Secured - SCSD Staff Only	048	MM-S146	< 1.0	None	--	--
Rm. 231 - Hallway/Vestibule	Sink	Public Access	049	MM-S147	< 1.0	None	--	--
Rm. 231 - Hallway/Vestibule	Sink	Public Access	050	MM-S148	< 1.0	None	--	--
Rm. 231 - Hallway/Vestibule	Sink	Public Access	051	MM-S149	2.8	None	--	--
Rm. 231 - Hallway/Vestibule	Sink	Public Access	052	MM-S150	< 1.0	None	--	--

Original Sampling Notes (September 27, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-022
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1619913
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to post warning sign
7. SCSD permanently removed fixture from service
8. SCSD is to replace fixture

Resampling Notes (March 23, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1703988
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".