

**SYRACUSE CITY SCHOOL DISTRICT
SALEM - HYDE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	04/27/2017 RESAMPLE RESULTS (ppb)	04/27/2017 RESAMPLE ACTIONS
Rm. 003 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	SH-005	SH-S100	< 1.0	None	--	--
Rm. 005 - Boy's Lockerroom	Sink	Public Access	SH-006	SH-S101	4.5	None	--	--
Rm. 006 - Girl's Lockerroom	Sink	Public Access	SH-040	SH-S200	< 1.0	None	--	--
Rm. 012 - Cafeteria	Fountain	Public Access	SH-001	SH-F100	< 1.0	None	--	--
Rm. 013 - Girl's Bathroom	Sink	Public Access	SH-008	SH-S103	< 1.0	None	--	--
Rm. 014 - Boy's Bathroom	Sink	Public Access	SH-007	SH-S102	1.3	None	--	--
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	SH-009	SH-S104	1.8	None	--	--
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	SH-010	SH-S105	2.0	None	--	--
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	SH-011	SH-S106	< 1.0	None	--	--
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	SH-012	SH-S107	< 1.0	None	--	--
Rm. 023 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	SH-013	SH-S108	< 1.0	None	--	--
Rm. 025 - Hallway/Corridor	Fountain	Public Access	SH-029	SH-F200	< 1.0	None	--	--
Rm. 101 - Classroom	Sink	Public Access	SH-041	SH-S201	31.0	*See Note 6	--	See Note 6
Rm. 101 - Classroom	Fountain	Public Access	SH-030	SH-F201	9.3	None	--	--
Rm. 101A - Classroom Bathroom	Sink	Public Access	SH-043	SH-S203	3.7	None	--	--
Rm. 102 - Classroom	Sink	Public Access	SH-045	SH-S205	4.0	None	--	--
Rm. 102 - Classroom	Fountain	Public Access	SH-032	SH-F203	1.6	None	--	--
Rm. 102A - Classroom Bathroom	Sink	Public Access	SH-046	SH-S206	1.4	None	--	--
Rm. 103 - Classroom	Sink	Public Access	SH-048	SH-S208	11.0	None	--	--
Rm. 104C - Office Bathroom	Sink	Secured - SCSD Staff Only	SH-047	SH-S207	< 1.0	None	--	--
Rm. 105A - Nurse's Office Exam Room	Sink	Public Access	SH-051	SH-S211	1.8	None	--	--
Rm. 105B - Nurse's Office Bathroom	Sink	Public Access	SH-052	SH-S212	< 1.0	None	--	--
Rm. 108 - Classroom	Sink	Public Access	SH-053	SH-S213	1.1	None	--	--
Rm. 109 - Classroom	Sink	Public Access	SH-054	SH-S214	< 1.0	None	--	--
Rm. 109 - Classroom	Fountain	Public Access	SH-033	SH-F204	< 1.0	None	--	--
Rm. 109A - Classroom Bathroom	Sink	Public Access	SH-055	SH-S215	3.0	None	--	--
Rm. 110 - Classroom	Fountain	Public Access	SH-034	SH-F205	2.1	None	--	--
Rm. 110 - Classroom	Sink	Public Access	SH-057	SH-S217	< 1.0	None	--	--
Rm. 110A - Classroom Bathroom	Sink	Public Access	SH-056	SH-S216	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
SALEM - HYDE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	04/27/2017 RESAMPLE RESULTS (ppb)	04/27/2017 RESAMPLE ACTIONS
Rm. 111 - Classroom	Fountain	Public Access	SH-035	SH-F206	2.9	None	--	--
Rm. 111 - Classroom	Sink	Public Access	SH-058	SH-S218	< 1.0	None	--	--
Rm. 111A - Classroom Bathroom	Sink	Public Access	SH-059	SH-S219	< 1.0	None	--	--
Rm. 112 - Classroom	Sink	Public Access	SH-060	SH-S220	1.1	None	--	--
Rm. 112 - Classroom	Fountain	Public Access	SH-036	SH-F207	< 1.0	None	--	--
Rm. 112A - Classroom Bathroom	Sink	Public Access	SH-061	SH-S221	< 1.0	None	--	--
Rm. 113 - Classroom	Fountain	Public Access	SH-037	SH-F208	< 1.0	None	--	--
Rm. 113 - Classroom	Sink	Public Access	SH-062	SH-S222	< 1.0	None	--	--
Rm. 113A - Classroom Bathroom	Sink	Public Access	SH-063	SH-S223	3.4	None	--	--
Rm. 115B - Library Work Room	Sink	Secured -SCSD Staff Only	SH-067	SH-S227	7.1	None	--	--
Rm. 119 - Classroom	Fountain	Public Access	SH-039	SH-F210	4.7	None	--	--
Rm. 119 - Classroom	Sink	Public Access	SH-068	SH-S228	3.2	None	--	--
Rm. 119A - Classroom Bathroom	Sink	Public Access	SH-069 / SH-001	SH-S229 / SH-S229B	31.0	*See Note 7	<1.0	None
Rm. 120 - Classroom	Sink	Public Access	SH-042	SH-S202	1.9	None	--	--
Rm. 120 - Classroom	Sink	Public Access	SH-044	SH-S204	6.4	None	--	--
Rm. 120 - Classroom	Fountain	Public Access	SH-031 / SH-002	SH-F202 / SH-F202B	35.0	*See Note 8	3.7	None
Rm. 131 - Hallway/Vestibule	Fountain	Public Access	SH-038	SH-F209	< 1.0	None	--	--
Rm. 131 - Hallway/Vestibule	Sink	Public Access	SH-064	SH-S224	< 1.0	None	--	--
Rm. 131 - Hallway/Vestibule	Sink	Public Access	SH-065	SH-S225	2.0	None	--	--
Rm. 131 - Hallway/Vestibule	Sink	Public Access	SH-066	SH-S226	1.7	None	--	--
Rm. 137 - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-049	SH-S209	< 1.0	None	--	--
Rm. 138 - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-050	SH-S210	1.2	None	--	--
Rm. 205 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	SH-018	SH-S113	3.6	None	--	--
Rm. 205A - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-019	SH-S114	1.4	None	--	--
Rm. 205B - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-020	SH-S115	1.7	None	--	--
Rm. 218 - Classroom	Fountain	Public Access	SH-002	SH-F101	13.0	None	--	--
Rm. 218 - Classroom	Sink	Public Access	SH-014	SH-S109	6.9	None	--	--
Rm. 224A - Hallway/Vestibule	Sink	Public Access	SH-015	SH-S110	< 1.0	None	--	--
Rm. 224A - Hallway/Vestibule	Sink	Public Access	SH-016	SH-S111	1.6	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
SALEM - HYDE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	04/27/2017 RESAMPLE RESULTS (ppb)	04/27/2017 RESAMPLE ACTIONS
Rm. 224A - Hallway/Vestibule	Sink	Public Access	SH-017	SH-S112	< 1.0	None	--	--
Rm. 224A - Hallway/Vestibule	Fountain	Public Access	SH-003	SH-F102	< 1.0	None	--	--
Rm. 225 - Hallway/Corridor	Fountain	Public Access	SH-004	SH-F103	< 1.0	None	--	--
Rm. 237 - Boy's Bathroom	Sink	Public Access	SH-025	SH-S120	< 1.0	None	--	--
Rm. 237 - Boy's Bathroom	Sink	Public Access	SH-026	SH-S121	3.5	None	--	--
Rm. 237 - Boy's Bathroom	Sink	Public Access	SH-027	SH-S122	1.4	None	--	--
Rm. 238 - Girl's Bathroom	Sink	Public Access	SH-021	SH-S116	< 1.0	None	--	--
Rm. 238 - Girl's Bathroom	Sink	Public Access	SH-022	SH-S117	< 1.0	None	--	--
Rm. 238 - Girl's Bathroom	Sink	Public Access	SH-023	SH-S118	< 1.0	None	--	--
Rm. 238 - Girl's Bathroom	Sink	Public Access	SH-024	SH-S119	< 1.0	None	--	--
Rm. 239 - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-028	SH-S123	1.4	None	--	--

Original Notes (September 17, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-005
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1616044
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to replace fixture
7. SCSD to replace fixture
8. SCSD to replace fixture

Resampling Notes (April 27, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1705886
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B"
6. Fixture not re-sampled