

**SYRACUSE CITY SCHOOL DISTRICT
PORTER ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/27/2016 SAMPLE RESULTS (ppb)	09/27/2016 ORIGINAL ACTIONS	05/05/2017 RESAMPLE RESULTS (ppb)	05/05/2017 RESAMPLE ACTIONS
Rm. 001 - Hallway/Corridor	Fountain	Public Access	064	PR-F303	< 1.0	None	--	--
Rm. 001C - Hallway/Corridor	Fountain	Public Access	063	PR-F302	< 1.0	None	--	--
Rm. 001C - Hallway/Corridor	Fountain	Public Access	062	PR-F301	< 1.0	None	--	--
Rm. 003 - Custodian's Office	Sink	Secured - SCSD Staff Only	014	PR-S313	3.0	None	--	--
Rm. 004A - Classroom Bathroom	Sink	Public Access	012	PR-S311	1.9	None	--	--
Rm. 005A - Classroom Bathroom	Sink	Public Access	011	PR-S310	2.0	None	--	--
Rm. 007 - Boy's Bathroom	Sink	Public Access	004	PR-S303	1.3	None	--	--
Rm. 007 - Boy's Bathroom	Sink	Public Access	005	PR-S304	< 1.0	None	--	--
Rm. 009 - Girl's Bathroom	Sink	Public Access	002	PR-S301	5.6	None	--	--
Rm. 009 - Girl's Bathroom	Sink	Public Access	003	PR-S302	1.1	None	--	--
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	007	PR-S306	< 1.0	None	--	--
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	008	PR-S307	2.0	None	--	--
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	009	PR-S308	2.0	None	--	--
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	010	PR-S309	6.1	None	--	--
Rm. 010C - Staff Bathroom	Sink	Secured - SCSD Staff Only	006	PR-S305	6.2	None	--	--
Rm. 014A - Classroom Bathroom	Sink	Public Access	013	PR-S312	6.1	None	--	--
Rm. 021A - Classroom Bathroom	Sink	Public Access	020 / 001	PR-S319 / PS-S319B	29.0	*See Note 6	<1.0	None
Rm. 022 - Classroom	Fountain	Public Access	066	PR-F305	< 1.0	None	--	--
Rm. 022B - Classroom Bathroom	Sink	Public Access	023	PR-S322	7.6	None	--	--
Rm. 024 - Classroom	Sink	Public Access	022	PR-S321	2.8	None	--	--
Rm. 024 - Classroom	Fountain	Public Access	065	PR-F304	< 1.0	None	--	--
Rm. 024A - Classroom Bathroom	Sink	Public Access	021	PR-S320	3.7	None	--	--
Rm. 025A - Classroom Bathroom	Sink	Public Access	019	PR-S318	3.2	None	--	--
Rm. 026 - Staff's Lounge	Sink	Secured - SCSD Staff Only	015	PR-S314	2.3	None	--	--
Rm. 026A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	016	PR-S315	1.8	None	--	--
Rm. 026A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	017	PR-S316	7.4	None	--	--
Rm. 026B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	018	PR-S317	3.4	None	--	--
Rm. 036B - Hallway/Corridor	Fountain	Public Access	067	PR-F306	< 1.0	None	--	--
Rm. 037 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	024 / 002	PR-S323 / PR-S323B	42.0	*See Note 6	1.2	None

**SYRACUSE CITY SCHOOL DISTRICT
PORTER ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/27/2016 SAMPLE RESULTS (ppb)	09/27/2016 ORIGINAL ACTIONS	05/05/2017 RESAMPLE RESULTS (ppb)	05/05/2017 RESAMPLE ACTIONS
Rm. 038 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	026 / 003	PR-S325 / PR-S325B	24.0	*See Note 6	<1.0	None
Rm. 041A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	025	PR-S324	8.0	None	--	--
Rm. 044 - Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	001	PR-S300	28.0	*See Note 7	--	--
Rm. 101 - Hallway/Corridor	Fountain	Public Access	068	PR-F307	< 1.0	None	--	--
Rm. 102D - Principal's Bathroom	Sink	Secured - SCSD Staff Only	037 / 004	PR-S336 / PR-S336B	140.0	*See Note 6	<1.0	None
Rm. 102I - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	035 / 005	PR-S334 / PR-S334B	67.0	* See Note 6	2.4	None
Rm. 102J - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	036	PR-S335	8.5	None	--	--
Rm. 103A Assist. Principal's Bathroom	Sink	Secured - SCSD Staff Only	034	PR-S333	7.4	None	--	--
Rm. 104A - Office Bathroom	Sink	Secured - SCSD Staff Only	033	PR-S332	6.4	None	--	--
Rm. 106 - Classroom	Sink	Public Access	032	PR-S331	9.2	None	--	--
Rm. 107 - Boy's Bathroom	Sink	Public Access	030	PR-S329	< 1.0	None	--	--
Rm. 107 - Boy's Bathroom	Sink	Public Access	031	PR-S330	< 1.0	None	--	--
Rm. 109 - Girl's Bathroom	Sink	Public Access	028 / 006	PR-S327 / PR-S327B	18.0	*See Note 6	<1.0	None
Rm. 109 - Girl's Bathroom	Sink	Public Access	029	PR-S328	< 1.0	None	--	--
Rm. 110A - Library Office	Sink	Secured - SCSD Staff Only	027	PR-S326	2.6	None	--	--
Rm. 116 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	039	PR-S338	12.0	None	--	--
Rm. 118C - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	042	PR-S341	4.2	None	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	043	PR-S342	< 1.0	None	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	044	PR-S343	3.3	None	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	045	PR-S344	1.5	None	--	--
Rm. 125A - Exam Room	Sink	Public Access	041	PR-S340	1.4	None	--	--
Rm. 125B - Exam Room Bathroom	Sink	Public Access	040	PR-S339	10.0	None	--	--
Rm. 127 - Parent's Room	Sink	Public Access	038	PR-S337	1.7	None	--	--
Rm. 201 - Hallway/Corridor	Fountain	Public Access	069	PR-F308	< 1.0	None	--	--
Rm. 202A - Resource Room Bathroom	Sink	Public Access	053 / 007	PR-S352 / PR-S352B	23.0	*See Note 6	1.1	None
Rm. 203 - Classroom	Sink	Public Access	052	PR-S351	3.7	None	--	--
Rm. 206 - Classroom	Sink	Public Access	051	PR-S350	1.5	None	--	--
Rm. 207 - Boy's Bathroom	Sink	Public Access	048	PR-S347	3.2	None	--	--
Rm. 207 - Boy's Bathroom	Sink	Public Access	049	PR-S348	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
PORTER ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/27/2016 SAMPLE RESULTS (ppb)	09/27/2016 ORIGINAL ACTIONS	05/05/2017 RESAMPLE RESULTS (ppb)	05/05/2017 RESAMPLE ACTIONS
Rm. 209 - Girl's Bathroom	Sink	Public Access	046	PR-S345	< 1.0	None	--	--
Rm. 209 - Girl's Bathroom	Sink	Public Access	047	PR-S346	1.2	None	--	--
Rm. 212 - Classroom	Sink	Public Access	050 / 008	PR-S349 / PR-S349B	29.0	*See Note 6	<1.0	None
Rm. 218 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	057	PR-S356	3.5	None	--	--
Rm. 220A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	058 / 009	PR-S357 / PR-S357B	15.0	*See Note 6	<1.0	None
Rm. 221 - Hallway/Vestibule	Sink	Public Access	059	PR-S358	2.3	None	--	--
Rm. 221 - Hallway/Vestibule	Sink	Public Access	060	PR-S359	11.0	None	--	--
Rm. 221 - Hallway/Vestibule	Sink	Public Access	061	PR-S360	< 1.0	None	--	--
Rm. 226 - Classroom	Sink	Public Access	056	PR-S355	6.4	None	--	--
Rm. 228 - Art Room	Sink	Public Access	054	PR-S353	72.0	*See Note 8	--	--
Rm. 228 - Art Room	Sink	Public Access	055	PR-S354	30.0	*See Note 8	--	--

Original Notes (September 27, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-021
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620702
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD is to replace fixture
7. SCSD to post warning sign
8. SCSD permanently removed fixture from service

Resampling Notes (May 5, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1706476
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".