

**SYRACUSE CITY SCHOOL DISTRICT  
CORCORAN HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	OCTOBER 2016 SAMPLE RESULTS (ppb)	OCTOBER 2016 ORIGINAL ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
<b>BUILDING SECTION 'A'</b>								
Rm. A8 - Mechanical/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	CN-001	CN-M400	4.7	None	--	--
Rm. A100C - Conference Room	Sink	Public Access	CN-027	CN-S425	5.8	None	--	--
Rm. A105 - Kitchenette (Between Classrooms)	Sink	Public Access	CN-025	CN-S423	< 1.0	None	--	--
Rm. A106 - Kitchen	Ice Machine	Secured - SCSD Staff Only	CN-002	CN-S400	< 1.0	None	--	--
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-003	CN-S401	8.3	None	--	--
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-004	CN-S402	3.2	None	--	--
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-005	CN-S403	2.7	None	--	--
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-006	CN-S404	3.7	None	--	--
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-007	CN-S405	2.5	None	--	--
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-008	CN-S406	2.5	None	--	--
Rm. A106 - Kitchen	Sink	Secured - SCSD Staff Only	CN-009	CN-S407	5.2	None	--	--
Rm. A106/A157 - Kitchen	Sink	Secured - SCSD Staff Only	CN-010	CN-S408	7.8	None	--	--
Rm. A109 - Clinic Office	Sink	Public Access	CN-011	CN-S409	< 1.0	None	--	--
Rm. A111 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	CN-014	CN-S412	2.0	None	--	--
Rm. A111 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-020	CN-S418	1.4	None	--	--
Rm. A113 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-019	CN-S417	1.5	None	--	--
Rm. A114 - Girl's Bathroom	Sink	Public Access	CN-015	CN-S413	1.7	None	--	--
Rm. A114 - Girl's Bathroom	Sink	Public Access	CN-016	CN-S414	1.8	None	--	--
Rm. A114 - Girl's Bathroom	Sink	Public Access	CN-017	CN-S415	1.2	None	--	--
Rm. A114 - Girl's Bathroom	Sink	Public Access	CN-018	CN-S416	2.4	None	--	--
Rm. A116 - Classroom	Sink	Public Access	CN-024	CN-S422	2.4	None	--	--
Rm. A117 - Classroom	Sink	Public Access	CN-026	CN-S424	11.0	None	--	--
Rm. A121 - Exam Room Bathroom	Sink	Public Access	CN-012	CN-S410	3.0	None	--	--
Rm. A122 - Clinic Office Bathroom	Sink	Public Access	CN-013	CN-S411	3.3	None	--	--
Rm. A142 - Main Office Men's Bathroom	Sink	Secured - SCSD Staff Only	CN-029	CN-S427	1.5	None	--	--
Rm. A143 - Main Office Women's Bathroom	Sink	Secured - SCSD Staff Only	CN-028	CN-S426	1.6	None	--	--
Rm. A151 - Hallway/Corridor	Fountain	Public Access	CN-051	CN-F402	7.7	None	--	--
Rm. A155 - Cafeteria	Fountain	Public Access	CN-049	CN-F400	12.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
CORCORAN HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	OCTOBER 2016 SAMPLE RESULTS (ppb)	OCTOBER 2016 ORIGINAL ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
<b>BUILDING SECTION 'A', Cont.</b>								
Rm. A155 - Cafeteria	Fountain	Public Access	CN-050	CN-F401	16.0	See note 6.	7.2	None
Rm. A170 - Staff Locker Room Bathroom	Sink	Secured - SCSD Staff Only	CN-030	CN-S428	4.7	None	--	--
Rm. A180 - Boy's Bathroom	Sink	Public Access	CN-021	CN-S419	1.8	None	--	--
Rm. A180 - Boy's Bathroom	Sink	Public Access	CN-022	CN-S420	< 1.0	None	--	--
Rm. A180 - Boy's Bathroom	Sink	Public Access	CN-023	CN-S421	< 1.0	None	--	--
Rm. A216 - Office	Sink	Secured - SCSD Staff Only	CN-035	CN-S433	66.0	See note 6.	4.7	None
Rm. A218A - Library	Fountain	Public Access	CN-052	CN-F403	2.0	None	--	--
Rm. A225 - Copy Room	Sink	Secured - SCSD Staff Only	CN-036	CN-S434	1.6	None	--	--
Rm. A231 - Hallway/Corridor	Fountain	Public Access	CN-053	CN-F404	6.2	None	--	--
Rm. A234 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-039	CN-S437	3.1	None	--	--
Rm. A238 - Girl's Bathroom	Sink	Public Access	CN-037	CN-S435	7.4	None	--	--
Rm. A238 - Girl's Bathroom	Sink	Public Access	CN-038	CN-S436	1.7	None	--	--
Rm. A243 - Boy's Bathroom	Sink	Public Access	CN-032	CN-S430	3.1	None	--	--
Rm. A243 - Boy's Bathroom	Sink	Public Access	CN-033	CN-S431	2.4	None	--	--
Rm. A243 - Boy's Bathroom	Sink	Public Access	CN-034	CN-S432	2.8	None	--	--
Rm. A244 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-031	CN-S429	2.2	None	--	--
Rm. A324 - Girl's Bathroom	Sink	Public Access	CN-044	CN-S442	4.4	None	--	--
Rm. A324 - Girl's Bathroom	Sink	Public Access	CN-045	CN-S443	3.3	None	--	--
Rm. A324 - Girl's Bathroom	Sink	Public Access	CN-046	CN-S444	2.2	None	--	--
Rm. A328 - Classroom	Sink	Public Access	CN-048	CN-S446	14.0	None	--	--
Rm. A330 - Hallway/Corridor	Fountain	Public Access	CN-054	CN-F405	3.9	None	--	--
Rm. A335 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-047	CN-S445	2.4	None	--	--
Rm. A345 - Boy's Bathroom	Sink	Public Access	CN-041	CN-S439	3.9	None	--	--
Rm. A345 - Boy's Bathroom	Sink	Public Access	CN-042	CN-S440	4.6	None	--	--
Rm. A345 - Boy's Bathroom	Sink	Public Access	CN-043	CN-S441	3.6	None	--	--
Rm. A347 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-040	CN-S438	2.8	None	--	--
Rm. A355 - Hallway/Corridor	Fountain	Public Access	CN-055	CN-F406	9.1	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
CORCORAN HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	OCTOBER 2016 SAMPLE RESULTS (ppb)	OCTOBER 2016 ORIGINAL ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
<b>BUILDING SECTION 'B'</b>								
Rm. B003 - Hallway/Corridor	Fountain	Public Access	CN-045	CN-F101	8.6	None	--	--
Rm. B04 - Storage Room	Sink	Secured - SCSD Staff Only	CN-004	CN-S103	170.0	See note 6.	<1.0	None
Rm. B4 - Art Room	Fountain	Public Access	CN-046	CN-F102	10.0	None	--	--
Rm. B11A - Boy's Bathroom	Ice Machine	Public Access	CN-022	CN-S120	< 1.0	None	--	--
Rm. B11A - Boy's Bathroom	Sink	Public Access	CN-016	CN-S114	11.0	None	--	--
Rm. B11A - Boy's Bathroom	Sink	Public Access	CN-017	CN-S115	6.6	None	--	--
Rm. B11B - Girl's Bathroom	Sink	Public Access	CN-015	CN-S113	17.0	See note 6.	1.0	None
Rm. B17 - Boy's Bathroom	Sink	Public Access	CN-005	CN-S104	4.6	None	--	--
Rm. B17 - Boy's Bathroom	Sink	Public Access	CN-006	CN-S105	4.8	None	--	--
Rm. B18 - Girl's Bathroom	Sink	Public Access	CN-007	CN-S106	8.1	None	--	--
Rm. B18 - Girl's Bathroom	Sink	Public Access	CN-008	CN-S107	2.4	None	--	--
Rm. B33 - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	CN-011	CN-S109B	11.0	None	--	--
Rm. B35 - Girl's Locker Room	Fountain	Public Access	CN-047	CN-F103	74.0	See note 6.	1.5	None
Rm. B36 - Girl's Locker Room Bathroom	Sink	Public Access	CN-009	CN-S108	1.8	None	--	--
Rm. B36 - Girl's Locker Room Bathroom	Sink	Public Access	CN-010	CN-S109A	3.5	None	--	--
Rm. B43 - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	CN-014	CN-S112	6.8	None	--	--
Rm. B45A - Boy's Locker Room Bathroom	Sink	Public Access	CN-012	CN-S110	1.8	None	--	--
Rm. B45A - Boy's Locker Room Bathroom	Sink	Public Access	CN-013	CN-S111	1.6	None	--	--
Rm. B51 - Staff's Locker Room	Fountain	Secured - SCSD Staff Only	CN-050	CN-F106	80.0	See note 6.	13.0	None
Rm. B52 - Staff Locker Room Bathroom	Sink	Secured - SCSD Staff Only	CN-018	CN-S116	2.3	None	--	--
Rm. B54 - Hallway/Corridor	Fountain	Public Access	CN-048	CN-F104	< 1.0	None	--	--
Rm. B54 - Hallway/Corridor	Fountain	Public Access	CN-049	CN-F105	4.2	None	--	--
Rm. B55 - Hallway/Corridor	Fountain	Public Access	CN-051	CN-F107	3.3	None	--	--
Rm. B61 - Pool	Fountain	Public Access	CN-052	CN-F108	13.0	None	--	--
Rm. B101 - Hallway/Corridor	Fountain	Public Access	CN-055	CN-F111	< 1.0	None	--	--
Rm. B102 - Home & Careers Room	Sink	Public Access	CN-030	CN-S507	5.2	None	--	--
Rm. B102 - Home & Careers Room	Sink	Public Access	CN-031	CN-S508	5.2	None	--	--
Rm. B104 - Home & Careers Room	Sink	Public Access	CN-026	CN-S503	69.0	See note 6.	2.1	None

**SYRACUSE CITY SCHOOL DISTRICT  
CORCORAN HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	OCTOBER 2016 SAMPLE RESULTS (ppb)	OCTOBER 2016 ORIGINAL ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
<b>BUILDING SECTION 'B', Cont.</b>								
Rm. B104 - Home & Careers Room	Sink	Public Access	CN-027	CN-S504	2.6	None	--	--
Rm. B104 - Home & Careers Room	Sink	Public Access	CN-028	CN-S505	4.9	None	--	--
Rm. B104 - Home & Careers Room	Sink	Public Access	CN-029	CN-S506	17.0	See note 7.	33.0	TBD
Rm. B104 - Hallway/Corridor	Fountain	Public Access	CN-043	CN-F520	13.0	None	--	--
Rm. B107 - Classroom	Sink	Public Access	CN-025	CN-S502	59.0	See note 8.	--	--
Rm. B108 - Classroom	Sink	Public Access	CN-024	CN-S501	62.0	See note 8.	--	--
Rm. B109 - Classroom	Sink	Public Access	CN-042	CN-S519	2.8	None	--	--
Rm. B109B - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	CN-023	CN-S500	7.8	None	--	--
Rm. B111 - Classroom	Sink	Public Access	CN-040	CH-S517	8.4	None	--	--
Rm. B112 - Classroom	Sink	Public Access	CN-041	CN-S518	4.1	None	--	--
Rm. B113 - Classroom	Sink	Public Access	CN-039	CN-S516	9.2	None	--	--
Rm. B117 - Girl's Locker Room	Fountain	Public Access	CN-054	CN-F110	< 1.0	None	--	--
Rm. B119 - Girl's Locker Room Bathroom	Sink	Public Access	CN-021	CN-S119	3.3	None	--	--
Rm. B122 - Boy's Locker Room Bathroom	Sink	Public Access	CN-020	CN-S118	6.9	None	--	--
Rm. B122 - Boy's Locker Room	Fountain	Public Access	CN-053	CN-F109	< 1.0	None	--	--
Rm. B125 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	CN-019	CN-S117	2.4	None	--	--
Rm. B213 - Girl's Bathroom	Sink	Public Access	CN-036	CN-S513	5.6	None	--	--
Rm. B213 - Girl's Bathroom	Sink	Public Access	CN-037	CN-S514	6.7	None	--	--
Rm. B214 - Boy's Bathroom	Sink	Public Access	CN-038	CN-S515	4.0	None	--	--
Rm. B216 - Staff Bathroom	Sink	Secured - SCSD Staff Only	CN-034	CN-S511	290.0	See note 6.	1.1	None
Rm. B221 - Boy's Bathroom	Sink	Public Access	CN-033	CN-S510	6.4	None	--	--
Rm. B222 - Girl's Bathroom	Sink	Public Access	CN-032	CN-S509	9.5	None	--	--
Rm. B224 - Hallway/Corridor	Fountain	Public Access	CN-035	CN-F512	1.1	None	--	--
<b>BUILDING SECTION 'C'</b>								
Rm. C108 - Hallway/Corridor	Fountain	Public Access	CN-044	CN-F100	< 1.0	None	--	--
Rm. C111 - Boy's Locker Bathroom	Sink	Public Access	CN-002	CN-S101	4.5	None	--	--
Rm. C113 - Girl's Locker Bathroom	Sink	Public Access	CN-001	CN-S100	3.4	None	--	--
Rm. C114 - Storage Room	Sink	Secured - SCSD Staff Only	CN-003	CN-S102	2000.0	See note 8.	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
CORCORAN HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	OCTOBER 2016 SAMPLE RESULTS (ppb)	OCTOBER 2016 ORIGINAL ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
<b>FIELD HOUSE/CONCESSION STAND</b>								
Outside Wall Mount	Fountain	Public Access	CNFH-016	CNFH-F100	< 1.0	None	--	--
Outside Wall Mount	Fountain	Public Access	CNFH-017	CNFH-F101	< 1.0	None	--	--
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-001	CNFH-S100	30.0	See note 6.	4.5	None
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-002	CNFH-S101	5.9	None	--	--
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-003	CNFH-S102	2.8	None	--	--
Rm. A1 - Concession Stand	Hose Bib	Secured - SCSD Staff Only	CNFH-004	CNFH-S103	1.6	None	--	--
Rm. A3 - Men's Bathroom	Sink	Public Access	CNFH-005	CNFH-S104	1.5	None	--	--
Rm. A3 - Men's Bathroom	Sink	Public Access	CNFH-006	CNFH-S105	1.6	None	--	--
Rm. A4 - Women's Bathroom	Sink	Public Access	--	CNFH-S106	--	See note 9.	--	--
Rm. A4 - Women's Bathroom	Sink	Public Access	CNFH-007	CNFH-S107	1.0	None	--	--
Rm. A5 - Home Team Locker Room	Sink	Public Access	CNFH-008	CNFH-S108	3.0	None	--	--
Rm. A5 - Home Team Locker Room	Sink	Public Access	CNFH-009	CNFH-S109	< 1.0	None	--	--
Rm. A5 - Home Team Locker Room	Ice Machine	Public Access	CNFH-010	CNFH-S110	< 1.0	None	--	--
Rm. A5 - Home Team Locker Room	Hose Bib	Public Access	CNFH-011	CNFH-S111	< 1.0	None	--	--
Rm. A8 - Visiting Team Locker Room	High Hose Bib	Public Access	CNFH-012	CNFH-S112	< 1.0	None	--	--
Rm. A8 - Visiting Team Locker Room	Sink	Public Access	CNFH-013	CNFH-S113	1.2	None	--	--
Rm. A8 - Visiting Team Locker Room	Sink	Public Access	--	CNFH-S114	--	See note 9.	--	--
Rm. A8 - Visiting Team Locker Room	Low Hose Bib	Public Access	CNFH-014	CNFH-S115	< 1.0	None	--	--
Rm. A12 - Official's Bathroom/Lounge	Sink	Secured - SCSD Staff Only	CNFH-015	CNFH-S116	1.3	None	--	--

Original Sampling Notes (October 9, 21 and 27, 2016 Events):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project Nos. 2016068-028, 2016068-040 and 2016068-045
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620840, 1620735, 1619197
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD removed and replaced fixture from service.
7. SCSD to post warning sign.
8. SCSD permanently removed fixture from service.
9. Fixture is not operating.

Resampling Notes (November 10, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1718688; November 16,
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.