

SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/25/16 RESAMPLE RESULTS (ppb)	10/25/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 101 - Boy's Bathroom	Sink	Public Access	BT2-017	BT-S414	23.0	See Note 6	4.7	None
Rm. 101 - Boy's Bathroom	Sink	Public Access	BT2-018	BT-S415	23.0	See Note 6	2.9	None
Rm. 102 - Classroom	Sink	Public Access	BT2-003	BT-S400	9.6	None	--	--
Rm. 106 - Classroom	Sink	Public Access	BT2-011	BT-S408	34.0	See Note 6	6.3	None
Rm. 106 - Classroom	Sink	Public Access	BT2-015	BT-S412	4.6	None	--	--
Rm. 106 - Classroom	Sink	Public Access	BT2-016	BT-S413	11.0	None	--	--
Rm. 116 - Classroom	Fountain	Public Access	BT2-035	BT-F401	< 1.0	None	--	--
Rm. 110 - Parent Room	Sink	Secured - SCSD Staff Only	BT2-013	BT-S410	1.3	None	--	--
Rm. 110 - Parent Room	Sink	Secured - SCSD Staff Only	BT2-014	BT-S411	< 1.0	None	--	--
Rm. 115 - Girl's Bathroom	Sink	Public Access	BT-007	BT-S404	44.0	See Note 6	2.6	None
Rm. 115 - Girl's Bathroom	Sink	Public Access	BT2-008	BT-S405	19.0	See Note 6	1.3	None
Rm. 115 - Girl's Bathroom	Sink	Public Access	BT2-009	BT-S406	28.0	See Note 6	12.0	None
Rm. 118 - Art Room	Sink	Public Access	BT2-021	BT-S418	< 1.0	None	--	--
Rm. 119 - Lounge	Sink	Secured - SCSD Staff Only	BT2-020	BT-S417	4.6	None	--	--
Rm. 124 - Classroom	Sink	Public Access	BT2-006	BT-S403	< 1.0	None	--	--
Rm. 133 - Boiler/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	BT2-002	BT-M400	8.9	None	--	--
Rm. 136 - Classroom Bathroom	Sink	Public Access	BT2-010	BT-S407	6.9	None	--	--
Rm. 142A - Classroom	Sink	Public Access	BT2-012	BT-S409	7.2	None	--	--
Rm. 145A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	BT2-025	BT-S422	< 1.0	None	--	--
Rm. 147A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	BT2-026	BT-S423	< 1.0	None	--	--
Rm. 149A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	BT2-029	BT-S426	3.9	None	--	--
Rm. 159 - Hallway/Corridor	Fountain	Public Access	BT2-037	BT-F403	50.0	See Note 6	42.0	See Note 5
Rm. 159 - Hallway/Corridor	Fountain	Public Access	BT2-036	BT-F402	< 1.0	None	--	--
Rm. 161 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT2-027	BT-S424	3.6	None	--	--
Rm. 161 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT2-028	BT-S425	2.8	None	--	--
Rm. 163 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT2-023	BT-S420	2.5	None	--	--
Rm. 163 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT2-024	BT-S421	3.2	None	--	--
Rm. 164 - Classroom	Sink	Public Access	BT2-004	BT-S401	27.0	See Note 6	<1.0	None
Rm. 168 - Classroom Bathroom	Sink	Public Access	BT2-005	BT-S402	4.1	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/25/16 RESAMPLE RESULTS (ppb)	10/25/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 175A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	BT2-022	BT-S419	2.9	None	--	--
Rm. 184 - Hallway/Corridor	Fountain	Public Access	BT2-034	BT-F400	< 1.0	None	--	--
Rm. 192 - Hallway/Passageway	Sink	Public Access	BT2-019	BT-S416	10.0	None	--	--
Rm. 202 - Classroom	Sink	Public Access	BT1-009	BT-S324	1.7	None	--	--
Rm. 203 - Girl's Bathroom	Sink	Public Access	BT1-004	BT-S319	83.0	See Note 6	<1.0	None
Rm. 203 - Girl's Bathroom	Sink	Public Access	BT1-005	BT-S320	23.0	See Note 7	--	--
Rm. 203 - Girl's Bathroom	Sink	Public Access	BT1-006	BT-S321	48.0	See Note 6	2.6	None
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-010	BT-S325	1.9	None	--	--
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-011	BT-S326	1.7	None	--	--
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-012	BT-S327	1.9	None	--	--
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-013	BT-S328	33.0	See Note 6	1.2	None
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-014	BT-S329	3.2	None	--	--
Rm. 204 - Nurse's Office	Sink	Public Access	BT1-015	BT-S330	19.0	See Note 6	6.0	None
Rm. 206 - Health Center	Sink	Public Access	BT1-016	BT-S331	2.0	None	--	--
Rm. 206 - Health Center	Sink	Public Access	BT1-017	BT-S332	1.7	None	--	--
Rm. 206 - Health Center Bathroom	Sink	Public Access	BT1-018	BT-S333	1.4	None	--	--
Rm. 207 - Office Bathroom	Sink	Secured - SCSD Staff Only	BT1-019	BT-S334	1.9	None	--	--
Rm. 215 - Cafeteria	Sink	Secured - SCSD Staff Only	BT2-001	BT-S337	16.0	See Note 6	--	See Note 6
Rm. 217A - Boy's Bathroom	Sink	Public Access	BT1-020	BT-S335	6.4	None	--	--
Rm. 217A - Boy's Bathroom	Sink	Public Access	BT1-021	BT-S336	4.9	None	--	--
Rm. 221 - Hallway/Corridor	Fountain	Secured - SCSD Staff Only	BT1-008	BT-F323	1.0	None	--	--
Rm. 221A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT1-007	BT-S322	18.0	See Note 7	--	--
Rm. 221A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	013A	BT-S322A	--	--	<1.0	None
Rm. 226 - Cafeteria	Fountain	Public Access	BT2-038	BT-F404	53.0	See Note 6	<1.0	None
Rm. 226 - Cafeteria	Sink	Public Access	BT2-030	BT-S427	22.0	See Note 7	--	--
Rm. 227B - Storage Room	Sink	Secured - SCSD Staff Only	BT2-032	BT-S429	3.9	None	--	--
Rm. 227B - Storage Room	Sink	Secured - SCSD Staff Only	BT2-033	BT-S430	1.2	None	--	--
Rm. 227E - Serving Room	Sink	Secured - SCSD Staff Only	BT2-031	BT-S428	5.5	None	--	--
Rm. 227F - Staff Bathroom	Sink	Secured - SCSD Staff Only	015A	BT-S427A	--	--	1.5	None

SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/25/16 RESAMPLE RESULTS (ppb)	10/25/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 303 - Girl's Bathroom	Sink	Public Access	BT1-031	BT-S310	5.4	None	--	--
Rm. 303 - Girl's Bathroom	Sink	Public Access	BT1-032	BT-S311	7.3	None	--	--
Rm. 303 - Girl's Bathroom	Sink	Public Access	BT1-033	BT-S312	6.5	None	--	--
Rm. 309 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT1-036	BT-S315	3.5	None	--	--
Rm. 309 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	BT1-001	BT-S316	4.1	None	--	--
Rm. 310 - Classroom	Sink	Public Access	BT1-034	BT-S313	16.0	See Note 6	--	See Note 6
Rm. 311 - Boy's Bathroom	Sink	Public Access	BT1-002	BT-S317	18.0	See Note 6	<1.0	None
Rm. 311 - Boy's Bathroom	Sink	Public Access	BT1-003	BT-S318	11.0	None	--	--
Rm. 318 - Hallway/Corridor	Fountain	Public Access	BT1-035	BT-F314	1.2	None	--	--
Rm. 400 - Classroom	Sink	Public Access	BT1-023	BT-S302	1.2	None	--	--
Rm. 401 - Classroom	Sink	Public Access	BT1-022	BT-S301	3.3	None	--	--
Rm. 411 - Classroom	Sink	Public Access	BT1-028	BT-S307	10.0	None	--	--
Rm. 413 - Girl's Bathroom	Sink	Public Access	BT1-024	BT-S303	23.0	See Note 6	3.8	None
Rm. 413 - Girl's Bathroom	Sink	Public Access	BT1-025	BT-S304	7.9	None	--	--
Rm. 413 - Girl's Bathroom	Sink	Public Access	BT1-026	BT-S305	7.0	None	--	--
Rm. 423 - Hallway/Corridor	Fountain	Public Access	BT1-027	BT-F306	< 1.0	None	--	--
Rm. 430 - Boy's Bathroom	Sink	Public Access	BT1-029	BT-S308	2.2	None	--	--
Rm. 430 - Boy's Bathroom	Sink	Public Access	BT1-030	BT-S309	2.3	None	--	--

Original Sampling Notes (October 25, 2016):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620943, 1620944
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD is to remove and replace fixture.
7. SCSD permanently removed fixture.

Resampling Notes (November 22, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1719312; November 28, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. SCSD is to remove and replace fixture.
6. Fixture is not operating.