

SYRACUSE CITY SCHOOL DISTRICT
DELAWARE ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/28 & 29/16 SAMPLE RESULTS (ppb)	09/28 & 29/16 ORIGINAL ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 101 - Classroom	Sink	Public Access	DE-033	DE-S332	28.0	* See Note 7	<1.0	None
Rm. 101 - Classroom	Fountain	Public Access	DE-078	DE-F310	1.8	None	--	--
Rm. 101A - Classroom Bathroom	Sink	Public Access	DE-034	DE-S333	11.0	None	--	--
Rm. 102 - Classroom	Sink	Public Access	DE-031	DE-S330	< 1.0	None	--	--
Rm. 102 - Classroom	Fountain	Public Access	DE-077	DE-F309	4.1	None	--	--
Rm. 102A - Classroom Bathroom	Sink	Public Access	DE-032	DE-S331	1.2	None	--	--
Rm. 103 - Classroom	Sink	Public Access	DE-026	DE-S325	3.0	None	--	--
Rm. 103 - Classroom	Fountain	Public Access	DE-075	DE-F307	2.7	None	--	--
Rm. 103A - Classroom Bathroom	Sink	Public Access	DE-027	DE-S326	< 1.0	None	--	--
Rm. 104 - Classroom	Sink	Public Access	DE-025	DE-S324	1.8	None	--	--
Rm. 104 - Classroom	Fountain	Public Access	DE-074	DE-F306	3.4	None	--	--
Rm. 104A - Classroom Bathroom	Sink	Public Access	DE-024	DE-S323	< 1.0	None	--	--
Rm. 105 - Classroom	Sink	Public Access	DE-029	DE-S328	< 1.0	None	--	--
Rm. 105 - Classroom	Fountain	Public Access	DE-076	DE-F308	1.1	None	--	--
Rm. 105A - Classroom Bathroom	Sink	Public Access	DE-028	DE-S327	< 1.0	None	--	--
Rm. 108 - Classroom	Sink	Public Access	DE-021	DE-S320	< 1.0	None	--	--
Rm. 108 - Classroom	Fountain	Public Access	DE-072	DE-F304	1.8	None	--	--
Rm. 108A - Classroom Bathroom	Sink	Public Access	DE-020	DE-S319	4.6	None	--	--
Rm. 110 - Classroom	Sink	Public Access	DE-019	DE-S318	2.1	None	--	--
Rm. 110 - Classroom	Fountain	Public Access	DE-071	DE-F303	1.7	None	--	--
Rm. 112 - Classroom	Sink	Public Access	DE-017	DE-S316	2.1	None	--	--
Rm. 112 - Classroom	Fountain	Public Access	DE-070	DE-F302	1.4	None	--	--
Rm. 112A - Classroom Bathroom	Sink	Public Access	DE-016	DE-S315	26.0	* See Note 7	<1.0	None
Rm. 113 - Art Room	Sink	Public Access	DE-015	DE-S314	2.1	None	--	--
Rm. 114A - Girl's Locker Room Bathroom	Sink	Public Access	DE-013	DE-S312	4.3	None	--	--
Rm. 114A - Girl's Locker Room Bathroom	Sink	Public Access	DE-014	DE-S313	7.3	None	--	--
Rm. 115B - Boy's Locker Room Bathroom	Sink	Public Access	DE-012	DE-S311	2.1	None	--	--
Rm. 118 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	DE-007	DE-S306	1.3	None	--	--
Rm. 118A - Teacher's Lounge Bathroom	Sink	Secured - SCSD Staff Only	DE-008	DE-S307	< 1.0	None	--	--
Rm. 119D - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	DE-011	DE-S310	7.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
DELAWARE ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/28 & 29/16 SAMPLE RESULTS (ppb)	09/28 & 29/16 ORIGINAL ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	DE-002	DE-S301	3.4	None	--	--
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	DE-003	DE-S302	3.5	None	--	--
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	DE-004	DE-S303	7.4	None	--	--
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	DE-005	DE-S304	39.0	* See Note 7	<1.0	None
Rm. 120A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	DE-006	DE-S305	27.0	* See Note 7	<1.0	None
Rm. 123A - Hallway/Corridor	Fountain	Public Access	DE-069	DE-F301	< 1.0	None	--	--
Rm. 129 - Hallway/Corridor	Fountain	Public Access	DE-073	DE-F305	< 1.0	None	--	--
Rm. 134B - Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-030	DE-S329	29.0	* See Note 7	<1.0	None
Rm. 139 - Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	DE-001	DE-M300	36.0	* See Note 8	<1.0	See Note 5
Rm. 141A - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-022	DE-S321	170.0	* See Note 7	<1.0	None
Rm. 141B - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-023	DE-S322	46.0	* See Note 7	<1.0	None
Rm. 145A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-009	DE-S308	2.8	None	--	--
Rm. 145B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-010	DE-S309	28.0	* See Note 7	<1.0	None
Rm. 190A - Classroom Bathroom	Sink	Public Access	DE-018	DE-S317	< 1.0	None	--	--
Rm. 206A - Clinic Bathroom	Sink	Public Access	DE-043	DE-S342	6.0	None	--	--
Rm. 206B - Clinical Lab	Sink	Public Access	DE-042	DE-S341	11.0	None	--	--
Rm. 206C - Treatment Center	Sink	Public Access	DE-041	DE-S340	6.7	None	--	--
Rm. 206D - Dental Room	Sink	Public Access	DE-040	DE-S339	5.7	None	--	--
Rm. 206E - Sick/Rest Room	Sink	Public Access	DE-039	DE-S338	11.0	None	--	--
Rm. 206F - Nurse's Room	Sink	Public Access	DE-038	DE-S337	2.3	None	--	--
Rm. 208C - Storage Room Bathroom	Sink	Secured - SCSD Staff Only	DE-044	DE-S343	< 1.0	None	--	--
Rm. 209 - Nurse's Room	Sink	Public Access	DE-046	DE-S345	< 1.0	None	--	--
Rm. 209A - Nurse's Bathroom	Sink	Public Access	DE-045	DE-S344	39.0	* See Note 7	<1.0	None
Rm. 211A - Office Bathroom	Sink	Secured - SCSD Staff Only	DE-052	DE-S351	21.0	* See Note 7	<1.0	None
Rm. 211B - Office Bathroom	Sink	Secured - SCSD Staff Only	DE-051	DE-S350	3.9	None	--	--
Rm. 232 - Hallway/Corridor	Fountain	Public Access	DE-079	DE-F311	< 1.0	None	--	--
Rm. 235 - Hallway/Vestibule	Sink	Public Access	DE-035	DE-S334	< 1.0	None	--	--
Rm. 235 - Hallway/Vestibule	Sink	Public Access	DE-036	DE-S335	< 1.0	None	--	--
Rm. 235 - Hallway/Vestibule	Sink	Public Access	DE-037	DE-S336	< 1.0	None	--	--
Rm. 240 - Hallway/Vestibule	Sink	Public Access	DE-047	DE-S346	< 1.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
DELAWARE ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/28 & 29/16 SAMPLE RESULTS (ppb)	09/28 & 29/16 ORIGINAL ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 240 - Hallway/Vestibule	Sink	Public Access	DE-048	DE-S347	22.0	* See Note 7	<1.0	None
Rm. 240 - Hallway/Vestibule	Sink	Public Access	DE-049	DE-S348	13.0	None	--	--
Rm. 240 - Hallway/Vestibule	Sink	Public Access	DE-050	DE-S349	1.2	None	--	--
Rm. 240 - Hallway/Vestibule	Fountain	Public Access	DE-080	DE-F312	< 1.0	None	--	--
Rm. 245 - Gym Lobby	Fountain	Public Access	DE-081	DE-F313	< 1.0	None	--	--
Rm. 306A - Classroom Bathroom	Sink	Public Access	DE-060	DE-S359	23.0	* See Note 7	<1.0	None
Rm. 308A - Classroom Bathroom	Sink	Public Access	DE-059	DE-S358	1.6	None	--	--
Rm. 319 - Work Room	Sink	Public Access	DE-053	DE-S352	7.9	None	--	--
Rm. 324A - Hallway/Corridor	Fountain	Public Access	DE-082	DE-F314	< 1.0	None	--	--
Rm. 330A - Hallway/Vestibule	Fountain	Public Access	DE-085	DE-F317	1.5	None	--	--
Rm. 335 - Hallway/Vestibule	Sink	Public Access	DE-061	DE-S360	25.0	* See Note 7	<1.0	None
Rm. 335 - Hallway/Vestibule	Sink	Public Access	DE-062	DE-S361	2.7	None	--	--
Rm. 335 - Hallway/Vestibule	Sink	Public Access	DE-063	DE-S362	4.4	None	--	--
Rm. 340 - Hallway/Vestibule	Sink	Public Access	DE-055	DE-S354	1.1	None	--	--
Rm. 340 - Hallway/Vestibule	Sink	Public Access	DE-056	DE-S355	< 1.0	None	--	--
Rm. 340 - Hallway/Vestibule	Sink	Public Access	DE-057	DE-S356	4.1	None	--	--
Rm. 340 - Hallway/Vestibule	Sink	Public Access	DE-058	DE-S357	< 1.0	None	--	--
Rm. 340 - Hallway/Vestibule	Fountain	Public Access	DE-083	DE-F315	< 1.0	None	--	--
Rm. 345A - Teacher's Lounge Bathroom	Sink	Secured - SCSD Staff Only	DE-054	DE-S353	21.0	* See Note 7	<1.0	None
Rm. 405 - Girl's Bathroom	Sink	Public Access	DE-064	DE-S363	< 1.0	None	--	--
Rm. 405 - Girl's Bathroom	Sink	Public Access	DE-065	DE-S364	17.0	* See Note 7	<1.0	None
Rm. 406 - Boy's Bathroom	Sink	Public Access	DE-067	DE-S366	5.8	None	--	--
Rm. 406 - Boy's Bathroom	Sink	Public Access	DE-068	DE-S367	3.2	None	--	--
Rm. 407 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-066	DE-S365	3.9	None	--	--
Rm. 429 - Hallway/Corridor	Fountain	Public Access	DE-084	DE-F316	< 1.0	None	--	--

Original Sampling Notes (September 28 & 29, 2016 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-023
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1620673; December 19, 21 and 26, 2016
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD is to replace fixture.
7. SCSD to post warning sign.

Resampling Notes (November 22, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1719311; November 28, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Water sample was collected from sink faucet in meter room.