

SYRACUSE CITY SCHOOL DISTRICT
MSAP (SHEA) SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/21/16 RESAMPLE RESULTS (ppb)	10/21/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-017	MSAP-S115	14.0	None	--	--
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-018	MSAP-S116	18.0	See Note 7	--	--
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-019	MSAP-S117	14.0	None	--	--
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-020	MSAP-S118	38.0	See Note 6	<1.0	None
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-021	MSAP-S119	7.4	None	--	--
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-022	MSAP-S120	15.0	See Note 6	1.5	None
Rm. 106 - Kitchen	Kettle	Secured - SCSD Staff Only	MSAP-023	MSAP-S121	110.0	See Note 7	--	--
Rm. 106 - Kitchen	Steamer	Secured - SCSD Staff Only	MSAP-024	MSAP-S122	69.0	See Note 6	<1.0	None
Rm. 106E - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	MSAP-025	MSAP-S123	2.7	None	--	--
Rm. 110A - Office Bathroom	Sink	Secured - SCSD Staff Only	MSAP-008	MSAP-S106	19.0	See Note 6	<1.0	None
Rm. 114 - Classroom	Sink	Public Access	MSAP-007	MSAP-S105	11.0	None	--	--
Rm. 116 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	MSAP-002	MSAP-S100	13.0	None	--	--
Rm. 116E - Boiler/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	MSAP-001	MSAP-M100	8.2	None	--	--
Rm. 117A - Office Bathroom	Sink	Secured - SCSD Staff Only	MSAP-005	MSAP-S103	6.3	None	--	--
Rm. 117A - Boy's Bathroom	Sink	Public Access	MSAP-010	MSAP-S108	6.9	None	--	--
Rm. 117A - Boy's Bathroom	Sink	Public Access	MSAP-011	MSAP-S109	3.0	None	--	--
Rm. 117A - Boy's Bathroom	Sink	Public Access	MSAP-012	MSAP-S110	3.8	None	--	--
Rm. 117B - Girl's Bathroom	Sink	Public Access	MSAP-013	MSAP-S111	14.0	None	--	--
Rm. 117B - Girl's Bathroom	Sink	Public Access	MSAP-014	MSAP-S112	2.4	None	--	--
Rm. 117B - Girl's Bathroom	Sink	Public Access	MSAP-015	MSAP-S113	19.0	See Note 6	<1.0	None
Rm. 117B - Girl's Bathroom	Sink	Public Access	MSAP-016	MSAP-S114	24.0	See Note 6	<1.0	None
Rm. 118 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	MSAP-004	MSAP-S102	3.4	None	--	--
Rm. 118A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	MSAP-003	MSAP-S101	3.3	None	--	--
Rm. 120 - Girl's Locker Room	Fountain	Public Access	MSAP-054	MSAP-F101	6.7	None	--	--
Rm. 122 - Girl's Locker Room Bathroom	Sink	Public Access	MSAP-006	MSAP-S104	10.0	None	--	--
Rm. 127 - Boy's Locker Room	Fountain	Public Access	MSAP-055	MSAP-F102	120.0	See Note 7	--	--
Rm. 128 - Boy's Locker Room Bathroom	Sink	Public Access	MSAP-009	MSAP-S107	310.0	See Note 6	1.5	None
Rm. 130A - Hallway/Corridor	Fountain	Public Access	MSAP-056	MSAP-F103	1.4	None	--	--
Rm. 130J - Hallway/Corridor	Fountain	Public Access	MSAP-053	MSAP-F100	1.3	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
MSAP (SHEA) SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/21/16 RESAMPLE RESULTS (ppb)	10/21/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 211P - Storage Room	Sink	Secured - SCSD Staff Only	MSAP-040	MSAP-S138	4.3	None	--	--
Rm. 211Q - Main Office Bathroom	Sink	Secured - SCSD Staff Only	MSAP-041	MSAP-S139	1.7	None	--	--
Rm. 211R - Main Office	Sink	Secured - SCSD Staff Only	MSAP-042	MSAP-S140	< 1.0	None	--	--
Rm. 212 - Classroom	Sink	Public Access	MSAP-029	MSAP-S127	7.3	None	--	--
Rm. 212 - Classroom	Sink	Public Access	MSAP-030	MSAP-S128	17.0	See Note 6	<1.0	None
Rm. 212 - Classroom	Sink	Public Access	MSAP-031	MSAP-S129	12.0	None	--	--
Rm. 215 - Home & Careers Room	Sink	Public Access	MSAP-026	MSAP-S124	34.0	See Note 6	1	None
Rm. 215 - Home & Careers Room	Sink	Public Access	MSAP-027	MSAP-S125	13.0	None	--	--
Rm. 215 - Home & Careers Room	Sink	Public Access	MSAP-028	MSAP-S126	26.0	See Note 6	<1.0	None
Rm. 220 - Girl's Bathroom	Sink	Public Access	MSAP-036	MSAP-S134	9.1	None	--	--
Rm. 220 - Girl's Bathroom	Sink	Public Access	MSAP-037	MSAP-S135	4.6	None	--	--
Rm. 220 - Girl's Bathroom	Sink	Public Access	MSAP-038	MSAP-S136	13.0	None	--	--
Rm. 220 - Girl's Bathroom	Sink	Public Access	MSAP-039	MSAP-S137	2.9	None	--	--
Rm. 221 - Boy's Bathroom	Sink	Public Access	MSAP-032	MSAP-S130	3.4	None	--	--
Rm. 221 - Boy's Bathroom	Sink	Public Access	MSAP-033	MSAP-S131	3.5	None	--	--
Rm. 221 - Boy's Bathroom	Sink	Public Access	MSAP-034	MSAP-S132	9.6	None	--	--
Rm. 221 - Boy's Bathroom	Sink	Public Access	MSAP-035	MSAP-S133	16.0	See Note 6	<1.0	None
Rm. 225 - Hallway/Corridor	Fountain	Public Access	MSAP-057	MSAP-F104	< 1.0	None	--	--
Rm. 225H - Hallway/Corridor	Fountain	Public Access	MSAP-060	MSAP-F107	1.2	None	--	--
Rm. 225J - Hallway/Vestibule	Fountain	Public Access	MSAP-059	MSAP-F106	2.1	None	--	--
Rm. 225N - Hallway/Corridor	Fountain	Public Access	MSAP-058	MSAP-F105	< 1.0	None	--	--
Rm. 227 - Work Room	Sink	Secured - SCSD Staff Only	MSAP-048	MSAP-S146	3.5	None	--	--
Rm. 233 - Health Service Bathroom	Sink	Public Access	MSAP-046	MSAP-S144	3.8	None	--	--
Rm. 235 - Principal's Office	Sink	Secured - SCSD Staff Only	MSAP-043	MSAP-S141	5.7	None	--	--
Rm. 237 - Nurse's Office	Sink	Public Access	MSAP-047	MSAP-S145	4.6	None	--	--
Rm. 238 - Exam Room	Sink	Public Access	MSAP-045	MSAP-S143	6.1	None	--	--
Rm. 239 - Conference Room	Sink	Secured - SCSD Staff Only	MSAP-044	MSAP-S142	2.0	None	--	--
Rm. 239 - Girl's Bathroom	Sink	Public Access	MSAP-049	MSAP-S147	5.2	None	--	--
Rm. 239 - Girl's Bathroom	Sink	Public Access	MSAP-050	MSAP-S148	4.7	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
MSAP (SHEA) SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/21/16 RESAMPLE RESULTS (ppb)	10/21/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 240 - Boy's Bathroom	Sink	Public Access	MSAP-051	MSAP-S149	5.4	None	--	--
Rm. 245 - Clinic Office	Sink	Public Access	MSAP-052	MSAP-S150	3.0	None	--	--

Original Sampling Notes (October 21, 2016):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-013
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620837
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD is to remove and replace fixture.
7. SCSD is to remove fixture from service.

Resampling Notes (November 22, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1719315; November 28, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.