

**SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL**
SAMPLE DATE: 09/26/23 ANALYSIS DATE: 10/02/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/26/23 RESULTS (ppb)	09/26/23 ACTIONS
Rm. 001 - Cafeteria	Fountain	Public Access	048	VN-F100	<1.0	None
Rm. 001 - Cafeteria	Fountain	Public Access	049	VN-F101	<1.0	None
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	050	VN-S101	<1.0	None
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	051	VN-S102	<1.0	None
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	052	VN-S103	<1.0	None
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	053	VN-S104	1.6	None
Rm. 031 - Hallway/Corridor	Fountain	Public Access	042	VN-F102	<1.0	None
Rm. 031 - Hallway/Corridor	Fountain	Public Access	043	VN-F102A	<1.0	None
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	044	VN-S105	4.8	None
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	045	VN-S106	<1.0	None
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	046	VN-S107	<1.0	None
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	047	VN-S108	2.4	None
Rm. 005 - Classroom	Sink	Public Access	041	VN-S109	<1.0	None
Rm. 010A - Office	Sink	Secured - SCSD Staff Only	040	VN-S110	24.9	See Note 7.
Rm. 134 - Classroom	Sink	Public Access	018	VN-S111	1.9	None
Rm. 100M - Hallway/Corridor	Fountain	Public Access	016	VN-F103	<1.0	None
Rm. 132 - Classroom	Sink	Public Access	015	VN-S112	<1.0	None
Rm. 135 - Classroom	Sink	Public Access	019	VN-S113	<1.0	None
Rm. 133 - Classroom	Sink	Public Access	017	VN-S114	<1.0	None
Rm. 128 - Classroom	Sink	Public Access	021	VN-S115A	2.6	None
Rm. 129 - Classroom	Sink	Public Access	020	VN-S115B	<1.0	None
Rm. 123 - Classroom	Sink	Public Access	014	VN-S117	1.7	None
Rm. 123 - Classroom	Fountain	Public Access	013	VN-F104	<1.0	None
Rm. 120 - Classroom	Sink	Public Access	011	VN-S118	1.5	None
Rm. 120A - Classroom Bathroom	Sink	Public Access	012	VN-S119	6.4	See Note 7.
Rm. 109 - Nurse's Room	Sink	Public Access	024	VN-S120	7.3	See Note 8.

**SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL**
SAMPLE DATE: 09/26/23 ANALYSIS DATE: 10/02/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/26/23 RESULTS (ppb)	09/26/23 ACTIONS
Rm. 117 - Classroom	Sink	Public Access	010	VN-S122	<1.0	None
Rm. 109A - Exam Room	Sink	Public Access	028	VN-S123	12.5	See Note 7.
Rm. 119D - Work Room	Sink	Secured - SCSD Staff Only	023	VN-S126	20.3	See Note 8.
Rm. 115E - Lounge Kitchenette	Sink	Secured - SCSD Staff Only	022	VN-S127	<1.0	None
Rm. 0A8 - Hallway/Corridor	Fountain	Public Access	--	VN-F200	--	See Note 6.
Rm. 023 - Classroom	Sink	Public Access	033	VN-S201	<1.0	None
Rm. 023 - Classroom	Sink	Public Access	034	VN-S202	2.1	None
Rm. 023A - Classroom	Sink	Public Access	035	VN-S203	1.4	None
Rm. 023A - Classroom	Sink	Public Access	036	VN-S204	<1.0	None
Rm. 021 - Kitchen Room	Sink	Secured - SCSD Staff Only	037	VN-S205	<1.0	None
Rm. 020A - Classroom	Sink	Public Access	038	VN-S206	2.4	None
Rm. 020A - Classroom	Sink	Public Access	039	VN-S207	<1.0	None
Rm. 024 - Classroom	Sink	Public Access	029	VN-S208	<1.0	None
Rm. 024 - Classroom	Sink	Public Access	030	VN-S209	1.2	None
Rm. 022 - Classroom	Sink	Public Access	031	VN-S210	<1.0	None
Rm. 022 - Classroom	Sink	Public Access	032	VN-S211	<1.0	None
Rm. 100P - Hallway/Corridor	Fountain	Public Access	025	VN-F201	<1.0	None
Rm. 103 - Gym	Fountain	Public Access	027	VN-F202	<1.0	None
Rm. 103 - Gym	Fountain	Public Access	026	VN-F203	<1.0	None
Rm. 108 - Classroom	Sink	Public Access	008	VN-S219	<1.0	None
Rm. 110 - Classroom	Sink	Public Access	007	VN-S220	<1.0	None
Rm. 111 - Classroom	Sink	Public Access	006	VN-S221	<1.0	None
Rm. 113 - Office	Sink	Secured - SCSD Staff Only	009	VN-S222	1.0	None
Rm. 230 - Hallway/Corridor	Fountain	Public Access	001	VN-F301	<1.0	None
Rm. 207 - Teacher Resource	Sink	Secured - SCSD Staff Only	002	VN-S307	1.6	None
Rm. 231 - Hallway/Corridor	Fountain	Public Access	---	VN-F302	---	See Note 6.

**SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL**
SAMPLE DATE: 09/26/23 ANALYSIS DATE: 10/02/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/26/23 RESULTS (ppb)	09/26/23 ACTIONS
Rm. 227A - Laboratory	Sink	Public Access	005	VN-S315	1.4	None
Rm. 227A - Laboratory	Sink	Public Access	004	VN-S316	1.2	None
Rm. 0B8 - Kitchen	Convotherm Oven Sprayer	Secured - SCSD Staff Only	054	VN-C1000	<1.0	None
Rm. 227F - Work Room	Sink	Public Access	003	VN-S3000	61.1	See Note 7.

Notes: [September 26, 2023 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70272048.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture removed and replaced by SCSD. Resampling pending.
8. Fixture repaired by SCSD. Resampling pending.