

SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL
SAMPLE DATE: 06/21/23 ANALYSIS DATE: 06/22/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/21/23 RESULTS (ppb)	06/21/23 ACTIONS
Rm. 113 - Classroom	Sink	Public Access	039	BT-S408	145.0	See Note 8.
Rm. 111 - Classroom	Sink	Public Access	004	BT-S412	3.7	None
Rm. 116 - Music Classroom	Fountain	Public Access	007	BT-F401	4.5	None
Rm. 110 - F.A.C.S Classroom	Sink	Public Access	003	BT-S411	1.3	None
Rm. 119 - Classroom	Sink	Public Access	009	BT-S417	11.3	See Note 7.
Rm. 120 - Hallway/Corridor	Fountain	Public Access	012	BT-F403	6.2	See Note 7.
Rm. 120 - Hallway/Corridor	Fountain	Public Access	011	BT-F402	2.1	None
Rm. 202 - Social Worker Room	Sink	Public Access	030	BT-S324	<1.0	None
Rm. 204 - Health Center	Sink	Public Access	025	BT-S325	1.1	None
Rm. 204 - Health Center	Sink	Public Access	026	BT-S326	2.4	None
Rm. 204 - Health Center	Sink	Public Access	028	BT-S328	7.2	See Note 8.
Rm. 204 - Health Center	Sink	Public Access	027	BT-S329	2.3	None
Rm. 204 - Health Center	Sink	Public Access	029	BT-S330	19.0	See Note 8.
Rm. 206 - Nurse's Office	Sink	Public Access	022	BT-S331	<1.0	None
Rm. 206 - Nurse's Office	Sink	Public Access	023	BT-S332	2.0	None
Rm. 206 - Nurse's Office	Sink(Hose)	Public Access	024	BT-S332A	71.8	See Note 8.
Rm. 226 - Cafeteria	Fountain	Public Access	016	BT-F404	3.5	None
Kitchen	Sink (Faucet)	Secured - SCSD Staff Only	019	BT-S429	<1.0	None
Kitchen	Sink (Spray)	Secured - SCSD Staff Only	018	BT-S430	<1.0	None
Rm. 226A - Serving Room	Sink	Secured - SCSD Staff Only	017	BT-S428	<1.0	None
Kitchen	Convotherm	Secured - SCSD Staff Only	-----	BT-C1000	---	See Note 6.
Rm. 100A - Hallway/Corridor	Fountain	Public Access	001	BT-F1000	<1.0	None
Rm. 108 - OT/PT	Sink	Public Access	002	BT-S1003	<1.0	None
Rm. 100C - Hallway/Corridor	Fountain	Public Access	006	BT-F1001	<1.0	None
Rm. 100C - Hallway/Corridor	Fountain	Public Access	005	BT-F1002	<1.0	None
Rm. 116 - Music Classroom	Sink	Public Access	008	BT-S2001	5.5	See Note 8.
Passageway	Sink	Public Access	010	BT-S1009	6.3	See Note 8.
Rm. 221 - Hallway/Corridor	Fountain	Public Access	020	BT-F1003	<1.0	None
Rm. 221 - Hallway/Corridor	Fountain	Public Access	021	BT-F1004	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL
SAMPLE DATE: 06/21/23 ANALYSIS DATE: 06/22/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/21/23 RESULTS (ppb)	06/21/23 ACTIONS
Rm. 221 - Hallway/Corridor	Fountain	Public Access	015	BT-F1005	8.0	See Note 7.
Rm. 221 - Hallway/Corridor	Fountain	Public Access	013	BT-F1006	<1.0	None
Rm. 221 - Hallway/Corridor	Fountain	Public Access	014	BT-F1006A	<1.0	None
Rm. 318 - Hallway/Corridor	Fountain	Public Access	031	BT-F1007	<1.0	None
Rm. 318 - Hallway/Corridor	Fountain	Public Access	032	BT-F1008	<1.0	None
Rm. 318 - Hallway/Corridor	Fountain	Public Access	034	BT-F1009	<1.0	None
Rm. 318 - Hallway/Corridor	Fountain	Public Access	033	BT-F1010	<1.0	None
Rm. 423 - Hallway/Corridor	Fountain	Public Access	038	BT-F1011	<1.0	None
Rm. 423 - Hallway/Corridor	Fountain	Public Access	037	BT-F1012	<1.0	None
Rm. 423 - Hallway/Corridor	Fountain	Public Access	036	BT-F1013	<1.0	None
Rm. 423 - Hallway/Corridor	Fountain	Public Access	035	BT-F1014	<1.0	None
Gymnasium- Locker Room	Fountain	Public Access	-----	BT-F3001	---	See Note 6.

Notes [June 21, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70260686.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture repaired by SCSD. Resampling pending.
8. Fixture removed and replaced by SCSD. Resampling pending.