

**SYRACUSE CITY SCHOOL DISTRICT**  
**DR. KING ELEMENTARY SCHOOL**  
SAMPLE DATE: 10/06/23      ANALYSIS DATE: 10/12/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/06/23 RESULTS (ppb)	10/06/23 ACTIONS
Rm. A102 - Hallway/Corridor	Fountain	Public Access	082	DK-F301	<1.0	None
Rm. A102 - Hallway/Corridor	Fountain	Public Access	083	DK-F302	<1.0	None
Rm. A113 - Kitchenette	Sink	Secured - SCSD Staff Only	097	DK-S325	<1.0	None
Rm. A116 - Classroom	Sink	Public Access	069	DK-S313	3.5	None
Rm. A116 - Classroom	Fountain	Public Access	070	DK-F500	<1.0	None
Rm. A117 - Classroom	Sink	Public Access	072	DK-S311	<1.0	None
Rm. A117 - Classroom	Fountain	Public Access	073	DK-F306	<1.0	None
Rm. A118 - Classroom	Sink	Public Access	071	DK-S309	<1.0	None
Rm. A118 - Classroom	Fountain	Public Access	---	DK-F305	---	See Note 6.
Rm. A119 - Classroom	Sink	Public Access	086	DK-S307	<1.0	None
Rm. A119 - Classroom	Fountain	Public Access	---	DK-F304	---	See Note 6.
Rm. A120 - Classroom	Sink	Public Access	085	DK-S305	<1.0	None
Rm. A120 - Classroom	Fountain	Public Access	030	DK-F303	<1.0	None
Rm. A129 - Classroom	Sink	Public Access	080	DK-S323	<1.0	None
Rm. A129 - Classroom	Fountain	Public Access	081	DK-F311	<1.0	None
Rm. A130 - Classroom	Sink	Public Access	078	DK-S321	<1.0	None
Rm. A130 - Classroom	Fountain	Public Access	079	DK-F310	<1.0	None
Rm. A131 - Classroom	Sink	Public Access	077	DK-S319	<1.0	None
Rm. A131 - Classroom	Fountain	Public Access	---	DK-F309	---	See Note 6.
Rm. A132 - Classroom	Sink	Public Access	075	DK-S317	<1.0	None
Rm. A133 - Classroom	Sink	Public Access	074	DK-S315	<1.0	None
Rm. A133 - Classroom	Fountain	Public Access	---	DK-F308	---	See Note 7.
Rm. B102 - Hallway/Corridor	Fountain	Public Access	087	DK-F312	<1.0	None
Rm. B102 - Hallway/Corridor	Fountain	Public Access	088	DK-F313	<1.0	None
Rm. B115 - Resource & Staff Development	Sink	Secured - SCSD Staff Only	065	DK-S125	<1.0	None
Rm. B116 - Science Office	Sink	Public Access	089	DK-S330	30.0	See Note 8.
Rm. B122 - Media Work Room	Sink	Public Access	066	DK-S128	1.3	None
Rm. B129 - Classroom	Fountain	Public Access	064	DK-F203	1.5	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**DR. KING ELEMENTARY SCHOOL**  
SAMPLE DATE: 10/06/23      ANALYSIS DATE: 10/12/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/06/23 RESULTS (ppb)	10/06/23 ACTIONS
Rm. B130 - Classroom	Sink	Public Access	063	DK-S223	<1.0	None
Rm. B133 - Music Room	Sink	Public Access	060	DK-S222	1.2	None
Rm. B134 - Classroom	Sink	Public Access	062	DK-S119	<1.0	None
Rm. B134 - Classroom	Fountain	Public Access	061	DK-F107	9.8	See Note 10.
Rm. B136 - Classroom	Sink	Public Access	059	DK-S117A	<1.0	None
Rm. C106 - Hallway/Corridor	Fountain	Public Access	051	DK-F100	<1.0	None
Rm. C106 - Hallway/Corridor	Fountain	Public Access	052	DK-F101	<1.0	None
Rm. C108 - Hallway/Corridor	Sink	Public Access	046	DK-S214	3.8	None
Rm. C108 - Hallway/Corridor	Sink	Public Access	047	DK-S216	<1.0	None
Rm. C112 - Café	Fountain	Public Access	041	DK-F201	<1.0	None
Rm. C112 - Café	Fountain	Public Access	042	DK-F202	<1.0	None
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	036	DK-S205	<1.0	None
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	038	DK-S206	<1.0	None
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	039	DK-S207	<1.0	None
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	040	DK-S208	<1.0	None
Rm. C117 - Kitchen	Comborthern	Secured - SCSD Staff Only	037	DK-C1001	<1.0	None
Rm. C133 - Nurse's Room	Sink	Public Access	049	DK-S219	<1.0	None
Rm. C136 - Clean Room	Sink	Secured - SCSD Staff Only	048	DK-S217	<1.0	None
Rm. C138 - Sick Room	Sink	Public Access	050	DK-S220	<1.0	None
Rm. C140 - Exam Room	Sink	Public Access	045	DK-S218	<1.0	None
Rm.s C141 - Exam Room	Sink	Public Access	044	DK-S213	1.7	None
Rm. C142 - Dental Room	Sink	Public Access	043	DK-S212	<1.0	None
Rm. D101 - Hallway/Corridor	Fountain	Public Access	056	DK-F102	<1.0	None
Rm. D101 - Hallway/Corridor	Fountain	Public Access	057	DK-F103	<1.0	None
Rm. D108A - Hallway/Corridor	Fountain	Public Access	053	DK-F104	<1.0	None
Rm. D108A - Hallway/Corridor	Fountain	Public Access	054	DK-F105	<1.0	None
Rm. D127 - Classroom	Sink	Public Access	084	DK-S113	<1.0	None
Rm. D128 - Classroom	Sink	Public Access	055	DK-S111	<1.0	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**DR. KING ELEMENTARY SCHOOL**  
SAMPLE DATE: 10/06/23      ANALYSIS DATE: 10/12/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/06/23 RESULTS (ppb)	10/06/23 ACTIONS
Rm. A202 - Hallway/Corridor	Fountain	Public Access	024	DK-F314	<1.0	None
Rm. A202 - Hallway/Corridor	Fountain	Public Access	025	DK-F315	<1.0	None
Rm. A213 - Kitchenette	Sink	Public Access	---	DK-S353	---	See Note 9.
Rm. A217 - Classroom	Sink	Public Access	035	DK-S342	<1.0	None
Rm. A221 - Classroom	Fountain	Public Access	027	DK-F334	<1.0	None
Rm. A217 - Classroom	Fountain	Public Access	034	DK-F320	1.6	None
Rm. A218 - Classroom	Sink	Public Access	033	DK-S340	<1.0	None
Rm. A218 - Classroom	Fountain	Public Access	032	DK-F319	1.6	None
Rm. A219 - Classroom	Sink	Public Access	031	DK-S338	<1.0	None
Rm. A219 - Classroom	Fountain	Public Access	096	DK-F318	<1.0	None
Rm. A220 - Classroom	Sink	Public Access	029	DK-S337	<1.0	None
Rm. A220 - Classroom	Fountain	Public Access	028	DK-F317	<1.0	None
Rm. A221 - Classroom	Sink	Public Access	026	DK-S335	<1.0	None
Rm. A233 - Classroom	Sink	Public Access	090	DK-S351	<1.0	None
Rm. A233 - Classroom	Fountain	Public Access	091	DK-F325	<1.0	None
Rm. A234 - Classroom	Sink	Public Access	092	DK-S350	<1.0	None
Rm. A234 - Classroom	Fountain	Public Access	093	DK-F324	<1.0	None
Rm. A235 - Classroom	Sink	Public Access	094	DK-S348	<1.0	None
Rm. A235 - Classroom	Fountain	Public Access	095	DK-F323	<1.0	None
Rm. A236 - Classroom	Fountain	Public Access	067	DK-F322	<1.0	None
Rm. A237 - Classroom	Fountain	Public Access	068	DK-F321	<1.0	None
Rm. B202 - Hallway/Corridor	Fountain	Public Access	023	DK-F205	<1.0	None
Rm. B202 - Hallway/Corridor	Fountain	Public Access	022	DK-F206	<1.0	None
Rm. B217 - Classroom	Sink	Public Access	021	DK-S233	<1.0	None
Rm. B217 - Classroom	Fountain	Public Access	020	DK-F204	<1.0	None
Rm. B218 - Classroom	Sink	Public Access	019	DK-S230	<1.0	None
Rm. B222 - Commons Kitchenette	Sink	Secured - SCSD Staff Only	018	DK-S231	<1.0	None
Rm. B223 - Classroom	Sink	Public Access	016	DK-S228	<1.0	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**DR. KING ELEMENTARY SCHOOL**  
SAMPLE DATE: 10/06/23      ANALYSIS DATE: 10/12/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/06/23 RESULTS (ppb)	10/06/23 ACTIONS
Rm. B224 - Classroom	Sink	Public Access	017	DK-S229	<1.0	None
Rm. B225 - Classroom	Sink	Public Access	015	DK-S227	<1.0	None
Rm. C202 - Hallway/Corridor	Fountain	Public Access	002	DK-F108	<1.0	None
Rm. C202 - Hallway/Corridor	Fountain	Public Access	001	DK-F109	<1.0	None
Rm. C216 - Kitchenette	Sink	Secured - SCSD Staff Only	003	DK-S130	<1.0	None
Rm. C216 - Kitchenette	Sink	Secured - SCSD Staff Only	004	DK-S130A	<1.0	None
Rm. C218 - Classroom	Sink	Public Access	006	DK-S129	<1.0	None
Rm. C219 - Classroom	Sink	Public Access	005	DK-S131	<1.0	None
Rm. C220 - Classroom	Sink	Public Access	007	DK-S132	<1.0	None
Rm. C221 - Classroom	Sink	Public Access	008	DK-S133	<1.0	None
Rm. C221 - Classroom	Fountain	Public Access	009	DK-F110	<1.0	None
Rm. C225 - Classroom	Sink	Public Access	011	DK-S136	<1.0	None
Rm. C225 - Classroom	Fountain	Public Access	010	DK-F111	<1.0	None
Rm. C226 - Classroom	Sink	Public Access	012	DK-S137	<1.0	None
Rm. C227 - Classroom	Sink	Public Access	013	DK-S138	<1.0	None
Rm. C228 - Classroom	Sink	Public Access	014	DK-S139	<1.0	None
Rm. A132 - Classroom	Fountain	Public Access	076	DK-F2000	5.0	None
Rm. B136 - Classroom	Fountain	Public Access	058	DK-F1000	<1.0	None

Notes [October 6, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-017
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. (70273326)
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture inaccessible.
8. Fixture removed and replaced by SCSD. Resampling pending.
9. Fixture not sampled.
10. Fixture repaired by SCSD. Resample pending.