

SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL
SAMPLE DATE: 07/21/2023 ANALYSIS DATE: 07/26/2023

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/21/23 RESULTS (ppb)	07/21/23 ACTIONS
Rm. A100 - Hallway/Vestibule	Fountain	Public Access	012	FN-F207	<1.0	None
Rm. A100 - Hallway/Vestibule	Fountain	Public Access	013	FN-F207A	<1.0	None
Rm. 201 - Nurse Office	Fountain	Public Access	014	FN-S208	<1.0	None
Rm. 100 - Classroom	Sink	Public Access	037	FN-S203	2.5	None
Rm. 100 - Classroom	Fountain	Public Access	036	FN-F204	<1.0	None
Rm. 102 - Classroom	Fountain	Public Access	038	FN-F205	14.7	See Note 7.
Rm. 103 - Classroom	Sink	Public Access	046	FN-S205	2.2	None
Rm. 103 - Classroom	Fountain	Public Access	045	FN-F206	2.4	None
Rm. 104 - Classroom	Sink	Public Access	048	FN-S110	1.4	None
Rm. 104 - Classroom	Fountain	Public Access	047	FN-F107	5.7	See Note 7.
Rm. 106 - Classroom	Sink	Public Access	050	FN-S109	1.6	None
Rm. 106 - Classroom	Fountain	Public Access	049	FN-F106	4.8	None
Rm. 112 - Classroom	Sink	Public Access	051	FN-S107	1.4	None
Rm. 112 - Classroom	Fountain	Public Access	052	FN-F105	132	See Note 7.
Rm. 113 - Classroom	Fountain	Public Access	053	FN-F104	3.7	None
Rm. 114 - Classroom	Sink	Public Access	055	FN-S105	2	None
Rm. 114 - Classroom	Fountain	Public Access	056	FN-F103	6.7	See Note 7.
Rm. 116 - Classroom	Fountain	Public Access	057	FN-F102	4.5	None
Rm. 117 - Classroom	Fountain	Public Access	059	FN-F101	3.7	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	058	FN-S100	<1.0	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	060	FN-S101	<1.0	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	061	FN-S102	<1.0	None
Rm. 119 - Hallway/Vestibule	Fountain	Public Access	054	FN-F100	1.2	None
Rm. 201 - Nurse Office	Sink	Public Access	015	FN-S209	5.8	See Note 8.
Rm. 123 - Classroom	Fountain	Public Access	062	FN-F200	<1.0	None
Rm. 202 - Health Center	Sink	Public Access	019	FN-S212A	8.8	See Note 9.
Rm. 124 - Classroom	Fountain	Public Access	063	FN-F201	<1.0	None
Rm. 208 - Teacher's Lounge	Sink	Public Access	022	FN-S130	2.4	None
Rm. 125 - Classroom	Fountain	Public Access	034	FN-F203	<1.0	None
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	044	FN-S112	1.5	None
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	040	FN-S113	2.8	None

SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL
SAMPLE DATE: 07/21/2023 ANALYSIS DATE: 07/26/2023

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/21/23 RESULTS (ppb)	07/21/23 ACTIONS
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	039	FN-S114	2.2	None
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	041	FN-S115	1	None
Rm. 146C - Cafeteria Passage	Fountain	Public Access	043	FN-F202	<1.0	None
Rm. 125 - Classroom	Sink	Public Access	035	FN-S202	3	None
Rm. 202 - Clinic Room	Sink	Public Access	017	FN-S211	2.4	None
Rm. 202 - Clinic Room	Sink	Public Access	018	FN-S212	2.4	None
Rm. 202 - Clinic/Examination Room	Sink	Public Access	020	FN-S213	2.2	None
Rm. 202 - Clinic Room	Sink	Public Access	021	FN-S215	1.5	None
Rm. 204 - Clinic Room	Sink	Public Access	016	FN-S210	1.7	None
Rm. 124 - Classroom	Sink	Public Access	064	FN-S201	2.3	None
Rm. 210 - Classroom	Sink	Public Access	032	FN-FA	<1.0	None
Rm. 212D - Hallway/Vestibule	Sink	Public Access	023	FN-S122	<1.0	None
Rm. 212D - Hallway/Vestibule	Sink	Public Access	024	FN-S123	3.8	None
Rm. 212D - Hallway/Vestibule	Sink	Public Access	026	FN-S124	<1.0	None
Rm. 212D - Hallway/Vestibule	Fountain	Public Access	025	FN-F108	<1.0	None
Rm. 215 - Computer Room	Sink	Public Access	027	FN-S126	2.0	None
Rm. 215 - Computer Room	Fountain	Public Access	028	FN-F110	1.5	None
Rm. 216 - Computer Room	Sink	Public Access	029	FN-S125	1.6	None
Rm. 216 - Computer Room	Fountain	Public Access	030	FN-F109	1.1	None
Rm. 220A - Classroom Bathroom	Sink	Public Access	---	FN-S121	---	See Note 6.
Rm. 228B - Office Kitchenette	Sink	Secured - SCSD Staff Only	031	FN-S118	<1.0	None
Rm. 234 - Hallway/Corridor	Fountain	Public Access	033	FN-F111	<1.0	None
Rm. 307 - Hallway/Vestibule	Sink	Public Access	008	FN-S139	1.2	None
Rm. 307 - Hallway/Vestibule	Sink	Public Access	006	FN-S140	<1.0	None
Rm. 307 - Hallway/Vestibule	Sink	Public Access	005	FN-S141	<1.0	None
Rm. 307 - Hallway/Vestibule	Fountain	Public Access	007	FN-F114	<1.0	None
Rm. 309 - Classroom	Fountain	Public Access	009	FN-F113	1.0	None
Rm. 310 - Classroom	Sink	Public Access	010	FN-S137	2.8	None
Rm. 310 - Classroom	Fountain	Public Access	011	FN-F112	1.3	None
Rm. 319 - Hallway/Vestibule	Sink	Public Access	001	FN-S219	2.4	None

SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL
SAMPLE DATE: 07/21/2023 ANALYSIS DATE: 07/26/2023

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/21/23 RESULTS (ppb)	07/21 /23 ACTIONS
Rm. 319 - Hallway/Vestibule	Sink	Public Access	002	FN-S220	<1.0	None
Rm. 319 - Hallway/Vestibule	Sink	Public Access	004	FN-S221	3.0	None
Rm. 319 - Hallway/Vestibule	Fountain	Public Access	003	FN-F208	1.3	None
Rm. 131 - Kitchen	iCombi Pro Oven Sprayer	Secured - SCSD Staff Only	042	FN-S4000	3.3	None

Notes [July 21, 2023 Event]:

- 1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-007
- 2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70264172
- 3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
- 4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
- 5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
- 6. Fixture inoperative. SCSD to evaluate for repair or removal.
- 7. Fixture repaired by SCSD. Resampling pending.
- 8. Fixture removed and replaced by SCSD. Resampling pending.
- 9. Fixture signed by SCSD.