

**SYRACUSE CITY SCHOOL DISTRICT**  
**FRAZER PK-GRADE 8 SCHOOL**  
SAMPLE DATE: 07/26/2023   ANALYSIS DATE: 08/01/2023

ROOM No. & LOCATION	FIXTURE (Sink/ Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07 /26/23 RESULTS (ppb)	07/26/23 ACTIONS
Rm. 000 - Hallway/Vestibule	Fountain	Public Access	014	FR-F104	<1.0	None
Rm. 000 - Hallway/Vestibule	Fountain	Public Access	013	FR-F105	<1.0	None
Rm. 000A - Hallway Corridor	Fountain	Public Access	010	FR-F100	<1.0	None
Rm. 000A - Hallway Corridor	Fountain	Public Access	009	FR-F101	<1.0	None
Rm. 05B - Technology Room	Sink	Public Access	012	FR-S110	4.0	None
Rm. 100B - Hallway/Corridor	Fountain	Public Access	015	FR-F115	<1.0	None
Rm. 008A - Cafeteria	Fountain	Public Access	008	FR-F102	<1.0	None
Rm. 008A - Cafeteria	Fountain	Public Access	007	FR-F103	<1.0	None
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	001	FR-S102	4.2	None
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	002	FR-S103	4.4	None
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	003	FR-S104	1.7	None
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	004	FR-S105	2.3	None
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	005	FR-S106	1.4	None
Rm. 009 - Technology Room	Sink	Public Access	011	FR-S109	10.2	See Note 8.
Rm. 100B - Hallway/Corridor	Fountain	Public Access	022	FR-F113	<1.0	None
Rm. 100H - Hallway/Corridor	Fountain	Public Access	025	FR-F111	<1.0	None
Rm. 100M - Hallway/Corridor	Fountain (Sensor)	Public Access	---	FR-F111A	---	See Note 6.
Rm. 101 - Classroom	Sink	Public Access	042	FR-S130	<1.0	None
Rm. 101 - Classroom	Fountain	Public Access	043	FR-F109	6.5	See Note 8.
Rm. 100B - Hallway/Corridor	Fountain	Public Access	016	FR-F114	<1.0	None
Rm. 102B - Exam Room	Sink	Public Access	041	FR-S128	4.8	None
Rm. 111 - Vestibule	Sink	Public Access	017	FR-S143	<1.0	None
Rm. 106 - Classroom	Sink	Public Access	040	FR-S125	<1.0	None
Rm. 106 - Classroom	Fountain	Public Access	039	FR-F108	2.2	None
Rm. 111 - Vestibule	Sink	Public Access	018	FR-S142	<1.0	None
Rm. 107 - Classroom	Sink	Public Access	038	FR-S123	<1.0	None
Rm. 107 - Classroom	Fountain	Public Access	037	FR-F107	2	None
Rm. 111 - Vestibule	Sink	Public Access	018	FR-S141	<1.0	None
Rm. 117C - Work Room	Sink	Secured - SCSD Staff Only	021	FR-S146	<1.0	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**FRAZER PK-GRADE 8 SCHOOL**  
SAMPLE DATE: 07/26/2023   ANALYSIS DATE: 08/01/2023

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07 /26/23 RESULTS (ppb)	07/26/23 ACTIONS
Rm. 118 - Work Room	Sink	Secured - SCSD Staff Only	020	FR-S145	<1.0	None
Rm. 130 - Classroom	Sink	Public Access	023	FR-S139	3.9	None
Rm. 142 - Classroom	Fountain	Public Access	026	FR-F110	<1.0	None
Rm. L-10 - Hallway/Corridor	Fountain	Public Access	024	FR-F112	<1.0	None
Rm. 200 - Computer Lab	Lab	Public Access	---	FR-S158	---	See Note 6
Rm. 200A - Hallway/Corridor	Fountain	Public Access	029	FR-F120	<1.0	None
Rm. 200A - Hallway/Corridor	Fountain	Public Access	030	FR-F121	<1.0	None
Dark Room	Sink	Public Access	---	FR-S157	---	See Note 7.
Rm. 200A - Hallway/Corridor	Fountain	Public Access	032	FR-F119	<1.0	None
Rm. 200D - Hallway/Corridor	Fountain	Public Access	033	FR-F118	<1.0	None
Rm. 200H - Hallway/Corridor	Fountain	Public Access	034	FR-F116	<1.0	None
Rm. 200H - Hallway/Corridor	Fountain	Public Access	035	FR-F117	1.1	None
Rm. 211 - Work Room	Sink	Secured - SCSD Staff Only	027	FR-S154	<1.0	None
Rm. 217 - Home & Careers Room	Sink	Public Access	028	FR-S148	5.5	See Note 8.
Rm. 008E - Kitchen	Oven Sprayer	Secured - SCSD Staff Only	006	FR-C1000	1.1	None
Rm. 2T2 - Hallway/Vestibule	Sink	Public Access	036	FR-S1013	<1.0	None
Rm. 2T1 - Hallway/Vestibule	Sink	Public Access	031	FR-S1017	<1.0	None

Notes [July 26,2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-012.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70264673.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture not accessible.
8. Fixture removed and replaced by SCSD.