

**SYRACUSE CITY SCHOOL DISTRICT**  
**HW SMITH PK - GRADE 8 SCHOOL**  
SAMPLE DATE: 08/04/23      ANALYSIS DATE: 08/09/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/04/23 RESULTS (ppb)	08/04/23 ACTIONS
Rm. A-A - Classroom	Sink	Public Access	007	HW-S308	1.1	None
Rm. A-A - Classroom	Sink	Public Access	008	HW-S309	1.7	None
Rm. A-01 - ESL Room	Sink	Public Access	006	HW-S307	<1.0	None
Rm. A-02 - Classroom	Sink	Public Access	009	HW-S312	2.3	None
Rm. A-02 - Classroom	Sink	Public Access	010	HW-S313	7.8	See Note 7.
Rm. A-03 - Classroom	Sink	Public Access	011	HW-S315	<1.0	None
Rm A-01 - ESL Room	Sink	Public Access	---	HW-S306	---	See Note 6.
Rm A-03 - Classroom	Fountain	Public Access	---	HW-F302	---	See Note 6.
Rm. A-04 - Classroom	Sink	Public Access	013	HW-S316	<1.0	None
Rm. A-04 - Classroom	Fountain	Public Access	012	HW-F303	6.9	See Note 7.
Rm. A-05 - Classroom	Sink	Public Access	016	HW-S319	1.5	None
Rm. A-05 - Classroom	Fountain	Public Access	017	HW-F305	4.4	None
Rm. A-06 - Classroom	Sink	Public Access	019	HW-S322	<1.0	None
Rm. A-06 - Classroom	Fountain	Public Access	018	HW-F306	12.6	See Note 7.
Rm. A-07 - Classroom	Sink	Public Access	020	HW-S324	<1.0	None
Rm. A-07 - Classroom	Fountain	Public Access	021	HW-F307	2.5	None
Rm. A-12 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	015	HW-S320	<1.0	None
Rm. A-22D - Storage Room	Sink	Secured - SCSD Staff Only	002	HW-S303	8.0	See Note 8.
Rm. A-30A - Hallway/Corridor	Fountain	Public Access	014	HW-F304	<1.0	None
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	004	HW-S301	<1.0	None
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	003	HW-S302	<1.0	None
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	005	HW-S305	<1.0	None
Rm. A-30H - Hallway/Corridor	Fountain	Public Access	001	HW-F301	<1.0	None
Rm. A-33 - Classroom	Sink	Public Access	022	HW-S104	<1.0	None
Rm. A-33 - Classroom	Fountain	Public Access	023	HW-F101	1.0	None
Rm. A-35 - Classroom	Sink	Public Access	024	HW-S102	<1.0	None
Rm. A-35 - Classroom	Fountain	Public Access	025	HW-F100	<1.0	None
Rm. A100J - Hallway/Corridor	Fountain	Public Access	052	HW-F308	<1.0	None
Rm. A100K	Fountain	Public Access	---	HW-F102	---	See Note 6.

**SYRACUSE CITY SCHOOL DISTRICT**  
**HW SMITH PK - GRADE 8 SCHOOL**  
SAMPLE DATE: 08/04/23      ANALYSIS DATE: 08/09/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/04/23 RESULTS (ppb)	08/04/23 ACTIONS
Rm. A100K	Fountain	Public Access	---	HW-F103	---	See Note 6.
Rm. A104 - Office	Sink	Secured - SCSD Staff Only	028	HW-S110	<1.0	None
Rm. A106 - Copy Room	Sink	Secured - SCSD Staff Only	061	HW-S112	<1.0	None
Rm. A108C - Home & Careers Room	Sink	Public Access	057	HW-S337	<1.0	None
Rm. A108C - Home & Careers Room	Sink	Public Access	058	HW-S338	<1.0	None
Rm. A108C - Home & Careers Room	Sink	Public Access	059	HW-S339	1.5	None
Rm. A108C - Home & Careers Room	Sink	Public Access	060	HW-S340	<1.0	None
Rm. A112 - Classroom	Sink	Public Access	056	HW-S342	<1.0	None
Rm. A122 - Classroom	Sink	Public Access	055	HW-S343	1.2	None
Rm. A123 - Classroom	Sink	Public Access	054	HW-S344	<1.0	None
Rm. A125 - Classroom	Sink	Public Access	053	HW-S345	<1.0	None
Rm. A200B - Hallway/Corridor	Fountain	Public Access	040	HW-F311	<1.0	None
Rm. A200B - Hallway/Corridor	Fountain	Public Access	041	HW-F312	<1.0	None
Rm. A205A - Hallway/Corridor	Fountain	Public Access	038	HW-F310	<1.0	None
Rm. A208A - Copy Room	Sink	Secured - SCSD Staff Only	039	HW-S363	<1.0	None
Rm. B109 - Boy's Locker Room	Fountain	Public Access	029	HW-F105	<1.0	None
Rm. B126 - Girl's Locker Room	Fountain	Public Access	030	HW-F106	<1.0	None
Rm. B128 - OT/PT Room	Sink	Public Access	031	HW-S121	<1.0	None
Rm. B132 - Dental Room	Sink	Public Access	062	HW-S346	<1.0	None
Rm. B134 - Hallway/Corridor	Fountain	Public Access	026	HW-F104	<1.0	None
Rm. B134 - Hallway/Corridor	Fountain (Sensor)	Public Access	027	HW-F104A	<1.0	None
Rm. B135B - Exam Room	Sink	Public Access	063	HW-S353	3.3	None
Rm. B136 - Health Center	Sink	Public Access	064	HW-S348	1.5	None
Rm. B138 - Nurse's Room	Sink	Public Access	036	HW-S352	2.6	None
Rm. B149 - Main Office	Sink	Secured - SCSD Staff Only	035	HW-S357	7.5	See Note 7.
Rm. B168 - Conference Room	Sink	Secured - SCSD Staff Only	033	HW-S355	<1.0	None
Rm. B172 - Work Room	Sink	Secured - SCSD Staff Only	032	HW-S125	<1.0	None
Rm. B204 - Hallway/Corridor	Fountain	Public Access	042	HW-F108	<1.0	None
Rm. B209 - Hallway/Corridor	Fountain	Public Access	051	HW-F107	<1.0	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**HW SMITH PK - GRADE 8 SCHOOL**  
SAMPLE DATE: 08/04/23      ANALYSIS DATE: 08/09/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/04/23 RESULTS (ppb)	08/04/23 ACTIONS
Rm. B222 - Kitchen	Sink (Pedal Operated)	Secured - SCSD Staff Only	046	HW-S370	1.5	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	043	HW-S371	4.2	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	044	HW-S372	3.4	None
Rm. B222 - Kitchen	Sink (Hose)	Secured - SCSD Staff Only	045	HW-S373	2.1	None
Rm. B222 - Kitchen	Sink (Hose)	Secured - SCSD Staff Only	048	HW-S374	<1.0	None
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	047	HW-S375	<1.0	None
Rm. B222B - Kitchen Serving Area	Sink (Pedal Operated)	Secured - SCSD Staff Only	049	HW-S377	3.2	None
Rm. B222 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	050	HW-C1000	2.6	None
Rm. B139 - Office	Sink	Public Access	037	HW-S1000	2.1	None
Rm. B104 - Hallway/Corridor	Fountain	Public Access	034	HW-F3004	<1.0	None

Notes [August 4, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-018.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No.70265784.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture removed and replaced by SCSD. Resampling pending.
8. Fixture signed by SCSD.