

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL
SAMPLE DATE: 09/29/23 ANALYSIS DATE: 10/03/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ACTIONS
Rm. 100D - Office Kitchenette	Sink	Secured - SCSD Staff Only	050	MB-S231	<1.0	None
Rm. 105 - Nurse's Office	Sink	Public Access	052	MB-S225	<1.0	None
Rm. 105A - Exam Room	Sink	Public Access	053	MB-S226	1.0	None
Rm. 105B - Nurse's Office Changing Room	Sink	Public Access	051	MB-S228	3.9	None
Rm. 107 - Classroom	Sink	Public Access	042	MB-S211	<1.0	None
Rm. 107 - Classroom	Sink	Public Access	041	MB-S212	<1.0	None
Rm. 107 - Classroom	Fountain	Public Access	043	MB-F203	<1.0	None
Rm. 111 - Classroom	Sink	Public Access	039	MB-S210	<1.0	None
Rm. 111 - Classroom	Sink	Public Access	040	MB-S209	<1.0	None
Rm. 111 - Classroom	Fountain	Public Access	038	MB-F202	<1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	033	MB-S204	<1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	032	MB-S205	<1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	034	MB-S206	<1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	030	MB-S207	<1.0	None
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	031	MB-S208	<1.0	None
Rm. 113 - Classroom	Sink	Public Access	035	MB-S201	<1.0	None
Rm. 113 - Classroom	Sink	Public Access	036	MB-S202	<1.0	None
Rm. 113 - Classroom	Fountain	Public Access	037	MB-F201	<1.0	None
Rm. 119 - Community Room	Sink	Public Access	049	MB-S218	<1.0	None
Rm. 126 - Classroom	Sink	Public Access	086	MB-S131	1.4	None
Rm. 126 - Classroom	Sink	Public Access	087	MB-S132	<1.0	None
Rm. 126 - Classroom	Fountain	Public Access	---	MB-F114	---	See Note 6.
Rm. 127 - Classroom	Sink	Public Access	084	MB-S129	2.8	None
Rm. 127 - Classroom	Sink	Public Access	085	MB-S130	<1.0	None
Rm. 127 - Classroom	Fountain	Public Access	083	MB-F113	<1.0	None
Rm. 128 - Classroom	Sink	Public Access	081	MB-S125	2.1	None
Rm. 128 - Classroom	Sink	Public Access	082	MB-S126	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL
SAMPLE DATE: 09/29/23 ANALYSIS DATE: 10/03/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ACTIONS
Rm. 128 - Classroom	Fountain	Public Access	---	MB-F112	---	See Note 6.
Rm. 130 - Classroom	Sink	Public Access	079	MB-S123	1.6	None
Rm. 130 - Classroom	Sink	Public Access	080	MB-S124	<1.0	None
Rm. 130 - Classroom	Fountain	Public Access	095	MB-F111	<1.0	None
Rm. 131 - Classroom	Sink	Public Access	078	MB-S122	3.6	None
Rm. 131 - Classroom	Fountain	Public Access	--	MB-F110	---	See Note 6.
Rm. 132 - Art Room	Sink	Public Access	076	MB-S119	3.0	None
Rm. 132 - Art Room	Sink	Public Access	077	MB-S120	<1.0	None
Rm. 137 - Classroom	Sink	Public Access	074	MB-S117	1	None
Rm. 137 - Classroom	Sink	Public Access	075	MB-S118	<1.0	None
Rm. 137 - Classroom	Fountain	Public Access	---	MB-F109	---	See Note 6.
Rm. 138 - Classroom	Fountain	Public Access	058	MB-F100	<1.0	None
Rm. 138 - Classroom	Sink	Public Access	057	MB-S101	<1.0	None
Rm. 139 - Classroom	Sink	Public Access	055	MB-S103	<1.0	None
Rm. 139 - Classroom	Fountain	Public Access	054	MB-F101	<1.0	None
Rm. 139T - Classroom	Sink	Public Access	056	MB-S102	<1.0	None
Rm. 140 - Classroom	Sink	Public Access	061	MB-S105	<1.0	None
Rm. 140 - Classroom	Fountain	Public Access	059	MB-F102	<1.0	None
Rm. 140T - Classroom	Sink	Public Access	060	MB-S104	<1.0	None
Rm. 141 - Classroom	Sink	Public Access	062	MB-S106	<1.0	None
Rm. 141 - Classroom	Sink	Public Access	063	MB-S107	3.6	None
Rm. 141 - Classroom	Fountain	Public Access	---	MB-F103	---	See Note 6.
Rm. 142 - Classroom	Sink	Public Access	068	MB-S110	<1.0	None
Rm. 142 - Classroom	Sink	Public Access	069	MB-S111	1.2	None
Rm. 142 - Classroom	Fountain	Public Access	---	MB-F106	---	See Note 6.
Rm. 146 - Classroom	Sink	Public Access	071	MB-S112	2.6	None
Rm. 146 - Classroom	Fountain	Public Access	070	MB-F107	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL
SAMPLE DATE: 09/29/23 ANALYSIS DATE: 10/03/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ACTIONS
Rm. 146 - Classroom	Sink	Public Access	072	MB-S113	<1.0	None
Rm. 150 - Classroom	Sink	Public Access	073	MB-S115	<1.0	None
Rm. 150 - Classroom	Fountain	Public Access	---	MB-F108	---	See Note 6.
Rm. 151A - Work Office	Sink	Secured - SCSD Staff Only	088	MB-S127	3.8	None
Rm. 166 - Hallway/Vestibule	Sink	Public Access	064	MB-S108	81.2	See Note 7.
Rm. 166 - Hallway/Vestibule	Sink	Public Access	065	MB-S109	62.5	See Note 7.
Rm. 166 - Hallway/Vestibule	Fountain	Public Access	066	MB-F104	<1.0	None
Rm. 166 - Hallway/Vestibule	Fountain	Public Access	067	MB-F105	<1.0	None
Rm. 178 - Hallway/Vestibule	Sink	Public Access	044	MB-S214	<1.0	None
Rm. 178 - Hallway/Vestibule	Sink	Public Access	045	MB-S215	<1.0	None
Rm. 178 - Hallway/Vestibule	Sink	Public Access	047	MB-S216	<1.0	None
Rm. 178 - Hallway/Vestibule	Sink	Public Access	048	MB-S217	<1.0	None
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	046	MB-F204	<1.0	None
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	---	MB-F205	---	See Note 6.
Rm. 200 - Science Room	Sink	Public Access	009	MB-S324	1.1	None
Rm. 202 - Science Room	Sink	Public Access	008	MB-S325	<1.0	None
Rm. 203 - Faculty Lounge	Sink	Secured - SCSD Staff Only	006	MB-S326	<1.0	None
Rm. 204 - Science Room	Sink	Public Access	005	MB-S330	<1.0	None
Rm. 205T - Classroom Bathroom	Sink	Public Access	007	MB-S329	2.6	None
Rm. 217 - Classroom	Sink	Public Access	090	MB-S323	<1.0	None
Rm. 217 - Classroom	Sink	Public Access	---	MB-S341	---	See Note 6.
Rm. 217 - Classroom	Fountain	Public Access	089	MB-F314	<1.0	None
Rm. 218 - Classroom	Sink	Public Access	092	MB-S322	<1.0	None
Rm. 218 - Classroom	Sink	Public Access	091	MB-S340	<1.0	None
Rm. 218 - Classroom	Fountain	Public Access	093	MB-F311	<1.0	None
Rm. 219 - Office	Sink	Secured - SCSD Staff Only	---	MB-S320	---	See Note 8.
Rm. 219 - Office	Sink	Secured - SCSD Staff Only	028	MB-S321	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL
SAMPLE DATE: 09/29/23 ANALYSIS DATE: 10/03/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ACTIONS
Rm. 219 - Office	Fountain	Secured - SCSD Staff Only	029	MB-F310	<1.0	None
Rm. 221 - Classroom	Sink	Public Access	026	MB-S319	<1.0	None
Rm. 221 - Classroom	Fountain	Public Access	027	MB-F309	<1.0	None
Rm. 222 - Classroom	Sink	Public Access	024	MB-S316	<1.0	None
Rm. 222 - Classroom	Fountain	Public Access	025	MB-F308	<1.0	None
Rm. 223 - Classroom	Sink	Public Access	021	MB-S315	<1.0	None
Rm. 223 - Classroom	Sink	Public Access	022	MB-S338	<1.0	None
Rm. 223 - Classroom	Fountain	Public Access	023	MB-F307	<1.0	None
Rm. 224 - Resource Room	Sink	Public Access	012	MB-S314	<1.0	None
Rm. 227 - Classroom	Sink	Public Access	---	MB-S313	---	See Note 6.
Rm. 227 - Classroom	Sink	Public Access	094	MB-S337	1.3	None
Rm. 227 - Classroom	Fountain	Public Access	---	MB-F306	---	See Note 6.
Rm. 228 - Classroom	Sink	Public Access	---	MB-S307	---	See Note 6.
Rm. 228 - Classroom	Sink	Public Access	020	MB-S336	2.6	None
Rm. 228 - Classroom	Fountain	Public Access	---	MB-F303	---	See Note 6.
Rm. 232 - Classroom	Sink	Public Access	019	MB-S304	<1.0	None
Rm. 233 - Classroom	Sink	Public Access	016	MB-S303	<1.0	None
Rm. 234 - Classroom	Sink	Public Access	018	MB-S302	<1.0	None
Rm. 235 - Classroom	Sink	Public Access	017	MB-S301	<1.0	None
Rm. 236 - Classroom	Sink	Public Access	---	MB-S308	---	See Note 6.
Rm. 236 - Classroom	Sink	Public Access	013	MB-S339	<1.0	None
Rm. 236 - Classroom	Fountain	Public Access	---	MB-F304	---	See Note 6.
Rm. 238 - Resource Room	Sink	Public Access	---	MB-S311	---	See Note 6.
Rm. 239 - Classroom	Sink	Public Access	010	MB-S310	<1.0	None
Rm. 239 - Classroom	Fountain	Public Access	011	MB-F305	<1.0	None
Rm. 247 - Hallway/Vestibule	Sink	Public Access	001	MB-S332	<1.0	None
Rm. 247 - Hallway/Vestibule	Sink	Public Access	002	MB-S333	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL
SAMPLE DATE: 09/29/23 ANALYSIS DATE: 10/03/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ACTIONS
Rm. 247 - Hallway/Vestibule	Sink	Public Access	003	MB-S334	<1.0	None
Rm. 247 - Hallway/Vestibule	Sink	Public Access	004	MB-S335	<1.0	None
Rm. 247 - Hallway/Vestibule	Fountain	Public Access	---	MB-F312	---	See Note 6.
Rm. 247 - Hallway/Vestibule	Fountain	Public Access	---	MB-F313	---	See Note 6.
Rm. 256 - Hallway/Vestibule	Sink	Public Access	---	MB-S305	---	See Note 9.
Rm. 256 - Hallway/Vestibule	Sink	Public Access	---	MB-S306	---	See Note 9.
Rm. 256 - Hallway/Vestibule	Fountain	Public Access	014	MB-F301	<1.0	None
Rm. 256 - Hallway/Vestibule	Fountain	Public Access	015	MB-F302	<1.0	None

- Notes [September 29, 2023 Event]:
- Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015
 - Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70272394.
 - New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
 - The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
 - Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
 - Fixture inoperative. SCSD to evaluate for repair or removal.
 - Fixture removed and replaced by SCSD. Resampling pending.
 - Fixture signed by SCSD.
 - Fixture removed by SCSD.