

SYRACUSE CITY SCHOOL DISTRICT
SEYMOUR DUAL LANGUAGE ACADEMY SCHOOL PK-GRADE 5
SAMPLE DATE: 07/11/23 ANALYSIS DATE: 07/12/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/11/23 RESULTS (ppb)	07/11/2023 ACTIONS
Rm. 114 - Classroom	Fountain	Public Access	012	SR-F304	<1.0	None
Rm. 115 - Classroom	Fountain	Public Access	011	SR-F204	<1.0	None
Rm. 116 - Classroom	Fountain	Public Access	020	SR-S203	<1.0	None
Rm. 117 - Classroom	Sink	Public Access	019	SR-S208	<1.0	None
Rm. 117 - Classroom	Fountain	Public Access	018	SR-F202	<1.0	None
Rm. 119 - Classroom	Sink	Public Access	017	SR-S204	<1.0	None
Rm. 119 - Classroom	Fountain	Public Access	---	SR-F201	---	See Note 6.
Rm. 123 - Hallway/Corridor	Fountain	Public Access	016	SR-F200	<1.0	None
Rm. 137 - Audio / Visual	Sink	Public Access	015	SR-A	1.4	None
Rm. 156 - Hallway/Corridor	Fountain	Public Access	014	SR-F303	<1.0	None
Rm. 156 - Hallway/Corridor	Fountain (Sensor)	Public Access	---	SR-F303A	---	See Note 6.
Rm. 175 - Exam Room	Sink	Public Access	013	SR-S326	<1.0	None
Rm. 176 - Cafeteria	Fountain	Public Access	001	SR-F305	<1.0	None
Rm. 178 - Kitchen	Sink	Secured - SCSD Staff Only	002	SR-S210	1.3	None
Rm. 178 - Kitchen	Sink	Secured - SCSD Staff Only	004	SR-S211	1.9	None
Rm. 178 - Kitchen	Sink Hose	Secured - SCSD Staff Only	005	SR-S212	<1.0	None
Rm. 178 - Kitchen	Sink	Secured - SCSD Staff Only	003	SR-S213	<1.0	None
Rm. 221 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	010	SR-S315	<1.0	None
Rm. 221G - Hallway/Vestibule	Fountain	Public Access	---	SR-F302	---	See Note 6.
Rm. 221G - Hallway/Vestibule	Sink	Public Access	008	SR-S307	<1.0	None
Rm. 221G - Hallway/Vestibule	Sink	Public Access	007	SR-S308	1.7	None
Rm. 222A - Classroom	Sink	Public Access	009	SR-S309	1.4	None
Rm. 232 - Hallway/Corridor	Fountain	Public Access	006	SR-F301	<1.0	None

Notes [July 11, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-016
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70262890.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.