

SYRACUSE CITY SCHOOL DISTRICT
SALEM-HYDE ELEMENTARY SCHOOL
SAMPLE DATE: 06/15/23 ANALYSIS DATE: 06/22/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/15/23 RESULTS (ppb)	06/15/23 ACTIONS
Rm. 004 - Gym Office	Sink	Secured - SCSD Staff Only	003	SH-S100	5.7	See Note 7.
Rm. 012 - Cafeteria	Fountain	Public Access	009	SH-F100	<1.0	None
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	004	SH-S104	1.7	None
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	005	SH-S105	2.2	None
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	006	SH-S106	1.2	None
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	007	SH-S107	<1.0	None
Rm. 022 - Kitchen	Kitchen Equipment	Secured - SCSD Staff Only	008	SH-S400	<1.0	None
Rm. 218 - Classroom	Fountain	Public Access	010	SH-F101	2.2	None
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	012	SH-S110	<1.0	None
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	013	SH-S111	<1.0	None
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	014	SH-S112	<1.0	None
Rm. 224A - Hallway/Vestibule	Fountain	Public Access	015	SH-F102	1.1	None
Rm. 224 - Hallway/Corridor	Fountain	Public Access	016	SH-F103	<1.0	None
Rm. 025 - Hallway/Corridor	Fountain	Public Access	001	SH-F200	<1.0	None
Rm. 025 - Hallway/Corridor	Fountain	Public Access	002	SH-F200A	<1.0	None
Rm. 101 - Classroom	Fountain	Public Access	022	SH-F201	4.5	None
Rm. 119B - Classroom Bathroom	Sink	Public Access	039	SH-S202	1.5	None
Rm. 101A - Classroom Bathroom	Sink	Public Access	021	SH-S203	3.4	None
Rm. 120 - Classroom	Fountain	Public Access	020	SH-F202	6.8	See Note 8.
Rm. 102 - Classroom	Sink	Public Access	026	SH-S205	1.4	None
Rm. 102 - Classroom	Fountain	Public Access	---	SH-F203	---	See Note 6.
Rm. 102A - Classroom Bathroom	Sink	Public Access	027	SH-S206	2.2	None
Rm. 105A - Exam Room	Sink	Public Access	037	SH-S211	<1.0	None
Rm. 109 - Classroom	Fountain	Public Access	030	SH-F204	<1.0	None
Rm. 109A - Classroom Bathroom	Sink	Public Access	031	SH-S215	1.8	None
Rm. 110 - Classroom	Sink	Public Access	019	SH-S216	<1.0	None

**SYRACUSE CITY SCHOOL DISTRICT
SALEM-HYDE ELEMENTARY SCHOOL**
SAMPLE DATE: 06/15/23 ANALYSIS DATE: 06/22/23

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/15/23 RESULTS (ppb)	06/15/23 ACTIONS
Rm. 110 - Classroom	Fountain	Public Access	028	SH-F205	<1.0	None
Rm. 111 - Classroom	Fountain	Public Access	018	SH-F206	1.3	None
Rm. 111A - Classroom Bathroom	Sink	Public Access	017	SH-S219	<1.0	None
Rm. 112 - Classroom	Fountain	Public Access	029	SH-F207	<1.0	None
Rm. 113 - Classroom	Fountain	Public Access	032	SH-F208	<1.0	None
Rm. 131 - Hallway/Vestibule	Fountain	Public Access	032	SH-F209	<1.0	None
Rm. 131 - Hallway/Vestibule	Sink	Public Access	034	SH-S224	<1.0	None
Rm. 131 - Hallway/Vestibule	Sink	Public Access	035	SH-S225	<1.0	None
Rm. 131 - Hallway/Vestibule	Sink	Public Access	036	SH-S226	1.1	None
Rm. 115B - Work Room	Sink	Secured -SCSD Staff Only	038	SH-S227	<1.0	None
Rm. 119 - Classroom	Fountain	Public Access	025	SH-F210	4.5	None
Rm. 119 - Classroom	Sink	Public Access	023	SH-S228	2.1	None
Rm. 119A - Classroom Bathroom	Sink	Public Access	024	SH-S229	<1.0	None
Rm. 223 - Hallway/Corridor	Fountain	Public Access	011	SH-F400	<1.0	None

Notes [June 15, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70260017.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture removed and replaced by SCSD. Resampling pending.
8. Fixture repaired by SCSD. Resampling pending.