

SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL
SAMPLE DATE: 01/12/24 ANALYSIS DATE: 01/17/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	01/12/2024 RESULTS (ppb)	01/12/2024 ACTIONS
BUILDING SECTION 'A'						
Rm. 111 - Cosmetology Room	Sink	Public Access	041	FR-S148	<1.0	None
Rm. 113 - Faculty Lounge	Sink	Secured - SCSD Staff Only	047	FR-S144	<1.0	None
Rm. 117 - Safety Classroom	Sink	Public Access	042	FR-S147	3.4	None
Rm. 119 - Home & Careers Room	Sink	Public Access	046	FR-S140	4.5	None
Rm. 119 - Home & Careers Room	Sink	Public Access	045	FR-S141	4.1	None
Rm. 119 - Home & Careers Room	Sink	Public Access	044	FR-S142	<1.0	None
Rm. 119 - Home & Careers Room	Sink	Public Access	043	FR-S143	<1.0	None
Rm. 121 - Hallway/Corridor	Fountain	Public Access	048	FR-F102	<1.0	None
Rm. 121 - Hallway/Corridor	Fountain	Public Access	049	FR-F103	<1.0	None
Rm. 128 - Serving Room	Sink	Secured - SCSD Staff Only	014	FR-S112	<1.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	015	FR-S113	1.4	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	016	FR-S114	<1.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	019	FR-S115	<1.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	020	FR-S116	2.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	021	FR-S117	<1.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	055	FR-S118	1.7	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	056	FR-S119	<1.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	064	FR-S120	4.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	017	FR-S121	1.2	None
Rm. 128C - Kitchen	Kettle	Secured - SCSD Staff Only	---	FR-S122	---	See Note 6.
Rm. 128C - Kitchen	Hose Spray Stand	Secured - SCSD Staff Only	022	FR-S123	<1.0	None
Rm. 128C - Kitchen	Kettle Faucet	Secured - SCSD Staff Only	---	FR-S124	---	See Note 6.
Rm. 128C - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	057	FR-S126	12.9	See Note 7.
Rm. 128C - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	058	FR-S127	2.8	None
Rm. 128C - Kitchen	Combitherm Oven	Secured - SCSD Staff Only	059	FR-S128	4.4	None
Rm. 128C - Kitchen	Combitherm Oven	Secured - SCSD Staff Only	060	FR-S129	4.6	None

SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL
SAMPLE DATE: 01/12/24 ANALYSIS DATE: 01/17/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	01/12/24 RESULTS (ppb)	01/12/24 ACTIONS
BUILDING SECTION 'A', cont.						
Rm. 128C - Kitchen	Hose Spray Stand	Secured - SCSD Staff Only	061	FR-S130	<1.0	None
Rm. 128C - Kitchen	Hose Spray Stand	Secured - SCSD Staff Only	062	FR-S131	<1.0	None
Rm. 128C - Kitchen	iCombi Pro	Secured - SCSD Staff Only	018	FR-C1000	1.0	None
Rm. 128D - Kitchen/Corridor	Ice Machine	Secured - SCSD Staff Only	051	FR-S132 A/B/C/D	<1.0	None
Rm. 128E - Storage Room	Sink	Secured - SCSD Staff Only	050	FR-S133	3.1	None
Rm. 129 - Hallway/Corridor	Fountain	Public Access	003	FR-F101	<1.0	None
Rm. 129 - Hallway/Corridor	Fountain	Public Access	004	FR-F101A	<1.0	None
Rm. 131I - Exam Room	Sink	Public Access	005	FR-S104	<1.0	None
Rm. 131J - Nurse's Office	Sink	Public Access	006	FR-S103	1.9	None
Rm. 131R - Practical Treatment Room	Sink	Secured - SCSD Staff Only	013	FR-S111	16.1	See Note 8.
Rm. 131U - Practical Treatment Room	Sink	Secured - SCSD Staff Only	011	FR-S110	<1.0	None
Rm. 131V - Soiled Meds Room	Sink	Secured - SCSD Staff Only	007	FR-S107	<1.0	None
Rm. 131Y - Dental Office	Sink	Public Access	010	FR-S109	1.1	None
Rm. 137B - Boy's Locker Room Bathroom	Fountain	Public Access	002	FR-F100	<1.0	None
Rm. 141 - Meter Room	Sink	Public Access	001	FR-S165	3.9	None
Rm. 210A - Hallway/Corridor	Fountain	Public Access	034	FR-F518	<1.0	None
Rm. 210A - Hallway/Corridor	Fountain	Public Access	035	FR-F528	<1.0	None
Rm. 215 - Special Edu. Room	Sink	Public Access	036	FR-S541	<1.0	None
Rm. 231 - Concession Room	Sink	Secured - SCSD Staff Only	033	FR-S527	1.8	None
Rm. 257/285 - Hallway/Corridor	Fountain	Public Access	031	FR-F516	<1.0	None
Rm. 257/285 - Hallway/Corridor	Fountain	Public Access	032	FR-F517	<1.0	None
Rm. 276 - Swimming Pool	Fountain	Public Access	023	FR-F501	<1.0	None
Rm. 278 - Hallway/Corridor	Fountain	Public Access	030	FR-F500	2.4	None
Rm. 280 Boy's Locker Room	Fountain	Public Access	037	FR-F506	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL
SAMPLE DATE: 01/12/24 ANALYSIS DATE: 01/17/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	1/12/24 RESULTS (ppb)	01/12/24 ACTIONS
BUILDING SECTION 'A', cont.						
Rm. 280 Boy's Locker Room	Fountain	Public Access	038	FR-F507	<1.0	None
Rm. 281 - Girl's Locker Room	Fountain	Public Access	039	FR-F511	<1.0	None
Rm. 281 - Girl's Locker Room	Fountain	Public Access	040	FR-F512	<1.0	None
Rm. 333 - Hallway/Corridor	Fountain	Public Access	026	FR-F106	<1.0	None
Rm. 333 - Hallway/Corridor	Fountain	Public Access	027	FR-F107	<1.0	None
Rm. 352 - Hallway/Corridor	Fountain	Public Access	024	FR-F108	<1.0	None
Rm. 352 - Hallway/Corridor	Fountain	Public Access	025	FR-F109	<1.0	None
Rm. 131J - Nurse's Office	Sink (Spray)	Public Access	---	FR-S103A	---	See Note 6.
Rm. 131V - Soiled Meds Room	Sink (Spray)	Secured - SCSD Staff Only	009	FR-S107A	7.8	See Note 8.
Rm. 131U - Practical Treatment Room	Sink (Spray)	Secured - SCSD Staff Only	012	FR-S110A	3.4	None
Rm. 131W - Meds Room Bathroom	Sink	Secured - SCSD Staff Only	8	FR-S108	<1.0	None
BUILDING SECTION 'B'						
Rm. 201A - Work Room	Sink	Secured - SCSD Staff Only	063	FR-S540	<1.0	None
Rm. 316 - Hallway/Corridor	Fountain	Public Access	028	FR-F104	<1.0	None
Rm. 316 - Hallway/Corridor	Fountain	Public Access	029	FR-F105	<1.0	None

Notes [January 12, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70284180.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture repaired by SCSD. Resampling pending.
8. Fixture removed and replaced by SCSD. Resampling pending.