

SYRACUSE CITY SCHOOL DISTRICT GRANT MIDDLE SCHOOL

SAMPLE DATE: 12/22/23

ANALYSIS DATE: 12/28/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/22/23 RESULTS (ppb)	12/22/23 ACTIONS
Rm. B-18 - Boy's Locker Room Bathroom	Fountain	Public Access	047	GT-F201	10.1	See Note 6.
Rm. 108B - Exam Room	Sink	Public Access	024	GT-S217	2.7	None
Rm. 109 - Nurse's Office	Sink	Public Access	025	GT-S218	2.5	None
Rm. 110 - Classroom	Sink	Public Access	023	GT-S220	8.8	See Note 7.
Rm. 115 - Music Room	Sink	Public Access	068	GT-S226	26.0	See Note 6.
Rm. 123 - Work Room	Sink	Secured - SCSD Staff Only	046	GT-S221	1.2	None
Rm. 131 - Serving Room	Sink	Secured - SCSD Staff Only	072	GT-S212	1.4	None
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	057	GT-S109	1.4	None
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	053	GT-S112	1.2	None
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	052	GT-S113	1.7	None
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	058	GT-S114	3.8	None
Rm. 132B - Dental Office	Sink	Public Access	056	GT-S115	<1.0	None
Rm. 132F - Examination Room	Sink	Public Access	054	GT-S111	3.2	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	077	GT-S206	2.3	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	076	GT-S207	9.8	See Note 7.
Rm. 133A - Kitchen	Sink (spray nozzle)	Secured - SCSD Staff Only	073	GT-S208	<1.0	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	074	GT-S209	<1.0	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	075	GT-S210	1.5	None
Rm. 140B - Swimming Pool Office	Sink	Secured - SCSD Staff Only	049	GT-S119	7.9	See Note 6.
Rm. 151 - Hallway/Vestibule	Fountain	Public Access	064	GT-F100	1.1	None
Rm. 151 - Hallway/Vestibule	Sink	Public Access	066	GT-S101	2.3	None
Rm. 169 - Work Room	Sink	Secured - SCSD Staff Only	027	GT-S224	6.2	See Note 7.
Rm. 170 - Audio/Video Storage	Sink	Secured - SCSD Staff Only	026	GT-S225	1.3	None
Rm. 182 - Classroom	Sink	Public Access	082	GT-S103	<1.0	None
Rm. 182A - Nurse's Waiting Room	Sink	Public Access	081	GT-S106	1.2	None
Rm. 182B - Classroom Office	Sink	Public Access	062	GT-S104	2.1	None
Rm. 182D - Examination Room	Sink	Public Access	059	GT-S108	1.3	None
Rm. 184 - Swimming Pool	Fountain	Public Access	048	GT-F101	14.4	See Note 6.

SYRACUSE CITY SCHOOL DISTRICT GRANT MIDDLE SCHOOL

SAMPLE DATE: 12/22/23

ANALYSIS DATE: 12/28/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/22/23 RESULTS (ppb)	12/22/23 ACTIONS
Rm. 182G - Sick/Rest Waiting Room	Sink	Public Access	061	GT-S105	1.3	None
Rm. 185C - Office	Sink	Secured - SCSD Staff Only	067	GT-S102	3.1	None
Rm. 203 - Classroom	Sink	Public Access	018	GT-S124	<1.0	None
Rm. 212 - Girl's Coach Office	Sink	Secured - SCSD Staff Only	015	GT-S129	12.7	See Note 6.
Rm. 227 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	006	GT-S142	1.2	None
Rm. 270 - Hallway/Vestibule	Fountain	Public Access	012	GT-F102	<1.0	None
Rm. 294 - Home & Careers Room	Sink	Public Access	020	GT-S125	<1.0	None
Rm. 294 - Home & Careers Room	Sink	Public Access	019	GT-S126	5.7	See Note 7.
Rm. 296 - Home & Careers Room	Sink	Public Access	017	GT-S120	10.7	See Note 7.
Rm. 296 - Home & Careers Room	Sink	Public Access	---	GT-S121	---	See Note 9.
Rm. 296 - Home & Careers Room	Sink	Public Access	016	GT-S122	1.6	None
Rm. 131 - Serving Room	Ice Machine	Secured - SCSD Staff Only	083	GT-S1000	<1.0	None
Rm. 152 - Vestibule	Fountain	Public Access	071	GT-F1000	<1.0	None
Rm. 152 - Vestibule	Sink	Public Access	069	GT-S1001	<1.0	None
Rm. 152 - Vestibule	Sink	Public Access	070	GT-S1002	<1.0	None
Rm. 120 - Hallway/ Corridor	Fountain	Public Access	021	GT-F1001	<1.0	None
Rm. 120 - Hallway/ Corridor	Fountain	Public Access	022	GT-F1002	<1.0	None
Rm. 139 - Hallway/ Corridor	Fountain	Public Access	043	GT-F1003	<1.0	None
Rm. 139 - Hallway/ Corridor	Fountain	Public Access	044	GT-F1003A	<1.0	None
Rm. 139 - Hallway/ Corridor	Fountain	Public Access	045	GT-F1004	<1.0	None
Rm. 151 - Vestibule	Sink	Public Access	065	GT-S1014	1.2	None
Rm. 218 - Hallway/ Corridor	Fountain	Public Access	001	GT-F1005	<1.0	None
Rm. 218 - Hallway/ Corridor	Fountain	Public Access	---	GT-F1006	---	See Note 8.
Rm. 262 - Vestibule	Sink	Public Access	039	GT-S1016	<1.0	None
Rm. 262 - Vestibule	Sink	Public Access	040	GT-S1017	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT GRANT MIDDLE SCHOOL

SAMPLE DATE: 12/22/23

ANALYSIS DATE: 12/28/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/22/23 RESULTS (ppb)	12/22/23 ACTIONS
Rm. 262 - Vestibule	Fountain	Public Access	038	GT-F1007	<1.0	None
Rm. 208 - Hallway/ Corridor	Fountain	Public Access	004	GT-F1008	<1.0	None
Rm. 208 - Hallway/ Corridor	Fountain	Public Access	005	GT-F1009	<1.0	None
Rm. 255 - Hallway/ Corridor	Fountain	Public Access	002	GT-F1010	<1.0	None
Rm. 255 - Hallway/ Corridor	Fountain	Public Access	003	GT-F1011	<1.0	None
Rm. 211 - Girl's Lockerroom	Sink	Public Access	013	GT-S1027	<1.0	None
Rm. 211 - Girl's Lockerroom	Sink	Public Access	014	GT-S1028	<1.0	None
Rm. 220 - Boy's Lockerroom	Sink	Public Access	009	GT-S1029	<1.0	None
Rm. 220 - Boy's Lockerroom	Sink	Public Access	008	GT-S1030	<1.0	None
Rm. 271 - Vestibule	Fountain	Public Access	011	GT-F1012	<1.0	None
Rm. 210 - Hallway/ Corridor	Fountain	Public Access	007	GT-F1013	<1.0	None
Rm. 315 - Hallway/ Corridor	Fountain	Public Access	030	GT-F1014	<1.0	None
Rm. 133A - Kitchen	Sink	Public Access	078	GT-S3000	5.5	See Note 7.
Rm. 315 - Hallway/ Corridor	Fountain	Public Access	031	GT-F1015	<1.0	None
Rm. 347 - Vestibule	Sink	Public Access	033	GT-S1034	<1.0	None
Rm. 347 - Vestibule	Sink	Public Access	034	GT-S1035	<1.0	None
Rm. 347 - Vestibule	Fountain	Public Access	032	GT-F1016	<1.0	None
Rm. 308 - Hallway/ Corridor	Fountain	Public Access	035	GT-F1018	<1.0	None
Rm. 308 - Hallway/ Corridor	Fountain	Public Access	---	GT-F1017	---	See Note 8.
Rm. 326 - Hallway/ Corridor	Fountain	Public Access	036	GT-F1019	<1.0	None
Rm. 326 - Hallway/ Corridor	Fountain	Public Access	037	GT-F1020	<1.0	None
Rm. 140E - Boy's Locker Room Bathroom	Sink	Public Access	051	GT-S1044	<1.0	None
Rm. 137 - Girls Locker Room Bathroom	Sink	Public Access	042	GT-S1045	1.6	None
Rm. 184 - Swimming Pool	Fountain	Public Access	050	GT-F1021	1.5	None
Rm. 372 - Art Room	Sink	Public Access	028	GT-S5000	1.5	None
Rm. 372 - Art Room	Sink	Public Access	029	GT-S5001	3.0	None
Rm. 133A - Kitchen	Convotherm (Oven)	Secured - SCSD Staff Only	079	GT-C1000	11.4	See Note 7.
Rm. 133A - Kitchen	Convotherm (Oven)	Secured - SCSD Staff Only	080	GT-C1001	1.4	None

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

SAMPLE DATE: 12/22/23 ANALYSIS DATE: 12/28/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/22/23 RESULTS (ppb)	12/22/23 ACTIONS
Rm. 181 - Classroom	Sink	Public Access	063	GT-S3004	1.2	None
Rm. 238 - Classroom	Sink	Public Access	041	GT-S136A	3.9	None
Rm. 273 - Boy's Bathroom	Sink	Public Access	010	GT-S1031	3.5	None
Rm. 132G - Medical Assistance Bathroom	Sink	Public Access	055	GT-S110	<1.0	None
Rm. 182E - Bathroom	Sink	Public Access	060	GT-S107	<1.0	None

Notes: [December 22, 2023 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70282363.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture replaced by SCSD. Resampling pending.
7. Fixture repaired by SCSD. Resampling pending.
8. Fixture inoperative. SCSD to evaluate for repair or removal.
9. Fixture not accessible.