

SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - GRADE 8 SCHOOL
SAMPLE DATE: 10/03/2023 ANALYSIS DATE: 10/10/2023

| ROOM No. & LOCATION | FIXTURE (Sink/Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 10/03/2023 RESULTS (ppb) | 10/03/2023 ACTIONS |
|------------------------------|----------------------------|---------------------------|------------------------|---------------------------|--------------------------------|-----------------------|
| Rm. 122 - Classroom | Sink | Public Access | 003 | ES-S103 | <1.0 | None |
| Rm. 124 - Classroom | Sink | Public Access | 006 | ES-S106 | <1.0 | None |
| Rm. 156 - Classroom | Sink | Public Access | 023 | ES-S137 | <1.0 | None |
| Rm. 158 - Classroom | Sink | Public Access | 022 | ES-S135 | <1.0 | None |
| Rm. 160 - Classroom | Sink | Public Access | 021 | ES-S136 | <1.0 | None |
| Rm. 104A - Work Room | Sink | Secured - SCSD Staff Only | --- | ES-S150 | --- | See Note 6. |
| Rm. 124 - Toilet | Sink | Secured - SCSD Staff Only | 005 | ES-S105 | 1.5 | None |
| Rm. 120 - Nurse's Office | Sink | Public Access | 001 | ES-S101 | 1.3 | None |
| Rm. 133B - Copy Room | Sink | Secured - SCSD Staff Only | 020 | ES-S138 | 13.2 | See Note 7. |
| Rm. 127 - Kitchen | Sink- Faucet | Secured - SCSD Staff Only | 012 | ES-S123A | <1.0 | None |
| Rm. 127 - Kitchen | Sink - Sprayer | Secured - SCSD Staff Only | 013 | ES-S123B | <1.0 | None |
| Rm. 127 - Kitchen | Sink | Secured - SCSD Staff Only | 011 | ES-S124 | 1.0 | None |
| Rm. 127 - Kitchen | Sink | Secured - SCSD Staff Only | 048 | ES-S125 | 5.6 | See Note 7. |
| Rm. 127 - Kitchen | Sink | Secured - SCSD Staff Only | 014 | ES-S126 | 2.0 | None |
| Rm. 127 - Kitchen | Sink | Secured - SCSD Staff Only | 015 | ES-S127 | <1.0 | None |
| Rm. 127 - Kitchen | Sink | Secured - SCSD Staff Only | 016 | ES-S128 | 3.4 | None |
| Rm. 115 - Library Lounge | Sink | Secured - SCSD Staff Only | 019 | ES-S139 | <1.0 | None |
| Rm. 013 - Classroom | Sink | Public Access | 029 | ES-S141 | 37.3 | See Note 7. |
| Rm. 013 - Classroom | Sink | Public Access | 028 | ES-S142 | 8.1 | See Note 7. |
| Rm. 114B - Toilet | Sink | Public Access | 002 | ES-S1015 | <1.0 | None |
| Rm. 154 - Girl's Toilet | Sink | Public Access | 004 | ES-S2004 | 1.5 | None |
| Rm. 123 - Cafeteria | Fountain | Public Access | 039 | ES-F1000 | <1.0 | None |
| Rm. 123 - Cafeteria | Fountain | Public Access | 038 | ES-F1001 | <1.0 | None |
| Rm. 126F - Hallway/ Corridor | Fountain | Public Access | 040 | ES-F1002 | <1.0 | None |
| Rm. 126F - Hallway/ Corridor | Fountain | Public Access | 041 | ES-F1003 | <1.0 | None |
| Rm. 134 - Classroom | Sink | Public Access | 010 | ES-S1011 | <1.0 | None |
| Rm. 126D - Hallway/ Corridor | Fountain | Public Access | 037 | ES-F1004 | <1.0 | None |
| Rm. 126 - Classroom | Sink | Public Access | 007 | ES-S2002 | <1.0 | None |

SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - GRADE 8 SCHOOL
SAMPLE DATE: 10/03/2023 ANALYSIS DATE: 10/10/2023

| ROOM No. & LOCATION | FIXTURE (Sink/Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 10/03/2023 RESULTS (ppb) | 10/03/2023 ACTIONS |
|------------------------------|----------------------------|---------------------------|------------------------|---------------------------|--------------------------------|-----------------------|
| Rm. 126 - Toilet | Sink | Public Access | 008 | ES-S2003 | <1.0 | None |
| Rm. 130/132 - ADA Toilet | Sink | Public Access | 009 | ES-S1012 | <1.0 | None |
| Rm. 126B - Hallway/ Corridor | Fountain | Public Access | 035 | ES-F1006 | <1.0 | None |
| Rm. 126B - Hallway/ Corridor | Fountain | Public Access | 036 | ES-F1005 | <1.0 | None |
| Rm. 230 - Gym | Fountain | Public Access | 047 | ES-F1009 | <1.0 | None |
| Rm. 230 - Gym | Fountain | Public Access | 046 | ES-F1010 | <1.0 | None |
| Rm. 219A - Hallway/ Corridor | Fountain | Public Access | 032 | ES-F1011 | <1.0 | None |
| Rm. 216 - Hallway/ Corridor | Fountain | Public Access | 033 | ES-F1007 | <1.0 | None |
| Rm. 216 - Hallway/ Corridor | Fountain | Public Access | 034 | ES-F1008 | <1.0 | None |
| Rm. 002B - Technology Shop | Sink | Public Access | 030 | ES-S1035 | <1.0 | None |
| Rm. 012 - Hallway/ Corridor | Fountain | Public Access | 045 | ES-F1012 | <1.0 | None |
| Rm. 017 - Home & Careers | Sink | Public Access | 027 | ES-S1036 | <1.0 | None |
| Rm. 017 - Home & Careers | Sink | Public Access | 025 | ES-S1037 | 7.5 | See Note 7. |
| Rm. 020 - Conference Room | Sink | Secured - SCSD Staff Only | 031 | ES-S2005 | 3.4 | None |
| Rm. 127 - Kitchen | Convotherm Oven | Secured - SCSD Staff Only | 017 | ES-C1000 | 38.2 | See Note 7. |
| Rm. 017 - Home & Careers | Sink (Spray) | Public Access | 024 | ES-S3000 | 1.2 | None |
| Rm. 017 - Home & Careers | Sink (Spray) | Public Access | 026 | ES-S3001 | <10 | None |
| Hallway/ Corridor | Fountain | Public Access | 042 | ES-F2000 | <1.0 | None |
| Hallway/ Corridor | Fountain | Public Access | 043 | ES-F2000A | <1.0 | None |
| Rm. 012 - Hallway/ Corridor | Fountain | Public Access | 044 | ES-F3002 | <1.0 | None |

Notes: [October 3, 2023 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-010
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70272791.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture Inoperative. SCSD to evaluate for repair or removal.
7. Fixture repaired by SCSD. Resampling pending.