

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

| ROOM No. & LOCATION | FIXTURE (Sink/Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 01/12/24 RESULTS (ppb) | 01/12/24 ORIGINAL ACTIONS | LAB RE-SAMPLE I.D. No. | 03/08/24 RE-SAMPLE RESULTS (ppb) | 03/08/24 RE-SAMPLE ACTIONS |
|-------------------------------|----------------------------|---------------------------|---------------------------|---------------------------|------------------------------|---------------------------------|------------------------------|---|----------------------------------|
| BUILDING SECTION 'A' | | | | | | | | | |
| Rm. 111 - Cosmetology Room | Sink | Public Access | 041 | FR-S148 | <1.0 | None | --- | --- | --- |
| Rm. 113 - Faculty Lounge | Sink | Secured - SCSD Staff Only | 047 | FR-S144 | <1.0 | None | --- | --- | --- |
| Rm. 117 - Safety Classroom | Sink | Public Access | 042 | FR-S147 | 3.4 | None | --- | --- | --- |
| Rm. 119 - Home & Careers Room | Sink | Public Access | 046 | FR-S140 | 4.5 | None | --- | --- | --- |
| Rm. 119 - Home & Careers Room | Sink | Public Access | 045 | FR-S141 | 4.1 | None | --- | --- | --- |
| Rm. 119 - Home & Careers Room | Sink | Public Access | 044 | FR-S142 | <1.0 | None | --- | --- | --- |
| Rm. 119 - Home & Careers Room | Sink | Public Access | 043 | FR-S143 | <1.0 | None | --- | --- | --- |
| Rm. 121 - Hallway/Corridor | Fountain | Public Access | 048 | FR-F102 | <1.0 | None | --- | --- | --- |
| Rm. 121 - Hallway/Corridor | Fountain | Public Access | 049 | FR-F103 | <1.0 | None | --- | --- | --- |
| Rm. 128 - Serving Room | Sink | Secured - SCSD Staff Only | 014 | FR-S112 | <1.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 015 | FR-S113 | 1.4 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 016 | FR-S114 | <1.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 019 | FR-S115 | <1.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 020 | FR-S116 | 2.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 021 | FR-S117 | <1.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 055 | FR-S118 | 1.7 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 056 | FR-S119 | <1.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 064 | FR-S120 | 4.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Sink | Secured - SCSD Staff Only | 017 | FR-S121 | 1.2 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Kettle | Secured - SCSD Staff Only | --- | FR-S122 | --- | See Note 6. | --- | --- | See Note 6. |
| Rm. 128C - Kitchen | Hose Spray Stand | Secured - SCSD Staff Only | 022 | FR-S123 | <1.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Kettle Faucet | Secured - SCSD Staff Only | --- | FR-S124 | --- | See Note 6. | --- | --- | See Note 6. |
| Rm. 128C - Kitchen | Convothem Oven | Secured - SCSD Staff Only | 057 | FR-S126 | 12.9 | See Note 7. | --- | --- | See Note 6. |
| Rm. 128C - Kitchen | Convothem Oven | Secured - SCSD Staff Only | 058 | FR-S127 | 2.8 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Combitherm Oven | Secured - SCSD Staff Only | 059 | FR-S128 | 4.4 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Combitherm Oven | Secured - SCSD Staff Only | 060 | FR-S129 | 4.6 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Hose Spray Stand | Secured - SCSD Staff Only | 061 | FR-S130 | <1.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | Hose Spray Stand | Secured - SCSD Staff Only | 062 | FR-S131 | <1.0 | None | --- | --- | --- |
| Rm. 128C - Kitchen | iCombi Pro | Secured - SCSD Staff Only | 018 | FR-C1000 | 1.0 | None | --- | --- | --- |

SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL

| ROOM No. & LOCATION | FIXTURE (Sink/Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 01/12/24 RESULTS (ppb) | 01/12/24 ORIGINAL ACTIONS | LAB RE-SAMPLE I.D. No. | 03/08/24 RE-SAMPLE RESULTS (ppb) | 03/08/24 RE-SAMPLE ACTIONS |
|---------------------------------------|----------------------------|---------------------------|---------------------------|---------------------------|------------------------------|---------------------------------|------------------------------|---|----------------------------------|
| BUILDING SECTION 'A', cont. | | | | | | | | | |
| Rm. 128D - Kitchen/Corridor | Ice Machine | Secured - SCSD Staff Only | 051 | FR-S132 A/B/C/D | <1.0 | None | --- | --- | --- |
| Rm. 128E - Storage Room | Sink | Secured - SCSD Staff Only | 050 | FR-S133 | 3.1 | None | --- | --- | --- |
| Rm. 129 - Hallway/Corridor | Fountain | Public Access | 003 | FR-F101 | <1.0 | None | --- | --- | --- |
| Rm. 129 - Hallway/Corridor | Fountain | Public Access | 004 | FR-F101A | <1.0 | None | --- | --- | --- |
| Rm. 131I - Exam Room | Sink | Public Access | 005 | FR-S104 | <1.0 | None | --- | --- | --- |
| Rm. 131J - Nurse's Office | Sink | Public Access | 006 | FR-S103 | 1.9 | None | --- | --- | --- |
| Rm. 131R - Practical Treatment Room | Sink | Secured - SCSD Staff Only | 013 | FR-S111 | 16.1 | See Note 8. | 001 | 2.5 | None |
| Rm. 131U - Practical Treatment Room | Sink | Secured - SCSD Staff Only | 011 | FR-S110 | <1.0 | None | --- | --- | --- |
| Rm. 131V - Soiled Meds Room | Sink | Secured - SCSD Staff Only | 007 | FR-S107 | <1.0 | None | --- | --- | --- |
| Rm. 131Y - Dental Office | Sink | Public Access | 010 | FR-S109 | 1.1 | None | --- | --- | --- |
| Rm. 137B - Boy's Locker Room Bathroom | Fountain | Public Access | 002 | FR-F100 | <1.0 | None | --- | --- | --- |
| Rm. 141 - Meter Room | Sink | Public Access | 001 | FR-S165 | 3.9 | None | --- | --- | --- |
| Rm. 210A - Hallway/Corridor | Fountain | Public Access | 034 | FR-F518 | <1.0 | None | --- | --- | --- |
| Rm. 210A - Hallway/Corridor | Fountain | Public Access | 035 | FR-F528 | <1.0 | None | --- | --- | --- |
| Rm. 215 - Special Edu. Room | Sink | Public Access | 036 | FR-S541 | <1.0 | None | --- | --- | --- |
| Rm. 231 - Concession Room | Sink | Secured - SCSD Staff Only | 033 | FR-S527 | 1.8 | None | --- | --- | --- |
| Rm. 257/285 - Hallway/Corridor | Fountain | Public Access | 031 | FR-F516 | <1.0 | None | --- | --- | --- |
| Rm. 257/285 - Hallway/Corridor | Fountain | Public Access | 032 | FR-F517 | <1.0 | None | --- | --- | --- |
| Rm. 276 - Swimming Pool | Fountain | Public Access | 023 | FR-F501 | <1.0 | None | --- | --- | --- |
| Rm. 278 - Hallway/Corridor | Fountain | Public Access | 030 | FR-F500 | 2.4 | None | --- | --- | --- |
| Rm. 280 Boy's Locker Room | Fountain | Public Access | 037 | FR-F506 | <1.0 | None | --- | --- | --- |
| Rm. 280 Boy's Locker Room | Fountain | Public Access | 038 | FR-F507 | <1.0 | None | --- | --- | --- |
| Rm. 281 - Girl's Locker Room | Fountain | Public Access | 039 | FR-F511 | <1.0 | None | --- | --- | --- |
| Rm. 281 - Girl's Locker Room | Fountain | Public Access | 040 | FR-F512 | <1.0 | None | --- | --- | --- |
| Rm. 333 - Hallway/Corridor | Fountain | Public Access | 026 | FR-F106 | <1.0 | None | --- | --- | --- |
| Rm. 333 - Hallway/Corridor | Fountain | Public Access | 027 | FR-F107 | <1.0 | None | --- | --- | --- |
| Rm. 352 - Hallway/Corridor | Fountain | Public Access | 024 | FR-F108 | <1.0 | None | --- | --- | --- |
| Rm. 352 - Hallway/Corridor | Fountain | Public Access | 025 | FR-F109 | <1.0 | None | --- | --- | --- |

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

| ROOM No. & LOCATION | FIXTURE (Sink/Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 01/12/24 RESULTS (ppb) | 01/12/24 ORIGINAL ACTIONS | LAB RE-SAMPLE I.D. No. | 03/08/24 RE-SAMPLE RESULTS (ppb) | 03/08/24 RE-SAMPLE ACTIONS |
|-------------------------------------|----------------------------|---------------------------|---------------------------|---------------------------|------------------------------|---------------------------------|------------------------------|---|----------------------------------|
| BUILDING SECTION 'A', cont. | | | | | | | | | |
| Rm. 131J - Nurse's Office | Sink (Spray) | Public Access | --- | FR-S103A | --- | See Note 6. | --- | --- | See Note 6. |
| Rm. 131V - Soiled Meds Room | Sink (Spray) | Secured - SCSD Staff Only | 009 | FR-S107A | 7.8 | See Note 8. | 002 | 1.8 | None |
| Rm. 131U - Practical Treatment Room | Sink (Spray) | Secured - SCSD Staff Only | 012 | FR-S110A | 3.4 | None | --- | --- | --- |
| Rm. 131W - Meds Room Bathroom | Sink | Secured - SCSD Staff Only | 8 | FR-S108 | <1.0 | None | --- | --- | --- |
| BUILDING SECTION 'B' | | | | | | | | | |
| Rm. 201A - Work Room | Sink | Secured - SCSD Staff Only | 063 | FR-S540 | <1.0 | None | --- | --- | --- |
| Rm. 316 - Hallway/Corridor | Fountain | Public Access | 028 | FR-F104 | <1.0 | None | --- | --- | --- |
| Rm. 316 - Hallway/Corridor | Fountain | Public Access | 029 | FR-F105 | <1.0 | None | --- | --- | --- |

Notes [January 12, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70284180.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture repaired by SCSD. Resampling pending.
8. Fixture removed and replaced by SCSD. Resampling pending.

Notes [March 08, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70284180.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.