

SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/06/23 RESULTS (ppb)	10/06/23 ACTIONS	LAB RE-SAMPLE I.D. No.	04/04/24 RE-SAMPLE RESULTS (ppb)	04/04/24 RE-SAMPLE ACTIONS
Rm. A102 - Hallway/Corridor	Fountain	Public Access	082	DK-F301	<1.0	None	---	---	---
Rm. A102 - Hallway/Corridor	Fountain	Public Access	083	DK-F302	<1.0	None	---	---	---
Rm. A113 - Kitchenette	Sink	Secured - SCSD Staff Only	097	DK-S325	<1.0	None	---	---	---
Rm. A116 - Classroom	Sink	Public Access	069	DK-S313	3.5	None	---	---	---
Rm. A116 - Classroom	Fountain	Public Access	070	DK-F500	<1.0	None	---	---	---
Rm. A117 - Classroom	Sink	Public Access	072	DK-S311	<1.0	None	---	---	---
Rm. A117 - Classroom	Fountain	Public Access	073	DK-F306	<1.0	None	---	---	---
Rm. A118 - Classroom	Sink	Public Access	071	DK-S309	<1.0	None	---	---	---
Rm. A118 - Classroom	Fountain	Public Access	---	DK-F305	---	See Note 6.	---	---	---
Rm. A119 - Classroom	Sink	Public Access	086	DK-S307	<1.0	None	---	---	---
Rm. A119 - Classroom	Fountain	Public Access	---	DK-F304	---	See Note 6.	---	---	---
Rm. A120 - Classroom	Sink	Public Access	085	DK-S305	<1.0	None	---	---	---
Rm. A120 - Classroom	Fountain	Public Access	030	DK-F303	<1.0	None			
Rm. A129 - Classroom	Sink	Public Access	080	DK-S323	<1.0	None	---	---	---
Rm. A129 - Classroom	Fountain	Public Access	081	DK-F311	<1.0	None	---	---	---
Rm. A130 - Classroom	Sink	Public Access	078	DK-S321	<1.0	None	---	---	---
Rm. A130 - Classroom	Fountain	Public Access	079	DK-F310	<1.0	None	---	---	---
Rm. A131 - Classroom	Sink	Public Access	077	DK-S319	<1.0	None	---	---	---
Rm. A131 - Classroom	Fountain	Public Access	---	DK-F309	---	See Note 6.	---	---	---
Rm. A132 - Classroom	Sink	Public Access	075	DK-S317	<1.0	None	---	---	---
Rm. A133 - Classroom	Sink	Public Access	074	DK-S315	<1.0	None	---	---	---
Rm. A133 - Classroom	Fountain	Public Access	---	DK-F308	---	See Note 6.	---	---	---
Rm. B102 - Hallway/Corridor	Fountain	Public Access	087	DK-F312	<1.0	None	---	---	---
Rm. B102 - Hallway/Corridor	Fountain	Public Access	088	DK-F313	<1.0	None	---	---	---
Rm. B115 - Resource & Staff Development	Sink	Secured - SCSD Staff Only	065	DK-S125	<1.0	None	---	---	---
Rm. B116 - Science Office	Sink	Public Access	089	DK-S330	30.0	See Note 7.	002	1.3	None
Rm. B122 - Media Work Room	Sink	Public Access	066	DK-S128	1.3	None	---	---	---
Rm. B129 - Classroom	Fountain	Public Access	064	DK-F203	1.5	None	---	---	---
Rm. B130 - Classroom	Sink	Public Access	063	DK-S223	<1.0	None	---	---	---
Rm. B133 - Music Room	Sink	Public Access	060	DK-S222	1.2	None	---	---	---
Rm. B134 - Classroom	Sink	Public Access	062	DK-S119	<1.0	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/06/23 RESULTS (ppb)	10/06/23 ACTIONS	LAB RE-SAMPLE I.D. No.	04/04/24 RE-SAMPLE RESULTS (ppb)	04/04/24 RE-SAMPLE ACTIONS
Rm. B134 - Classroom	Fountain	Public Access	061	DK-F107	9.8	See Note 10.	001	3.2	None
Rm. B136 - Classroom	Sink	Public Access	059	DK-S117A	<1.0	None	---	---	---
Rm. C106 - Hallway/Corridor	Fountain	Public Access	051	DK-F100	<1.0	None	---	---	---
Rm. C106 - Hallway/Corridor	Fountain	Public Access	052	DK-F101	<1.0	None	---	---	---
Rm. C108 - Hallway/Corridor	Sink	Public Access	046	DK-S214	3.8	None	---	---	---
Rm. C108 - Hallway/Corridor	Sink	Public Access	047	DK-S216	<1.0	None	---	---	---
Rm. C112 - Café	Fountain	Public Access	041	DK-F201	<1.0	None	---	---	---
Rm. C112 - Café	Fountain	Public Access	042	DK-F202	<1.0	None	---	---	---
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	036	DK-S205	<1.0	None	---	---	---
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	038	DK-S206	<1.0	None	---	---	---
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	039	DK-S207	<1.0	None	---	---	---
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	040	DK-S208	<1.0	None	---	---	---
Rm. C117 - Kitchen	Comborthern	Secured - SCSD Staff Only	037	DK-C1001	<1.0	None	---	---	---
Rm. C133 - Nurse's Room	Sink	Public Access	049	DK-S219	<1.0	None	---	---	---
Rm. C136 - Clean Room	Sink	Secured - SCSD Staff Only	048	DK-S217	<1.0	None	---	---	---
Rm. C138 - Sick Room	Sink	Public Access	050	DK-S220	<1.0	None	---	---	---
Rm. C140 - Exam Room	Sink	Public Access	045	DK-S218	<1.0	None	---	---	---
Rm.s C141 - Exam Room	Sink	Public Access	044	DK-S213	1.7	None	---	---	---
Rm. C142 - Dental Room	Sink	Public Access	043	DK-S212	<1.0	None	---	---	---
Rm. D101 - Hallway/Corridor	Fountain	Public Access	056	DK-F102	<1.0	None	---	---	---
Rm. D101 - Hallway/Corridor	Fountain	Public Access	057	DK-F103	<1.0	None	---	---	---
Rm. D108A - Hallway/Corridor	Fountain	Public Access	053	DK-F104	<1.0	None	---	---	---
Rm. D108A - Hallway/Corridor	Fountain	Public Access	054	DK-F105	<1.0	None	---	---	---
Rm. D127 - Classroom	Sink	Public Access	084	DK-S113	<1.0	None	---	---	---
Rm. D128 - Classroom	Sink	Public Access	055	DK-S111	<1.0	None	---	---	---
Rm. A202 - Hallway/Corridor	Fountain	Public Access	024	DK-F314	<1.0	None	---	---	---
Rm. A202 - Hallway/Corridor	Fountain	Public Access	025	DK-F315	<1.0	None	---	---	---
Rm. A213 - Kitchenette	Sink (Sprayer)	Public Access	---	DK - S353A	---	---	004	4.0	None
Rm. A213 - Kitchenette	Sink	Public Access	---	DK-S353	---	See Note 9.	003	<1.0	None
Rm. A217 - Classroom	Sink	Public Access	035	DK-S342	<1.0	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/06/23 RESULTS (ppb)	10/06/23 ACTIONS	LAB RE-SAMPLE I.D. No.	04/04/24 RE-SAMPLE RESULTS (ppb)	04/04/24 RE-SAMPLE ACTIONS
Rm. A221 - Classroom	Fountain	Public Access	027	DK-F334	<1.0	None	---	---	---
Rm. A217 - Classroom	Fountain	Public Access	034	DK-F320	1.6	None	---	---	---
Rm. A218 - Classroom	Sink	Public Access	033	DK-S340	<1.0	None	---	---	---
Rm. A218 - Classroom	Fountain	Public Access	032	DK-F319	1.6	None	---	---	---
Rm. A219 - Classroom	Sink	Public Access	031	DK-S338	<1.0	None	---	---	---
Rm. A219 - Classroom	Fountain	Public Access	096	DK-F318	<1.0	None	---	---	---
Rm. A220 - Classroom	Sink	Public Access	029	DK-S337	<1.0	None	---	---	---
Rm. A220 - Classroom	Fountain	Public Access	028	DK-F317	<1.0	None	---	---	---
Rm. A221 - Classroom	Sink	Public Access	026	DK-S335	<1.0	None	---	---	---
Rm. A233 - Classroom	Sink	Public Access	090	DK-S351	<1.0	None	---	---	---
Rm. A233 - Classroom	Fountain	Public Access	091	DK-F325	<1.0	None	---	---	---
Rm. A234 - Classroom	Sink	Public Access	092	DK-S350	<1.0	None	---	---	---
Rm. A234 - Classroom	Fountain	Public Access	093	DK-F324	<1.0	None	---	---	---
Rm. A235 - Classroom	Sink	Public Access	094	DK-S348	<1.0	None	---	---	---
Rm. A235 - Classroom	Fountain	Public Access	095	DK-F323	<1.0	None	---	---	---
Rm. A236 - Classroom	Fountain	Public Access	067	DK-F322	<1.0	None	---	---	---
Rm. A237 - Classroom	Fountain	Public Access	068	DK-F321	<1.0	None	---	---	---
Rm. B202 - Hallway/Corridor	Fountain	Public Access	023	DK-F205	<1.0	None	---	---	---
Rm. B202 - Hallway/Corridor	Fountain	Public Access	022	DK-F206	<1.0	None	---	---	---
Rm. B217 - Classroom	Sink	Public Access	021	DK-S233	<1.0	None	---	---	---
Rm. B217 - Classroom	Fountain	Public Access	020	DK-F204	<1.0	None	---	---	---
Rm. B218 - Classroom	Sink	Public Access	019	DK-S230	<1.0	None	---	---	---
Rm. B222 - Commons Kitchenette	Sink	Secured - SCSD Staff Only	018	DK-S231	<1.0	None	---	---	---
Rm. B223 - Classroom	Sink	Public Access	016	DK-S228	<1.0	None	---	---	---
Rm. B224 - Classroom	Sink	Public Access	017	DK-S229	<1.0	None	---	---	---
Rm. B225 - Classroom	Sink	Public Access	015	DK-S227	<1.0	None	---	---	---
Rm. C202 - Hallway/Corridor	Fountain	Public Access	002	DK-F108	<1.0	None	---	---	---
Rm. C202 - Hallway/Corridor	Fountain	Public Access	001	DK-F109	<1.0	None	---	---	---
Rm. C216 - Kitchenette	Sink	Secured - SCSD Staff Only	003	DK-S130	<1.0	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/06/23 RESULTS (ppb)	10/06/23 ACTIONS	LAB RE-SAMPLE I.D. No.	04/04/24 RE-SAMPLE RESULTS (ppb)	04/04/24 RE-SAMPLE ACTIONS
Rm. C216 - Kitchenette	Sink	Secured - SCSD Staff Only	004	DK-S130A	<1.0	None	---	---	---
Rm. C218 - Classroom	Sink	Public Access	006	DK-S129	<1.0	None	---	---	---
Rm. C219 - Classroom	Sink	Public Access	005	DK-S131	<1.0	None	---	---	---
Rm. C220 - Classroom	Sink	Public Access	007	DK-S132	<1.0	None	---	---	---
Rm. C221 - Classroom	Sink	Public Access	008	DK-S133	<1.0	None	---	---	---
Rm. C221 - Classroom	Fountain	Public Access	009	DK-F110	<1.0	None	---	---	---
Rm. C225 - Classroom	Sink	Public Access	011	DK-S136	<1.0	None	---	---	---
Rm. C225 - Classroom	Fountain	Public Access	010	DK-F111	<1.0	None	---	---	---
Rm. C226 - Classroom	Sink	Public Access	012	DK-S137	<1.0	None	---	---	---
Rm. C227 - Classroom	Sink	Public Access	013	DK-S138	<1.0	None	---	---	---
Rm. C228 - Classroom	Sink	Public Access	014	DK-S139	<1.0	None	---	---	---
Rm. A132 - Classroom	Fountain	Public Access	076	DK-F2000	5.0	None	---	---	---
Rm. B136 - Classroom	Fountain	Public Access	058	DK-F1000	<1.0	None	---	---	---

Notes [October 6, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-017
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70273326.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.
7. Fixture removed and replaced by SCSD.
8. Fixture repaired by SCSD.

Notes [April 4, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-017
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70293142.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.