

**SYRACUSE CITY SCHOOL DISTRICT  
HENNINGER HIGH SCHOOL**

SAMPLE DATE: 03/05/24 ANALYSIS DATE: 03/15/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	03/05/24 RESULTS (ppb)	03/05/24 ACTIONS
Rm. 008 - Classroom	Sink	Public Access	015	HR-S509 A	<1.0	None
Rm. 008 - Classroom	Sink	Public Access	016	HR-S509 B	<1.0	None
Rm. 008 - Classroom	Sink	Public Access	017	HR-S509 C	<1.0	None
Rm. 017 - Storage Room	Sink	Secured - SCSD Staff Only	026	HR-S511	<1.0	None
Rm. 044 - Hallway/Corridor	Fountain	Public Access	022	HR-F504	<1.0	None
Rm. 044 - Hallway/Corridor	Fountain	Public Access	023	HR-F504 A	<1.0	None
Rm. 044 - Hallway/Corridor	Fountain	Public Access	020	HR-F505 A	1.1	None
Rm. 044 - Hallway/Corridor	Fountain	Public Access	021	HR-F505	1.1	None
Rm. Rm. 047A - Hallway/Vestibule	Fountain	Public Access	019	HR-F503 A	<1.0	None
Rm. Rm. 047A - Hallway/Vestibule	Fountain	Public Access	018	HR-F503	<1.0	None
Rm. 047B - Hallway/Vestibule	Fountain	Public Access	025	HR-F501 A	<1.0	None
Rm. 047B - Hallway/Vestibule	Fountain	Public Access	024	HR-F501	<1.0	None
Rm. 051 - Hallway/Corridor	Fountain	Public Access	---	HR-F502	---	See Note 6.
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	043	HR-S132	<1.0	None
Rm. 071A - Hallway/Corridor	Fountain	Public Access	066	HR-F108	<1.0	None
Rm. 071A - Hallway/Corridor	Fountain	Public Access	065	HR-F108 A	<1.0	None
Rm. 103 - Classroom	Sink	Public Access	067	HR-S145	1.6	None
Rm. 103 - Classroom	Sink	Public Access	068	HR-S146	7.0	See Note 7.
Rm. 103 - Classroom	Sink	Public Access	069	HR-S147	<1.0	None
Rm. 103 - Classroom	Sink	Public Access	070	HR-S148	2.3	None
Rm. 103A - Work Area	Sink	Public Access	---	HR-S143	---	See Note 8.
Rm. 104 - Home & Careers Room	Sink	Public Access	062	HR-S140	2.7	None
Rm. 104 - Home & Careers Room	Sink	Public Access	064	HR-S141	<1.0	None
Rm. 104 - Home & Careers Room	Sink	Public Access	063	HR-S142	1.0	None

**SYRACUSE CITY SCHOOL DISTRICT  
HENNINGER HIGH SCHOOL**

SAMPLE DATE: 03/05/24 ANALYSIS DATE: 03/15/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	03/05/24 RESULTS (ppb)	03/05/24 ACTIONS
Rm. 132 - Hallway/Corridor	Fountain	Public Access	077	HR-F100	<1.0	None
Rm. 132 - Hallway/Corridor	Fountain	Public Access	078	HR-F101	<1.0	None
Rm. 149 - Health Service Room	Sink	Public Access	076	HR-S121	2.5	None
Rm. 163 - Hallway/Corridor	Fountain	Public Access	061	HR-F104	<1.0	None
Rm. 163 - Hallway/Corridor	Fountain	Public Access	060	HR-F104 A	<1.0	None
Rm. 163 - Hallway/Corridor	Fountain	Public Access	058	HR-F105	<1.0	None
Rm. 163 - Hallway/Corridor	Fountain	Public Access	059	HR-F105 A	<1.0	None
Rm. 190 - Hallway/Corridor	Fountain	Public Access	074	HR-F102	<1.0	None
Rm. 190 - Hallway/Corridor	Fountain	Public Access	075	HR-F103	<1.0	None
Rm. 205 - Classroom	Sink	Public Access	006	HR-S225	<1.0	None
Rm. 212 - Classroom	Sink	Public Access	009	HR-S226	5.9	See Note 7.
Rm. 213 - Classroom	Sink	Public Access	---	HR-S222	---	See Note 9.
Rm. 226C - Hallway/Corridor	Fountain	Public Access	008	HR-F523	<1.0	None
Rm. 240 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	005	HR-S209	<1.0	None
Rm. 259 - Hallway/Corridor	Fountain	Public Access	003	HR-F205	<1.0	None
Rm. 259 - Hallway/Corridor	Fountain	Public Access	004	HR-F206	<1.0	None
Rm. N-42 - Pool	Fountain	Public Access	---	HR-F202	---	See Note 6.
Rm. 263 - Hallway/Corridor	Fountain	Public Access	001	HR-F4000	<1.0	None
Rm. 263 - Hallway/Corridor	Fountain	Public Access	002	HR-F4001	<1.0	None
Rm. 227 - Hallway/Corridor	Fountain	Public Access	003	HR-F4002	<1.0	None
Rm. N-04 - Hallway/Corridor	Fountain	Public Access	010	HR-F2004	<1.0	None
Rm. N-04 - Hallway/Corridor	Fountain	Public Access	011	HR-F2003	<1.0	None
Rm. N-35 - Hallway/Corridor	Fountain	Public Access	012	HR-F2000	<1.0	None
Rm. N-35 - Hallway/Corridor	Fountain	Public Access	013	HR-F2001	<1.0	None
Rm. 001 - Lower Cafeteria	Ice Machine	Secured - SCSD Staff Only	027	HR-S5000ABC	<1.0	None
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	028	HR-S1000	1.9	None

**SYRACUSE CITY SCHOOL DISTRICT  
HENNINGER HIGH SCHOOL**

SAMPLE DATE: 03/05/24 ANALYSIS DATE: 03/15/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	03/05/24 RESULTS (ppb)	03/05/24 ACTIONS
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	029	HR-S1001	<1.0	None
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	030	HR-S1002	<1.0	None
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	031	HR-S1003	<1.0	None
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	032	HR-S1004	<1.0	None
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	033	HR-S1005	<1.0	None
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	034	HR-S1006	<1.0	None
Rm. 001 - Lower Cafeteria	Fountain	Public Access	035	HR-F1001	<1.0	None
Rm. 001 - Lower Cafeteria	Fountain	Public Access	036	HR-F1001A	<1.0	None
Rm. 001 - Lower Cafeteria	Fountain	Public Access	037	HR-F1000	<1.0	None
Rm. 069 - Upper Cafeteria	Fountain	Public Access	038	HR-F3000A	<1.0	None
Rm. 069 - Upper Cafeteria	Fountain	Public Access	039	HR-F3000	<1.0	None
Rm. 069 - Upper Cafeteria	Fountain	Public Access	040	HR-F3001A	<1.0	None
Rm. 069 - Upper Cafeteria	Fountain	Public Access	041	HR-F3001	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	056	HR-S3002	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	057	HR-S3000	2.3	None
Rm. 155 - Classroom	Sink	Public Access	071	HR-S3013	4.2	None
Rm. 161 - Hallway/Corridor	Fountain	Public Access	072	HR-F3002	<1.0	None
Rm. 161 - Hallway/Corridor	Fountain	Public Access	073	HR-F3003	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	042	HR-S3009	1.7	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	044	HR-S3012	1.5	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	045	HR-S3010	1.6	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	046	HR-S3011	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	047	HR-S3008A	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	048	HR-S3008	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	049	HR-S3007	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	050	HR-S3007A	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	051	HR-S3005	1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	052	HR-S3003	1.9	None

**SYRACUSE CITY SCHOOL DISTRICT  
HENNINGER HIGH SCHOOL**

SAMPLE DATE: 03/05/24 ANALYSIS DATE: 03/15/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	03/05/24 RESULTS (ppb)	03/05/24 ACTIONS
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	053	HR-S3004	1.2	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	054	HR-S3006	<1.0	None
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	055	HR-S3001	<1.0	None
Rm. 068 - Kitchen	Convotherm	Secured - SCSD Staff Only	---	HR-C3002	---	See Note 8.

Notes (March 5, 2024 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed By: Life Science Laboratories, Inc. - Pace Project No.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. Removed from service by SCSD.
7. Fixture repaired by SCSD. Resampling pending.
8. Fixture inoperative. Repaired by SCSD. Sampling pending.
9. Fixture inaccessible. Access restored by SCSD. Sampling pending.