

SYRACUSE CITY SCHOOL DISTRICT  
HW SMITH PK - GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/04/23 RESULTS (ppb)	08/04/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/12/24 RE-SAMPLE RESULTS (ppb)	04/12/24 RE-SAMPLE ACTIONS
Rm. A-A - Classroom	Sink	Public Access	007	HW-S308	1.1	None	---	---	---
Rm. A-A - Classroom	Sink	Public Access	008	HW-S309	1.7	None	---	---	---
Rm. A-01 - ESL Room	Sink	Public Access	006	HW-S307	<1.0	None	---	---	---
Rm. A-02 - Classroom	Sink	Public Access	009	HW-S312	2.3	None	---	---	---
Rm. A-02 - Classroom	Sink	Public Access	010	HW-S313	7.8	See Note 7.	001	2.2	None
Rm. A-03 - Classroom	Sink	Public Access	011	HW-S315	<1.0	None	---	---	---
Rm A-01 - ESL Room	Sink	Public Access	---	HW-S306	---	See Note 9.	---	---	---
Rm A-03 - Classroom	Fountain	Public Access	---	HW-F302	---	See Note 9.	---	---	---
Rm. A-04 - Classroom	Sink	Public Access	013	HW-S316	<1.0	None	---	---	---
Rm. A-04 - Classroom	Fountain	Public Access	012	HW-F303	6.9	See Note 7.	002	1.7	None
Rm. A-05 - Classroom	Sink	Public Access	016	HW-S319	1.5	None	---	---	---
Rm. A-05 - Classroom	Fountain	Public Access	017	HW-F305	4.4	None	---	---	---
Rm. A-06 - Classroom	Sink	Public Access	019	HW-S322	<1.0	None	---	---	---
Rm. A-06 - Classroom	Fountain	Public Access	018	HW-F306	12.6	See Note 9.	---	---	---
Rm. A-07 - Classroom	Sink	Public Access	020	HW-S324	<1.0	None	---	---	---
Rm. A-07 - Classroom	Fountain	Public Access	021	HW-F307	2.5	None	---	---	---
Rm. A-12 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	015	HW-S320	<1.0	None	---	---	---
Rm. A-22D - Storage Room	Sink	Secured - SCSD Staff Only	002	HW-S303	8.0	See Note 8.	---	---	---
Rm. A-30A - Hallway/Corridor	Fountain	Public Access	014	HW-F304	<1.0	None	---	---	---
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	004	HW-S301	<1.0	None	---	---	---
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	003	HW-S302	<1.0	None	---	---	---
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	005	HW-S305	<1.0	None	---	---	---
Rm. A-30H - Hallway/Corridor	Fountain	Public Access	001	HW-F301	<1.0	None	---	---	---
Rm. A-33 - Classroom	Sink	Public Access	022	HW-S104	<1.0	None	---	---	---
Rm. A-33 - Classroom	Fountain	Public Access	023	HW-F101	1.0	None	---	---	---
Rm. A-35 - Classroom	Sink	Public Access	024	HW-S102	<1.0	None	---	---	---
Rm. A-35 - Classroom	Fountain	Public Access	025	HW-F100	<1.0	None	---	---	---
Rm. A100J - Hallway/Corridor	Fountain	Public Access	052	HW-F308	<1.0	None	---	---	---
Rm. A100K	Fountain	Public Access	---	HW-F102	---	See Note 6.	005	<1.0	None

**SYRACUSE CITY SCHOOL DISTRICT  
HW SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/04/23 RESULTS (ppb)	08/04/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/12/24 RE-SAMPLE RESULTS (ppb)	04/12/24 RE-SAMPLE ACTIONS
Rm. A100K	Fountain	Public Access	---	HW-F103	---	See Note 6.	004	<1.0	None
Rm. A104 - Office	Sink	Secured - SCSD Staff Only	028	HW-S110	<1.0	None	---	---	---
Rm. A106 - Copy Room	Sink	Secured - SCSD Staff Only	061	HW-S112	<1.0	None	---	---	---
Rm. A108C - Home & Careers Room	Sink	Public Access	057	HW-S337	<1.0	None	---	---	---
Rm. A108C - Home & Careers Room	Sink	Public Access	058	HW-S338	<1.0	None	---	---	---
Rm. A108C - Home & Careers Room	Sink	Public Access	059	HW-S339	1.5	None	---	---	---
Rm. A108C - Home & Careers Room	Sink	Public Access	060	HW-S340	<1.0	None	---	---	---
Rm. A112 - Classroom	Sink	Public Access	056	HW-S342	<1.0	None	---	---	---
Rm. A122 - Classroom	Sink	Public Access	055	HW-S343	1.2	None	---	---	---
Rm. A123 - Classroom	Sink	Public Access	054	HW-S344	<1.0	None	---	---	---
Rm. A125 - Classroom	Sink	Public Access	053	HW-S345	<1.0	None	---	---	---
Rm. A200B - Hallway/Corridor	Fountain	Public Access	040	HW-F311	<1.0	None	---	---	---
Rm. A200B - Hallway/Corridor	Fountain	Public Access	041	HW-F312	<1.0	None	---	---	---
Rm. A205A - Hallway/Corridor	Fountain	Public Access	038	HW-F310	<1.0	None	---	---	---
Rm. A208A - Copy Room	Sink	Secured - SCSD Staff Only	039	HW-S363	<1.0	None	---	---	---
Rm. B109 - Boy's Locker Room	Fountain	Public Access	029	HW-F105	<1.0	None	---	---	---
Rm. B126 - Girl's Locker Room	Fountain	Public Access	030	HW-F106	<1.0	None	---	---	---
Rm. B128 - OT/PT Room	Sink	Public Access	031	HW-S121	<1.0	None	---	---	---
Rm. B132 - Dental Room	Sink	Public Access	062	HW-S346	<1.0	None	---	---	---
Rm. B134 - Hallway/Corridor	Fountain	Public Access	026	HW-F104	<1.0	None	---	---	---
Rm. B134 - Hallway/Corridor	Fountain (Sensor)	Public Access	027	HW-F104A	<1.0	None	---	---	---
Rm. B135B - Exam Room	Sink	Public Access	063	HW-S353	3.3	None	---	---	---
Rm. B136 - Health Center	Sink	Public Access	064	HW-S348	1.5	None	---	---	---
Rm. B138 - Nurse's Room	Sink	Public Access	036	HW-S352	2.6	None	---	---	---
Rm. B149 - Main Office	Sink	Secured - SCSD Staff Only	035	HW-S357	7.5	See Note 7.	006	2.6	None
Rm. B168 - Conference Room	Sink	Secured - SCSD Staff Only	033	HW-S355	<1.0	None	---	---	---
Rm. B172 - Work Room	Sink	Secured - SCSD Staff Only	032	HW-S125	<1.0	None	---	---	---
Rm. B204 - Hallway/Corridor	Fountain	Public Access	042	HW-F108	<1.0	None	---	---	---
Rm. B209 - Hallway/Corridor	Fountain	Public Access	051	HW-F107	<1.0	None	---	---	---
Rm. B222 - Kitchen	Sink (Pedal Operated)	Secured - SCSD Staff Only	046	HW-S370	1.5	None	---	---	---

## SYRACUSE CITY SCHOOL DISTRICT HW SMITH PK - GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/04/23 RESULTS (ppb)	08/04/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/12/24 RE-SAMPLE RESULTS (ppb)	04/12/24 RE-SAMPLE ACTIONS
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	043	HW-S371	4.2	None	---	---	---
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	044	HW-S372	3.4	None	---	---	---
Rm. B222 - Kitchen	Sink (Hose)	Secured - SCSD Staff Only	045	HW-S373	2.1	None	---	---	---
Rm. B222 - Kitchen	Sink (Hose)	Secured - SCSD Staff Only	048	HW-S374	<1.0	None	---	---	---
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	047	HW-S375	<1.0	None	---	---	---
Rm. B222B - Kitchen Serving Area	Sink (Pedal Operated)	Secured - SCSD Staff Only	049	HW-S377	3.2	None	---	---	---
Rm. B222 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	050	HW-C1000	2.6	None	---	---	---
Rm. B139 - Office	Sink	Public Access	037	HW-S1000	2.1	None	---	---	---
Rm. B104 - Hallway/Corridor	Fountain	Public Access	034	HW-F3004	<1.0	None	---	---	---
Rom. A110 - Technology Shop	Sink	Public Access	---	HW-S336	---	See Note 10.	003	<1.0	None
Rm. A202B - Special ED.	Sink	Public Access	---	HW-S366	---	See Note 10.	008	3.3	None
Rm. B220 - Band	Sink	Public Access	---	HW-S137	---	See Note 10.	007	1.6	None

Notes [August 4, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-018.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70265784.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed and replaced by SCSD.
8. Fixture signed by SCSD. No further action required.
9. Fixture removed by SCSD.
10. Fixture not sampled on 8/4/23.

Notes [April 12, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-018.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70294200.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.