

**SYRACUSE CITY SCHOOL DISTRICT
EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL**

ROOM NO. & LOCATION	FIXTURE (SINK/FOUNTAIN)	ACCESSIBILITY	LAB SAMPLE I.D. NO.	TDK SAMPLE I.D. No.	12/19/2023 ORIGINAL RESULTS (ppb)	12/19/2023 ORIGINAL ACTIONS	LAB SAMPLE I.D. NO.	01/10/2024 RE-SAMPLE RESULTS (ppb)	01/10/2024 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. NO.	05/03/2024 RE-SAMPLE RESULTS (ppb)	05/03/2024 RE-SAMPLE ACTIONS
Rm. 165 - Teacher/Staff Cafeteria	Sink	Secured - SCSD Staff Only	001	ELMS-S1005	<1.0	None	---	---	---	---	---	---
Rm. 110 - Hallway/Corridor	Fountain	Public Access	002	ELMS-F1002	<1.0	None	---	---	---	---	---	---
Rm. 110 - Hallway/Corridor	Fountain	Public Access	003	ELMS-F1002A	<1.0	None	---	---	---	---	---	---
Rm. 110 - Hallway/Corridor	Fountain	Public Access	004	ELMS-F1000	<1.0	None	---	---	---	---	---	---
Rm. 190 - Kitchen	Sink	Secured - SCSD Staff Only	005	ELMS-S1000	2.7	None	---	---	---	---	---	---
Rm. 190 - Kitchen	Sink	Secured - SCSD Staff Only	006	ELMS-S1001	9.8	See Note 6.	002	7.7	See Note 6.	002	4.3	None
Rm. 190 - Kitchen	Sink	Secured - SCSD Staff Only	007	ELMS-S1002	1.3	None	---	---	---	---	---	---
Rm. 106 - Nurse's Office	Sink	Public Access	008	ELMS-S1006	5.3	See Note 6.	001	6.5	See Note 6.	001	5.0	None
Rm. 123 - Hallway/Corridor	Fountain	Public Access	009	ELMS-F1003	<1.0	None	---	---	---	---	---	---
Rm. 135 - Hallway/Corridor	Fountain	Public Access	010	ELMS-F1001	<1.0	None	---	---	---	---	---	---
Rm. 135 - Hallway/Corridor	Fountain(Sensor)	Public Access	011	ELMS-F1001A	<1.0	None	---	---	---	---	---	---
Rm. 154 - Counselor Intern	Sink	Secured - SCSD Staff Only	012	ELMS-S1004	1.8	None	---	---	---	---	---	---
Rm. 143 - PE Office	Sink	Secured - SCSD Staff Only	013	ELMS-S1003	2.1	None	---	---	---	---	---	---
Rm. 190 - Kitchen	Convotherm	Secured - SCSD Staff Only	---	ELMS-C1000	---	---	---	---	---	003	1.5	None

Notes: [December 19, 2023 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031.
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70281619.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

Notes: [January 10, 2024 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031.
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70283838.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture replaced by SCSD. Resampling pending.

SYRACUSE CITY SCHOOL DISTRICT EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL

Notes: [May 3, 2024 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70296550.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.