

**SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/17/2024 RE-SAMPLE RESULTS (ppb)	04/17/2024 RE-SAMPLE ACTIONS	05/07/24 LAB RE-SAMPLE I.D. No.	01/07/24 RE-SAMPLE RESULTS (ppb)	05/07/24 RE-SAMPLE ACTIONS
Rm. 100D - Office Kitchenette	Sink	Secured - SCSD Staff Only	050	MB-S231	<1.0	None	---	---	---	---	---	---
Rm. 105 - Nurse's Office	Sink	Public Access	052	MB-S225	<1.0	None	---	---	---	---	---	---
Rm. 105A - Exam Room	Sink	Public Access	053	MB-S226	1.0	None	---	---	---	---	---	---
Rm. 105B - Nurse's Office Changing Room	Sink	Public Access	051	MB-S228	3.9	None	---	---	---	---	---	---
Rm. 107 - Classroom	Sink	Public Access	042	MB-S211	<1.0	None	---	---	---	---	---	---
Rm. 107 - Classroom	Sink	Public Access	041	MB-S212	<1.0	None	---	---	---	---	---	---
Rm. 107 - Classroom	Fountain	Public Access	043	MB-F203	<1.0	None	---	---	---	---	---	---
Rm. 111 - Classroom	Sink	Public Access	039	MB-S210	<1.0	None	---	---	---	---	---	---
Rm. 111 - Classroom	Sink	Public Access	040	MB-S209	<1.0	None	---	---	---	---	---	---
Rm. 111 - Classroom	Fountain	Public Access	038	MB-F202	<1.0	None	---	---	---	---	---	---
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	033	MB-S204	<1.0	None	---	---	---	---	---	---
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	032	MB-S205	<1.0	None	---	---	---	---	---	---
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	034	MB-S206	<1.0	None	---	---	---	---	---	---
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	030	MB-S207	<1.0	None	---	---	---	---	---	---
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	031	MB-S208	<1.0	None	---	---	---	---	---	---
Rm. 113 - Classroom	Sink	Public Access	035	MB-S201	<1.0	None	---	---	---	---	---	---
Rm. 113 - Classroom	Sink	Public Access	036	MB-S202	<1.0	None	---	---	---	---	---	---
Rm. 113 - Classroom	Fountain	Public Access	037	MB-F201	<1.0	None	---	---	---	---	---	---
Rm. 119 - Community Room	Sink	Public Access	049	MB-S218	<1.0	None	---	---	---	---	---	---
Rm. 126 - Classroom	Sink	Public Access	086	MB-S131	1.4	None	---	---	---	---	---	---
Rm. 126 - Classroom	Sink	Public Access	087	MB-S132	<1.0	None	---	---	---	---	---	---
Rm. 126 - Classroom	Fountain	Public Access	---	MB-F114	---	See Note 6.	003	<1.0	None	---	---	---
Rm. 127 - Classroom	Sink	Public Access	084	MB-S129	2.8	None	---	---	---	---	---	---
Rm. 127 - Classroom	Sink	Public Access	085	MB-S130	<1.0	None	---	---	---	---	---	---
Rm. 127 - Classroom	Fountain	Public Access	083	MB-F113	<1.0	None	---	---	---	---	---	---
Rm. 128 - Classroom	Sink	Public Access	081	MB-S125	2.1	None	---	---	---	---	---	---
Rm. 128 - Classroom	Sink	Public Access	082	MB-S126	<1.0	None	---	---	---	---	---	---
Rm. 130 - Classroom	Sink	Public Access	079	MB-S123	1.6	None	---	---	---	---	---	---
Rm. 130 - Classroom	Sink	Public Access	080	MB-S124	<1.0	None	---	---	---	---	---	---
Rm. 128 - Classroom	Fountain	Public Access	---	MB-F112	---	See Note 6.	004	<1.0	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ACTIONS	04/17/24 LAB RE-SAMPLE I.D. No.	04/17/24 RE-SAMPLE RESULTS (ppb)	04/17/24 RE-SAMPLE ACTIONS	05/07/24 LAB RE-SAMPLE I.D. No.	01/07/24 RE-SAMPLE RESULTS (ppb)	05/07/24 RE-SAMPLE ACTIONS
Rm. 130 - Classroom	Sink	Public Access	079	MB-S123	1.6	None	---	---	---	---	---	---
Rm. 130 - Classroom	Sink	Public Access	080	MB-S124	<1.0	None	---	---	---	---	---	---
Rm. 130 - Classroom	Fountain	Public Access	095	MB-F111	<1.0	None	---	---	---	---	---	---
Rm. 131 - Classroom	Sink	Public Access	078	MB-S122	3.6	None	---	---	---	---	---	---
Rm. 131 - Classroom	Fountain	Public Access	--	MB-F110	---	See Note 6.	005	1.4	None	---	---	---
Rm. 132 - Art Room	Sink	Public Access	076	MB-S119	3.0	None	---	---	---	---	---	---
Rm. 132 - Art Room	Sink	Public Access	077	MB-S120	<1.0	None	---	---	---	---	---	---
Rm. 137 - Classroom	Sink	Public Access	074	MB-S117	1	None	---	---	---	---	---	---
Rm. 137 - Classroom	Sink	Public Access	075	MB-S118	<1.0	None	---	---	---	---	---	---
Rm. 137 - Classroom	Fountain	Public Access	---	MB-F109	---	See Note 6.	006	<1.0	None	---	---	---
Rm. 138 - Classroom	Fountain	Public Access	058	MB-F100	<1.0	None	---	---	---	---	---	---
Rm. 138 - Classroom	Sink	Public Access	057	MB-S101	<1.0	None	---	---	---	---	---	---
Rm. 139 - Classroom	Sink	Public Access	055	MB-S103	<1.0	None	---	---	---	---	---	---
Rm. 139 - Classroom	Fountain	Public Access	054	MB-F101	<1.0	None	---	---	---	---	---	---
Rm. 139T - Classroom	Sink	Public Access	056	MB-S102	<1.0	None	---	---	---	---	---	---
Rm. 140 - Classroom	Sink	Public Access	061	MB-S105	<1.0	None	---	---	---	---	---	---
Rm. 140 - Classroom	Fountain	Public Access	059	MB-F102	<1.0	None	---	---	---	---	---	---
Rm. 140T - Classroom	Sink	Public Access	060	MB-S104	<1.0	None	---	---	---	---	---	---
Rm. 141 - Classroom	Sink	Public Access	062	MB-S106	<1.0	None	---	---	---	---	---	---
Rm. 141 - Classroom	Sink	Public Access	063	MB-S107	3.6	None	---	---	---	---	---	---
Rm. 141 - Classroom	Fountain	Public Access	---	MB-F103	---	See Note 6.	010	<1.0	None	---	---	---
Rm. 142 - Classroom	Sink	Public Access	068	MB-S110	<1.0	None	---	---	---	---	---	---
Rm. 142 - Classroom	Sink	Public Access	069	MB-S111	1.2	None	---	---	---	---	---	---
Rm. 142 - Classroom	Fountain	Public Access	---	MB-F106	---	See Note 6.	009	<1.0	None	---	---	---
Rm. 146 - Classroom	Sink	Public Access	071	MB-S112	2.6	None	---	---	---	---	---	---
Rm. 146 - Classroom	Fountain	Public Access	070	MB-F107	<1.0	None	---	---	---	---	---	---
Rm. 146 - Classroom	Sink	Public Access	072	MB-S113	<1.0	None	---	---	---	---	---	---
Rm. 150 - Classroom	Sink	Public Access	073	MB-S115	<1.0	None	---	---	---	---	---	---
Rm. 150 - Classroom	Fountain	Public Access	---	MB-F108	---	See Note 6.	011	<1.0	None	---	---	---
Rm. 151A - Work Office	Sink	Secured - SCSD Staff Only	088	MB-S127	3.8	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ACTIONS	04/17/24 LAB RE-SAMPLE I.D. No.	04/17/24 RE-SAMPLE RESULTS (ppb)	04/17/24 RE-SAMPLE ACTIONS	05/07/24 LAB RE-SAMPLE I.D. No.	01/07/24 RE-SAMPLE RESULTS (ppb)	05/07/24 RE-SAMPLE ACTIONS
Rm. 166 - Hallway/Vestibule	Sink	Public Access	064	MB-S108	81.2	See Note 7.	007	<1.0	None	---	---	---
Rm. 166 - Hallway/Vestibule	Sink	Public Access	065	MB-S109	62.5	See Note 7.	008	<1.0	None	---	---	---
Rm. 166 - Hallway/Vestibule	Fountain	Public Access	066	MB-F104	<1.0	None	---	---	---	---	---	---
Rm. 166 - Hallway/Vestibule	Fountain	Public Access	067	MB-F105	<1.0	None	---	---	---	---	---	---
Rm. 178 - Hallway/Vestibule	Sink	Public Access	044	MB-S214	<1.0	None	---	---	---	---	---	---
Rm. 178 - Hallway/Vestibule	Sink	Public Access	045	MB-S215	<1.0	None	---	---	---	---	---	---
Rm. 178 - Hallway/Vestibule	Sink	Public Access	047	MB-S216	<1.0	None	---	---	---	---	---	---
Rm. 178 - Hallway/Vestibule	Sink	Public Access	048	MB-S217	<1.0	None	---	---	---	---	---	---
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	046	MB-F204	<1.0	None	---	---	---	---	---	---
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	---	MB-F205	---	See Note 6.	002	<1.0	None	---	---	---
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	---	MB-F205A	---	---	001	<1.0	None	---	---	---
Rm. 200 - Science Room	Sink	Public Access	009	MB-S324	1.1	None	---	---	---	---	---	---
Rm. 202 - Science Room	Sink	Public Access	008	MB-S325	<1.0	None	---	---	---	---	---	---
Rm. 203 - Faculty Lounge	Sink	Secured - SCSD Staff Only	006	MB-S326	<1.0	None	---	---	---	---	---	---
Rm. 204 - Science Room	Sink	Public Access	005	MB-S330	<1.0	None	---	---	---	---	---	---
Rm. 205T - Classroom Bathroom	Sink	Public Access	007	MB-S329	2.6	None	---	---	---	---	---	---
Rm. 217 - Classroom	Sink	Public Access	090	MB-S323	<1.0	None	---	---	---	---	---	---
Rm. 217 - Classroom	Sink	Public Access	---	MB-S341	---	See Note 8.	---	---	---	---	---	---
Rm. 217 - Classroom	Fountain	Public Access	089	MB-F314	<1.0	None	---	---	---	---	---	---
Rm. 218 - Classroom	Sink	Public Access	092	MB-S322	<1.0	None	---	---	---	---	---	---
Rm. 218 - Classroom	Sink	Public Access	091	MB-S340	<1.0	None	---	---	---	---	---	---
Rm. 218 - Classroom	Fountain	Public Access	093	MB-F311	<1.0	None	---	---	---	---	---	---
Rm. 219 - Office	Sink	Secured - SCSD Staff Only	---	MB-S320	---	See Note 8.	---	---	---	---	---	---
Rm. 219 - Office	Sink	Secured - SCSD Staff Only	028	MB-S321	<1.0	None	---	---	---	---	---	---
Rm. 219 - Office	Fountain	Secured - SCSD Staff Only	029	MB-F310	<1.0	None	---	---	---	---	---	---
Rm. 221 - Classroom	Sink	Public Access	026	MB-S319	<1.0	None	---	---	---	---	---	---
Rm. 221 - Classroom	Fountain	Public Access	027	MB-F309	<1.0	None	---	---	---	---	---	---
Rm. 222 - Classroom	Sink	Public Access	024	MB-S316	<1.0	None	---	---	---	---	---	---
Rm. 222 - Classroom	Fountain	Public Access	025	MB-F308	<1.0	None	---	---	---	---	---	---
Rm. 223 - Classroom	Sink	Public Access	021	MB-S315	<1.0	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	09/29/23 RESULTS (ppb)	09/29/23 ACTIONS	04/17/24 LAB RE-SAMPLE I.D. No.	04/17/24 RE-SAMPLE RESULTS (ppb)	04/17/24 RE-SAMPLE ACTIONS	05/07/24 LAB RE-SAMPLE I.D. No.	01/07/24 RE-SAMPLE RESULTS (ppb)	05/07/24 RE-SAMPLE ACTIONS
Rm. 223 - Classroom	Sink	Public Access	022	MB-S338	<1.0	None	---	---	---	---	---	---
Rm. 223 - Classroom	Fountain	Public Access	023	MB-F307	<1.0	None	---	---	---	---	---	---
Rm. 224 - Resource Room	Sink	Public Access	012	MB-S314	<1.0	None	---	---	---	---	---	---
Rm. 227 - Classroom	Sink	Public Access	---	MB-S313	---	See Note 6.	015	<1.0	None	---	---	---
Rm. 227 - Classroom	Sink	Public Access	094	MB-S337	1.3	None	---	---	---	---	---	---
Rm. 227 - Classroom	Fountain	Public Access	---	MB-F306	---	See Note 6.	014	<1.0	None	---	---	---
Rm. 228 - Classroom	Sink	Public Access	---	MB-S307	---	See Note 6.	012	<1.0	None	---	---	---
Rm. 228 - Classroom	Sink	Public Access	020	MB-S336	2.6	None	---	---	---	---	---	---
Rm. 228 - Classroom	Fountain	Public Access	---	MB-F303	---	See Note 6.	013	<1.0	None	---	---	---
Rm. 232 - Classroom	Sink	Public Access	019	MB-S304	<1.0	None	---	---	---	---	---	---
Rm. 233 - Classroom	Sink	Public Access	016	MB-S303	<1.0	None	---	---	---	---	---	---
Rm. 234 - Classroom	Sink	Public Access	018	MB-S302	<1.0	None	---	---	---	---	---	---
Rm. 235 - Classroom	Sink	Public Access	017	MB-S301	<1.0	None	---	---	---	---	---	---
Rm. 236 - Classroom	Sink	Public Access	---	MB-S308	---	See Note 6.	019	<1.0	None	---	---	---
Rm. 236 - Classroom	Sink	Public Access	013	MB-S339	<1.0	None	---	---	-	---	---	-
Rm. 236 - Classroom	Fountain	Public Access	---	MB-F304	---	See Note 6.	018	<1.0	None	---	---	---
Rm. 238 - Resource Room	Sink	Public Access	---	MB-S311	---	See Note 6.	016	<1.0	None	---	---	---
Rm. 239 - Classroom	Sink	Public Access	010	MB-S310	<1.0	None	---	---	---	---	---	---
Rm. 239 - Classroom	Fountain	Public Access	011	MB-F305	<1.0	None	---	---	---	---	---	---
Rm. 247 - Hallway/Vestibule	Sink	Public Access	001	MB-S332	<1.0	None	---	---	---	---	---	---
Rm. 247 - Hallway/Vestibule	Sink	Public Access	002	MB-S333	<1.0	None	---	---	---	---	---	---
Rm. 247 - Hallway/Vestibule	Sink	Public Access	003	MB-S334	<1.0	None	---	---	---	---	---	---
Rm. 247 - Hallway/Vestibule	Sink	Public Access	004	MB-S335	<1.0	None	---	---	---	---	---	---
Rm. 247 - Hallway/Vestibule	Fountain	Public Access	---	MB-F312	---	See Note 6.	017	<1.0	None	---	---	---
Rm. 247 - Hallway/Vestibule	Fountain	Public Access	---	MB-F313	---	See Note 9.	---	---	---	---	---	---
Rm. 256 - Hallway/Vestibule	Sink	Public Access	---	MB-S305	---	See Note 9.	---	---	---	---	---	---
Rm. 256 - Hallway/Vestibule	Sink	Public Access	---	MB-S306	---	See Note 9.	---	---	---	---	---	---
Rm. 256 - Hallway/Vestibule	Fountain	Public Access	014	MB-F301	<1.0	None	---	---	---	---	---	---
Rm. 256 - Hallway/Vestibule	Fountain	Public Access	015	MB-F302	<1.0	None	---	---	---	---	---	---
Rm.112 - Kitchen	Oven Sprayer	Public Access	---	---	---	---	---	---	---	001	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

Notes [September 29, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70272394.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture removed and replaced by SCSD.
8. Fixture signed by SCSD. No further action required.
9. Fixture removed by SCSD.

Notes [April 17, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70294623.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Notes [May 7, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70296847.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.