

**SYRACUSE CITY SCHOOL DISTRICT  
LINCOLN MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/18/23 RESULTS (ppb)	07/18/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	05/01/24 RE-SAMPLE RESULTS (ppb)	05/01/24 RE-SAMPLE ACTIONS
Rm. 101 - Hallway/Corridor	Fountain	Public Access	012	LN-F205	<1.0	None	---	---	---
Rm. 101 - Hallway/Corridor	Fountain	Public Access	013	LN-F206	<1.0	None	---	---	---
Rm. 101 - Hallway/Corridor	Fountain (Sensor)	Public Access	014	LN-F206A	<1.0	None	---	---	---
Rm. 101H - Hallway/Corridor	Fountain	Public Access	015	LN-F201	<1.0	None	---	---	---
Rm. 102 - Nurse's Office	Sink	Public Access	016	LN-S223	2.5	None	---	---	---
Rm. 103 - Home & Careers Room	Sink	Public Access	032	LN-S428	4.4	None	---	---	---
Rm. 103 - Home & Careers Room	Sink	Public Access	033	LN-S429	6.9	See Note 7.	003	3.5	None
Rm. 104 - Classroom	Sink	Public Access	---	LN-S431	---	See Note 6.	004	25.7	See Note 6.
Rm. 104 - Classroom	Sink	Public Access	017	LN-S432	4.8	None	---	---	---
Rm. 106A - Storage Room	Sink	Secured - SCSD Staff Only	031	LN-S435	7.8	See Note 7.	005	2.6	None
Rm. 107 - Classroom	Sink	Public Access	030	LN-S436	4.3	None	---	---	---
Rm. 107 - Classroom	Sink	Public Access	029	LN-S437	3.4	None	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	005	LN-S225	<1.0	None	---	---	---
Rm. 109F - Kitchen	Sink (Sprayer)	Secured - SCSD Staff Only	004	LN-S226	<1.0	None	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	003	LN-S227	1.5	None	---	---	---
Rm. 109F - Kitchen	Sink (Sprayer)	Secured - SCSD Staff Only	002	LN-S228	<1.0	None	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	001	LN-S229	<1.0	None	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	006	LN-S230	2.7	None	---	---	---
Rm. 109F - Kitchen	Kettle	Secured - SCSD Staff Only	009	LN-S232	<1.0	None	---	---	---
Rm. 109F - Kitchen	Convothem Oven Sprayer	Secured - SCSD Staff Only	008	LN-S233	<1.0	None	---	---	---
Rm. 109F - Kitchen	i Combi Pro Oven Sprayer	Secured - SCSD Staff Only	007	LN-S234	<1.0	None	---	---	---
Rm. 109F - Kitchen	Kettle	Secured - SCSD Staff Only	010	LN-S235	2.4	None	---	---	---
Rm. 113 - Wood Shop	Sink	Public Access	011	LN-S236	1.1	None	---	---	---
Rm. 119A - Gym	Fountain	Public Access	023	LN-F204	1.1	None	---	---	---
Rm. 119A - Gym	Fountain	Public Access	025	LN-F202	2.0	None	---	---	---
Rm. 125 - Office	Sink	Secured - SCSD Staff Only	027	LN-S239	23.5	See Note 7.	002	14.7	See Note 6.
Rm. 128 - Library	Fountain	Public Access	026	LN-F208	1.3	None	---	---	---
Rm. 128A - Library Office	Sink	Secured - SCSD Staff Only	028	LN-S221	<1.0	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
LINCOLN MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/18/23 RESULTS (ppb)	07/18/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	05/01/24 RE-SAMPLE RESULTS (ppb)	05/01/24 RE-SAMPLE ACTIONS
Rm. 132 - Girl's Locker Room	Fountain	Public Access	024	LN-F203	4.8	None	---	---	---
Rm. 134A - Hallway/Corridor	Fountain	Public Access	034	LN-F207	<1.0	None	---	---	---
Rm. 206A - Hallway/Corridor	Fountain	Public Access	022	LN-F402	1.1	None	---	---	---
Rm. 206A - Hallway/Corridor	Fountain	Public Access	020	LN-F403	<1.0	None	---	---	---
Rm. 207 - Hallway/Corridor	Sink	Public Access	019	LN-F401	<1.0	None	---	---	---
Rm. 213 - Hallway/Corridor	Fountain	Public Access	018	LN-F400	<1.0	None	---	---	---
Rm. 109F - Kitchen	Ice Machine	Secured - SCSD Staff Only	---	LN-S1000	---	---	001	<1.0	None

Notes [July 18, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-023.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70263777.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed and replaced by SCSD.

Notes [May 1, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-023.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70296228.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed from service by SCSD.