

**SYRACUSE CITY SCHOOL DISTRICT
BELLEVUE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/12/23 ORIGINAL RESULTS (ppb)	12/12/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	05/23/24 RE-SAMPLE RESULTS (ppb)	05/23/24 RE-SAMPLE ACTIONS
Rm. 210 - Cafetorium	Fountain	Public Access	027	BE-F111	<1.0	None	---	---	---
Rm. 210 - Cafetorium	Fountain	Public Access	028	BE-F111A	<1.0	None	---	---	---
Rm. 208 - Kitchen	Sink	Secured - SCSD Staff Only	024	BE-S138	2.2	None	---	---	---
Rm. 208 - Kitchen	Sink	Secured - SCSD Staff Only	022	BE-S139	<1.0	None	---	---	---
Rm. C200 - Hallway/Corridor	Fountain	Public Access	035	BE-F114	1.7	None	---	---	---
Rm. 201 - Nurse's Office	Sink	Public Access	036	BE-S148	<1.0	None	---	---	---
Rm. 100 - Pre-K Classroom	Sink	Public Access	001	BE-S1000	1.0	None	---	---	---
Rm. 100 - Pre-K Classroom	Fountain	Public Access	002	BE-F1000	3.9	None	---	---	---
Rm. 101 - Pre-K Classroom	Sink	Public Access	003	BE-S1002	<1.0	None	---	---	---
Rm. 101 - Pre-K Classroom	Fountain	Public Access	--	BE-F1001	--	See Note 6.	---	---	---
Rm. 102 - Pre-K Classroom	Sink	Public Access	004	BE-S1004	<1.0	None	---	---	---
Rm. 102 - Pre-K Classroom	Fountain	Public Access	005	BE-F1002	4.2	None	---	---	---
Rm. 111 - Kindergarten Classroom	Sink	Public Access	008	BE-S1006	<1.0	None	---	---	---
Rm. 111 - Kindergarten Classroom	Fountain	Public Access	--	BE-F1003	--	See Note 6.	---	---	---
Rm. 112 - Kindergarten Classroom	Sink	Public Access	009	BE-S1008	<1.0	None	---	---	---
Rm. 112 - Kindergarten Classroom	Fountain	Public Access	--	BE-F1004	--	See Note 6.	---	---	---
Rm. 116 - Kindergarten Classroom	Sink	Public Access	014	BE-S1010	<1.0	None	---	---	---
Rm. 116 - Kindergarten Classroom	Fountain	Public Access	013	BE-F1005	<1.0	None	---	---	---
Rm. 117 - Kindergarten Classroom	Fountain	Public Access	--	BE-F1006	--	See Note 6.	---	---	---
Rm. 117 - Kindergarten Classroom	Sink	Public Access	015	BE-S1012	<1.0	None	---	---	---
Rm. C104 - Hallway/Corridor	Sink	Public Access	020	BE-S1017	<1.0	None	---	---	---
Rm. C104 - Hallway/Corridor	Sink	Public Access	019	BE-S1018	<1.0	None	---	---	---
Rm. C104 - Hallway/Corridor	Sink	Public Access	018	BE-S1019	<1.0	None	---	---	---
Rm. C105 - Hallway/Corridor	Fountain	Public Access	016	BE-F1007	<1.0	None	---	---	---
Rm. C105 - Hallway/Corridor	Fountain	Public Access	017	BE-F1008	<1.0	None	---	---	---
Rm. 205 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	021	BE-S1020	<1.0	None	---	---	---
Rm. 208 - Kitchen	Sink (Faucet)	Secured - SCSD Staff Only	025	BE-S1025	1.2	None	---	---	---
Rm. 208 - Kitchen	Sink (Spray)	Secured - SCSD Staff Only	026	BE-S1026	<1.0	None	---	---	---
Rm. C204 - Hallway/Corridor	Sink	Public Access	030	BE-S1029	<1.0	None	---	---	---

SYRACUSE CITY SCHOOL DISTRICT BELLEVUE ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/12/23 ORIGINAL RESULTS (ppb)	12/12/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	05/23/24 RE-SAMPLE RESULTS (ppb)	05/23/24 RE-SAMPLE ACTIONS
Rm. C204 - Hallway/Corridor	Sink	Public Access	031	BE-S1030	<1.0	None	---	---	---
Rm. C204 - Hallway/Corridor	Sink	Public Access	032	BE-S1031	<1.0	None	---	---	---
Rm. C205 - Hallway/Corridor	Fountain	Public Access	033	BE-F1009	<1.0	None	---	---	---
Rm. C205 - Hallway/Corridor	Fountain	Public Access	034	BE-F1010	<1.0	None	---	---	---
Rm. 115 - Music Classroom	Sink	Public Access	010	BE-S1037	9.7	See Note 7.	001	3.0	None
Rm. 115 - Music Classroom	Sink	Public Access	011	BE-S1038	2.4	None	---	---	---
Rm. 115 - Music Classroom	Sink	Public Access	012	BE-S1039	7.4	See Note 7.	002	3.2	None
Rm. C103 - Hallway/Corridor	Fountain	Public Access	007	BE-F3000	<1.0	None	---	---	---
Rm. C103 - Hallway/Corridor	Fountain	Public Access	006	BE-F3001	<1.0	None	---	---	---
Rm. C103 - Hallway/Corridor	Fountain	Public Access	023	BE-C1000	<1.0	None	---	---	---
Rm. 211 - Parent Room	Sink	Public Access	029	BE-S2000	2.8	None	---	---	---

Notes [December 12, 2023 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-009.
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70280712.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation of Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture repaired by SCSD.

Notes [May 23, 2024 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-009A.
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70299051
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation of Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture repaired by SCSD. Resampling pending.