

SYRACUSE CITY SCHOOL DISTRICT
CLARY MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/15/23 RESULTS (ppb)	12/15/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	05/03/24 RE-SAMPLE RESULTS (ppb)	05/03/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/30/24 RE-SAMPLE RESULTS (ppb)	05/30/24 RE-SAMPLE ACTIONS
Rm. 001 - Classroom	Sink	Public Access	018	CY-S1003	4.0	None.	---	---	---	---	---	---
Rm. 001 - Classroom	Fountain	Public Access	017	CY-F1005	2.1	None.	---	---	---	---	---	---
Rm. 115 - Hallway/Corridor	Fountain	Public Access	012	CY-F1003	<1.0	None.	---	---	---	---	---	---
Rm. 004D - Clinic Room	Sink	Public Access	010	CY-S1011	41.4	See Note 7.	006	3.7	None	---	---	---
Rm. 008 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	009	CY-S1012	<1.0	None.	---	---	---	---	---	---
Rm. 039 - Home & Careers Room	Sink	Public Access	006	CY-S1013	<1.0	None.	---	---	---	---	---	---
Rm. 039 - Home & Careers Room	Sink	Public Access	007	CY-S1014	1.5	None.	---	---	---	---	---	---
Rm. 039 - Home & Careers Room	Sink	Public Access	008	CY-S1015	<1.0	None.	---	---	---	---	---	---
Rm. 070 Technology Classroom	Sink	Public Access	014	CY-S1000	<1.0	None.	---	---	---	---	---	---
Rm. 081 - Classroom	Sink	Public Access	---	CY-S1002	---	See Note 9.	---	---	---	---	---	---
Rm. 115 - Lobby	Fountain	Public Access	---	CY-F1004	---	See Note 6.	005	<1.0	None	---	---	---
Rm. 153 - Hallway/Corridor	Sensor	Public Access	005	CY-F1010A	<1.0	None.	---	---	---	---	---	---
Rm. 153 - Hallway/Corridor	Fountain	Public Access	003	CY-F1008	<1.0	None.	---	---	---	---	---	---
Rm. 153 - Hallway/Corridor	Fountain	Public Access	002	CY-F1007	5.1	See Note 7.	007	<1.0	None	---	---	---
Rm. 152 - Hallway/Corridor	Fountain	Public Access	001	CY-F1009	<1.0	None.	---	---	---	---	---	---
Rm. 153 - Hallway/Corridor	Fountain	Public Access	004	CY-F1010	<1.0	None.	---	---	---	---	---	---
Rm. 204 - Hallway/Corridor	Fountain	Public Access	013	CY-F1002	1.6	None.	---	---	---	---	---	---
Rm. 160 - Hallway/Corridor	Fountain	Public Access	016	CY-F1000	16.5	See Note 7.	004	<1.0	None	---	---	---
Rm. 204 - Hallway/Corridor	Fountain	Public Access	015	CY-F1001	<1.0	None.	---	---	---	---	---	---
Rm. 326 - Nurse's Office	Sink	Public Access	011	CY-S1010	4.0	None.	---	---	---	---	---	---
Rm. 329 - Cafeteria	Fountain	Public Access	---	CY-F1006	---	See Note 6.	003	2.3	None	---	---	---
Rm. 331 - Kitchen (Sprayer)	Sink	Secured - SCSD Staff Only	029	CY-S1009A	2.5	None.	---	---	---	---	---	---
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	027	CY-S1009	2.0	None.	---	---	---	---	---	---
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	026	CY-S1008	2.3	None.	---	---	---	---	---	---
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	028	CY-S1007	3.4	None.	---	---	---	---	---	---
Rm. 331 - Kitchen (Sprayer)	Sink	Secured - SCSD Staff Only	025	CY-S1006A	1.4	None.	---	---	---	---	---	---
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	024	CY-S1006	3.1	None.	---	---	---	---	---	---
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	023	CY-S1005	11.0	See Note 7.	001	10.0	See Note 6.	001	4.2	None
Rm. 331 - Kitchen	Oven Sprayer	Secured - SCSD Staff Only	020	CY-C1002	4.9	None.	---	---	---	---	---	---
Rm. 331 - Kitchen	Oven Sprayer	Secured - SCSD Staff Only	021	CY-C1001	29.6	See Note 8.	002	4.5	None	---	---	---
Rm. 331 - Kitchen	Oven Sprayer	Secured - SCSD Staff Only	022	CY-C1000	3.8	None.	---	---	---	---	---	---
Rm. 339 - Kitchen	Ice Machine	Secured - SCSD Staff Only	030	CY-I1000	<1.0	None.	---	---	---	---	---	---
Rm. 339 - Kitchen	Sink	Secured - SCSD Staff Only	019	CY-S1004	3.6	None.	---	---	---	---	---	---
R. 076A - Classroom	Sink	Public Access	---	CY-S1001	---	See Note 9.	---	---	---	---	---	---
Rm. 450 - Office	Sink	Secured - SCSD Staff Only	---	CY-S1016	---	See Note 9.	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT
CLARY MIDDLE SCHOOL

Notes [December 15, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70281468.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. Repaired by SCSD and sampled.
7. Fixture removed and replaced by SCSD.
8. Fixture repaired by SCSD.
9. Fixture removed by SCSD.

Notes [May 3, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031A
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70296569.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

Notes [May 30, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031A
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70299647.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.