

SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/21/23 RESULTS (ppb)	06/21/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/11/24 RE-SAMPLE RESULTS (ppb)	04/11/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/14/24 RE-SAMPLE RESULTS (ppb)	05/14/24 RE-SAMPLE ACTIONS
Rm. 113 - Classroom	Sink	Public Access	039	BT-S408	145.0	See Note 9.	---	---	---	---	---	---
Rm. 111 - Classroom	Sink	Public Access	004	BT-S412	3.7	None	---	---	---	---	---	---
Rm. 116 - Music Classroom	Fountain	Public Access	007	BT-F401	4.5	None	---	---	---	---	---	---
Rm. 110 - F.A.C.S Classroom	Sink	Public Access	003	BT-S411	1.3	None	---	---	---	---	---	---
Rm. 119 - Classroom	Sink	Public Access	009	BT-S417	11.3	See Note 9.	---	---	---	---	---	---
Rm. 120 - Hallway/Corridor	Fountain	Public Access	012	BT-F403	6.2	See Note 7.	006	<1.0	None	---	---	---
Rm. 120 - Hallway/Corridor	Fountain	Public Access	011	BT-F402	2.1	None	---	---	---	---	---	---
Rm. 202 - Social Worker Room	Sink	Public Access	030	BT-S324	<1.0	None	---	---	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	025	BT-S325	1.1	None	---	---	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	026	BT-S326	2.4	None	---	---	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	028	BT-S328	7.2	See Note 8.	004	6.9	See Note 6.	001	1.5	None
Rm. 204 - Health Center	Sink	Public Access	027	BT-S329	2.3	None	---	---	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	029	BT-S330	19.0	See Note 8.	003	10.4	See Note 6.	002	1.1	None
Rm. 206 - Nurse's Office	Sink	Public Access	022	BT-S331	<1.0	None	---	---	---	---	---	---
Rm. 206 - Nurse's Office	Sink	Public Access	023	BT-S332	2.0	None	---	---	---	---	---	---
Rm. 206 - Nurse's Office	Sink(Hose)	Public Access	024	BT-S332A	71.8	See Note 8.	005	47.5	See Note 6.	003	7.3	See Note 6.
Rm. 226 - Cafeteria	Fountain	Public Access	016	BT-F404	3.5	None	---	---	---	---	---	---
Kitchen	Sink (Faucet)	Secured - SCSD Staff Only	019	BT-S429	<1.0	None	---	---	---	---	---	---
Kitchen	Sink (Spray)	Secured - SCSD Staff Only	018	BT-S430	<1.0	None	---	---	---	---	---	---
Rm. 226A - Serving Room	Sink	Secured - SCSD Staff Only	017	BT-S428	<1.0	None	---	---	---	---	---	---
Kitchen	Convotherm	Secured - SCSD Staff Only	----	BT-C1000	---	See Note 6.	001	1.2	None	---	---	---
Rm. 100A - Hallway/Corridor	Fountain	Public Access	001	BT-F1000	<1.0	None	---	---	---	---	---	---
Rm. 108 - OT/PT	Sink	Public Access	002	BT-S1003	<1.0	None	---	---	---	---	---	---
Rm. 100C - Hallway/Corridor	Fountain	Public Access	006	BT-F1001	<1.0	None	---	---	---	---	---	---
Rm. 100C - Hallway/Corridor	Fountain	Public Access	005	BT-F1002	<1.0	None	---	---	---	---	---	---
Rm. 116 - Music Classroom	Sink	Public Access	008	BT-S2001	5.5	See Note 9.	---	---	---	---	---	---
Passageway	Sink	Public Access	010	BT-S1009	6.3	See Note 8.	007	2.8	None	---	---	---
Rm. 221 - Hallway/Corridor	Fountain	Public Access	020	BT-F1003	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Corridor	Fountain	Public Access	021	BT-F1004	<1.0	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/21/23 RESULTS (ppb)	06/21/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/11/24 RE-SAMPLE RESULTS (ppb)	04/11/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/14/24 RE-SAMPLE RESULTS (ppb)	05/14/24 RE-SAMPLE ACTIONS
Rm. 221 - Hallway/Corridor	Fountain	Public Access	015	BT-F1005	8.0	See Note 7.	002	<1.0	None	---	---	---
Rm. 221 - Hallway/Corridor	Fountain	Public Access	013	BT-F1006	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Corridor	Fountain	Public Access	014	BT-F1006A	<1.0	None	---	---	---	---	---	---
Rm. 318 - Hallway/Corridor	Fountain	Public Access	031	BT-F1007	<1.0	None	---	---	---	---	---	---
Rm. 318 - Hallway/Corridor	Fountain	Public Access	032	BT-F1008	<1.0	None	---	---	---	---	---	---
Rm. 318 - Hallway/Corridor	Fountain	Public Access	034	BT-F1009	<1.0	None	---	---	---	---	---	---
Rm. 318 - Hallway/Corridor	Fountain	Public Access	033	BT-F1010	<1.0	None	---	---	---	---	---	---
Rm. 423 - Hallway/Corridor	Fountain	Public Access	038	BT-F1011	<1.0	None	---	---	---	---	---	---
Rm. 423 - Hallway/Corridor	Fountain	Public Access	037	BT-F1012	<1.0	None	---	---	---	---	---	---
Rm. 423 - Hallway/Corridor	Fountain	Public Access	036	BT-F1013	<1.0	None	---	---	---	---	---	---
Rm. 423 - Hallway/Corridor	Fountain	Public Access	035	BT-F1014	<1.0	None	---	---	---	---	---	---
Gymnasium- Locker Room	Fountain	Public Access	----	BT-F3001	---	See Note 9.	---	---	---	---	---	---

Notes [June 21, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70260686.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture repaired by SCSD.
8. Fixture removed and replaced by SCSD.
9. Fixture removed by SCSD.

Notes [April 11, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 700293945.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL

Notes [May 14, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70297915.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.