

**SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/03/23 RESULTS (ppb)	10/03/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/19/24 RE-SAMPLE RESULTS (ppb)	04/19/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/14/24 RE-SAMPLE RESULTS (ppb)	05/14/24 RE-SAMPLE ACTIONS
Rm. 122 - Classroom	Sink	Public Access	003	ES-S103	<1.0	None	---	---	---	---	---	---
Rm. 124 - Classroom	Sink	Public Access	006	ES-S106	<1.0	None	---	---	---	---	---	---
Rm. 156 - Classroom	Sink	Public Access	023	ES-S137	<1.0	None	---	---	---	---	---	---
Rm. 158 - Classroom	Sink	Public Access	022	ES-S135	<1.0	None	---	---	---	---	---	---
Rm. 160 - Classroom	Sink	Public Access	021	ES-S136	<1.0	None	---	---	---	---	---	---
Rm. 104A - Work Room	Sink	Secured - SCSD Staff Only	---	ES-S150	---	See Note 6.	001	4.9	None	---	---	---
Rm. 124 - Toilet	Sink	Secured - SCSD Staff Only	005	ES-S105	1.5	None	---	---	---	---	---	---
Rm. 120 - Nurse's Office	Sink	Public Access	001	ES-S101	1.3	None	---	---	---	---	---	---
Rm. 133B - Copy Room	Sink	Secured - SCSD Staff Only	020	ES-S138	13.2	See Note 6.	002	<1.0	None	---	---	---
Rm. 127 - Kitchen	Sink- Faucet	Secured - SCSD Staff Only	012	ES-S123A	<1.0	None	---	---	---	---	---	---
Rm. 127 - Kitchen	Sink - Sprayer	Secured - SCSD Staff Only	013	ES-S123B	<1.0	None	---	---	---	---	---	---
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	011	ES-S124	1.0	None	---	---	---	---	---	---
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	048	ES-S125	5.6	See Note 6.	005	1.3	None	---	---	---
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	014	ES-S126	2.0	None	---	---	---	---	---	---
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	015	ES-S127	<1.0	None	---	---	---	---	---	---
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	016	ES-S128	3.4	None	---	---	---	---	---	---
Rm. 115 - Library Lounge	Sink	Secured - SCSD Staff Only	019	ES-S139	<1.0	None	---	---	---	---	---	---
Rm. 013 - Classroom	Sink	Public Access	029	ES-S141	37.3	See Note 6.	007	31.8	See Note 6.	---	---	---
Rm. 013 - Classroom	Sink	Public Access	028	ES-S142	8.1	See Note 6.	008	4.3	None	---	---	---
Rm. 114B - Toilet	Sink	Public Access	002	ES-S1015	<1.0	None	---	---	---	---	---	---
Rm. 154 - Girl's Toilet	Sink	Public Access	004	ES-S2004	1.5	None	---	---	---	---	---	---
Rm. 123 - Cafeteria	Fountain	Public Access	039	ES-F1000	<1.0	None	---	---	---	---	---	---
Rm. 123 - Cafeteria	Fountain	Public Access	038	ES-F1001	<1.0	None	---	---	---	---	---	---
Rm. 126F - Hallway/ Corridor	Fountain	Public Access	040	ES-F1002	<1.0	None	---	---	---	---	---	---
Rm. 126F - Hallway/ Corridor	Fountain	Public Access	041	ES-F1003	<1.0	None	---	---	---	---	---	---
Rm. 134 - Classroom	Sink	Public Access	010	ES-S1011	<1.0	None	---	---	---	---	---	---
Rm. 126D - Hallway/ Corridor	Fountain	Public Access	037	ES-F1004	<1.0	None	---	---	---	---	---	---
Rm. 126 - Classroom	Sink	Public Access	007	ES-S2002	<1.0	None	---	---	---	---	---	---
Rm. 126 - Toilet	Sink	Public Access	008	ES-S2003	<1.0	None	---	---	---	---	---	---
Rm. 130/132 - ADA Toilet	Sink	Public Access	009	ES-S1012	<1.0	None	---	---	---	---	---	---
Rm. 126B - Hallway/ Corridor	Fountain	Public Access	036	ES-F1005	<1.0	None	---	---	---	---	---	---
Rm. 230 - Gym	Fountain	Public Access	047	ES-F1009	<1.0	None	---	---	---	---	---	---
Rm. 126B - Hallway/ Corridor	Fountain	Public Access	035	ES-F1006	<1.0	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/03/23 RESULTS (ppb)	10/03/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/19/24 RE-SAMPLE RESULTS (ppb)	04/19/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/14/24 RE-SAMPLE RESULTS (ppb)	05/14/24 RE-SAMPLE ACTIONS
Rm. 230 - Gym	Fountain	Public Access	046	ES-F1010	<1.0	None	---	---	---	---	---	---
Rm. 219A - Hallway/ Corridor	Fountain	Public Access	032	ES-F1011	<1.0	None	---	---	---	---	---	---
Rm. 216 - Hallway/ Corridor	Fountain	Public Access	033	ES-F1007	<1.0	None	---	---	---	---	---	---
Rm. 216 - Hallway/ Corridor	Fountain	Public Access	034	ES-F1008	<1.0	None	---	---	---	---	---	---
Rm. 002B - Technology Shop	Sink	Public Access	030	ES-S1035	<1.0	None	---	---	---	---	---	---
Rm. 012 - Hallway/ Corridor	Fountain	Public Access	045	ES-F1012	<1.0	None	---	---	---	---	---	---
Rm. 017 - Home & Careers	Sink	Public Access	027	ES-S1036	<1.0	None	---	---	---	---	---	---
Rm. 017 - Home & Careers	Sink	Public Access	025	ES-S1037	7.5	See Note 7.	006	2.5	None	---	---	---
Rm. 020 - Conference Room	Sink	Secured - SCSD Staff Only	031	ES-S2005	3.4	None	---	---	---	---	---	---
Rm. 127 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	017	ES-C1000	38.2	See Note 7.	003	32.5	See Note 7.	001	26.7	See Note 6.
Rm. 127 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	---	ES-C1000A	---	---	---	---	---	002	4.1	None
Rm. 127 - Kitchen	Combitherm Oven	Secured - SCSD Staff Only	---	ES-C1001	---	---	004	<1.0	None	---	---	---
Rm. 017 - Home & Careers	Sink (Spray)	Public Access	024	ES-S3000	1.2	None	---	---	---	---	---	---
Rm. 017 - Home & Careers	Sink (Spray)	Public Access	026	ES-S3001	<1.0	None	---	---	---	---	---	---
Hallway/ Corridor	Fountain	Public Access	042	ES-F2000	<1.0	None	---	---	---	---	---	---
Hallway/ Corridor	Fountain	Public Access	043	ES-F2000A	<1.0	None	---	---	---	---	---	---
Rm. 012 - Hallway/ Corridor	Fountain	Public Access	044	ES-F3002	<1.0	None	---	---	---	---	---	---

Notes: [October 3, 2023 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-010
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70272791.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

Notes: [April 19, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-010
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70294976.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.
7. Fixture repaired by SCSD.

SYRACUSE CITY SCHOOL DISTRICT ED SMITH PK - GRADE 8 SCHOOL

Notes: [May 14, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-010
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70297918.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.