

**SYRACUSE CITY SCHOOL DISTRICT
SALEM-HYDE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/15/23 RESULTS (ppb)	06/15/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/03/24 RE-SAMPLE RESULTS (ppb)	04/03/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/10/24 RE-SAMPLE RESULTS (ppb)	05/10/24 RE-SAMPLE ACTIONS
Rm. 004 - Gym Office	Sink	Secured - SCSD Staff Only	003	SH-S100	5.7	See Note 7.	001	3.4	None	---	---	---
Rm. 012 - Cafeteria	Fountain	Public Access	009	SH-F100	<1.0	None	---	---	---	---	---	---
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	004	SH-S104	1.7	None	---	---	---	---	---	---
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	005	SH-S105	2.2	None	---	---	---	---	---	---
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	006	SH-S106	1.2	None	---	---	---	---	---	---
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	007	SH-S107	<1.0	None	---	---	---	---	---	---
Rm. 022 - Kitchen	Kitchen Equipment	Secured - SCSD Staff Only	008	SH-S400	<1.0	None	---	---	---	---	---	---
Rm. 218 - Classroom	Fountain	Public Access	010	SH-F101	2.2	None	---	---	---	---	---	---
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	012	SH-S110	<1.0	None	---	---	---	---	---	---
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	013	SH-S111	<1.0	None	---	---	---	---	---	---
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	014	SH-S112	<1.0	None	---	---	---	---	---	---
Rm. 224A - Hallway/Vestibule	Fountain	Public Access	015	SH-F102	1.1	None	---	---	---	---	---	---
Rm. 224 - Hallway/Corridor	Fountain	Public Access	016	SH-F103	<1.0	None	---	---	---	---	---	---
Rm. 025 - Hallway/Corridor	Fountain	Public Access	001	SH-F200	<1.0	None	---	---	---	---	---	---
Rm. 025 - Hallway/Corridor	Fountain	Public Access	002	SH-F200A	<1.0	None	---	---	---	---	---	---
Rm. 101 - Classroom	Fountain	Public Access	022	SH-F201	4.5	None	---	---	---	---	---	---
Rm. 119B - Classroom Bathroom	Sink	Public Access	039	SH-S202	1.5	None	---	---	---	---	---	---
Rm. 101A - Classroom Bathroom	Sink	Public Access	021	SH-S203	3.4	None	---	---	---	---	---	---
Rm. 120 - Classroom	Fountain	Public Access	020	SH-F202	6.8	See Note 6.	003	255	See Note 6.	001	48.2	See Note 6.
Rm. 102 - Classroom	Sink	Public Access	026	SH-S205	1.4	None	---	---	---	---	---	---
Rm. 102 - Classroom	Fountain	Public Access	---	SH-F203	---	See Note 6.	002	10.1	See Note 6.	002	11.6	See Note 6.
Rm. 102A - Classroom Bathroom	Sink	Public Access	027	SH-S206	2.2	None	---	---	---	---	---	---
Rm. 105A - Exam Room	Sink	Public Access	037	SH-S211	<1.0	None	---	---	---	---	---	---
Rm. 109 - Classroom	Fountain	Public Access	030	SH-F204	<1.0	None	---	---	---	---	---	---
Rm. 109A - Classroom Bathroom	Sink	Public Access	031	SH-S215	1.8	None	---	---	---	---	---	---
Rm. 110 - Classroom	Sink	Public Access	019	SH-S216	<1.0	None	---	---	---	---	---	---
Rm. 110 - Classroom	Fountain	Public Access	028	SH-F205	<1.0	None	---	---	---	---	---	---
Rm. 111 - Classroom	Fountain	Public Access	018	SH-F206	1.3	None	---	---	---	---	---	---
Rm. 111A - Classroom Bathroom	Sink	Public Access	017	SH-S219	<1.0	None	---	---	---	---	---	---
Rm. 112 - Classroom	Fountain	Public Access	029	SH-F207	<1.0	None	---	---	---	---	---	---
Rm. 113 - Classroom	Fountain	Public Access	032	SH-F208	<1.0	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
SALEM-HYDE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/15/23 RESULTS (ppb)	06/15/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/03/24 RE-SAMPLE RESULTS (ppb)	04/03/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/10/24 RE-SAMPLE RESULTS (ppb)	05/10/24 RE-SAMPLE ACTIONS
Rm. 131 - Hallway/Vestibule	Fountain	Public Access	032	SH-F209	<1.0	None	---	---	---	---	---	---
Rm. 131 - Hallway/Vestibule	Sink	Public Access	034	SH-S224	<1.0	None	---	---	---	---	---	---
Rm. 131 - Hallway/Vestibule	Sink	Public Access	035	SH-S225	<1.0	None	---	---	---	---	---	---
Rm. 131 - Hallway/Vestibule	Sink	Public Access	036	SH-S226	1.1	None	---	---	---	---	---	---
Rm. 115B - Work Room	Sink	Secured -SCSD Staff Only	038	SH-S227	<1.0	None	---	---	---	---	---	---
Rm. 119 - Classroom	Fountain	Public Access	025	SH-F210	4.5	None	---	---	---	---	---	---
Rm. 119 - Classroom	Sink	Public Access	023	SH-S228	2.1	None	---	---	---	---	---	---
Rm. 119A - Classroom Bathroom	Sink	Public Access	024	SH-S229	<1.0	None	---	---	---	---	---	---
Rm. 223 - Hallway/Corridor	Fountain	Public Access	011	SH-F400	<1.0	None	---	---	---	---	---	---

Notes [June 15, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70260017.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed and replaced by SCSD.

Notes [April 3, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70292833.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

SYRACUSE CITY SCHOOL DISTRICT SALEM-HYDE ELEMENTARY SCHOOL

Notes [May 10, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70297481.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.