

SYRACUSE CITY SCHOOL DISTRICT  
GRANT MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/22/23 RESULTS (ppb)	12/22/23 ACTIONS	LAB SAMPLE I.D. No.	05/17/24 RE-SAMPLE RESULTS (ppb)	05/17/24 RE- SAMPLE ACTIONS	LAB SAMPLE I.D. No.	06/21/24 RE-SAMPLE RESULTS (ppb)	06/21/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. B-18 - Boy's Locker Room Bathroom	Fountain	Public Access	047	GT-F201	10.1	See Note 6.	001	6.5	See Note 6.	---	---	---	---	---	---
Rm. 108B - Exam Room	Sink	Public Access	024	GT-S217	2.7	None	--	--	---	---	---	---	---	---	---
Rm. 109 - Nurse's Office	Sink	Public Access	025	GT-S218	2.5	None	--	--	---	---	---	---	---	---	---
Rm. 110 - Classroom	Sink	Public Access	023	GT-S220	8.8	See Note 7.	011	7.7	See Note 6.	--	--	--	---	--	--
Rm. 115 - Music Room	Sink	Public Access	068	GT-S226	26.0	See Note 6.	009	27.9	See Note 7.	005	4.4	None	---	---	---
Rm. 123 - Work Room	Sink	Secured - SCSD Staff Only	046	GT-S221	1.2	None	--	--	---	---	---	---	---	---	---
Rm. 131 - Serving Room	Sink	Secured - SCSD Staff Only	072	GT-S212	1.4	None	--	--	--	--	--	--	--	--	--
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	057	GT-S109	1.4	None	--	--	--	--	--	--	--	--	--
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	053	GT-S112	1.2	None	--	--	--	--	--	--	--	--	--
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	052	GT-S113	1.7	None	--	--	--	--	--	--	--	--	--
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	058	GT-S114	3.8	None	--	--	--	--	--	--	--	--	--
Rm. 132B - Dental Office	Sink	Public Access	056	GT-S115	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 132F - Examination Room	Sink	Public Access	054	GT-S111	3.2	None	--	--	--	--	--	--	--	--	--
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	077	GT-S206	2.3	None	--	--	--	--	--	--	--	--	--
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	076	GT-S207	9.8	See Note 7.	008	9.7	See Note 8.	003	5.4	See Note 6.	001	2.9	None
Rm. 133A - Kitchen	Sink (spray nozzle)	Secured - SCSD Staff Only	073	GT-S208	<1.0	None	--	--	--	--	--	--	---	--	--
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	074	GT-S209	<1.0	None	--	--	--	--	--	--	---	--	--
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	075	GT-S210	1.5	None	--	--	--	--	--	--	---	--	--
Rm. 140B - Swimming Pool Office	Sink	Secured - SCSD Staff Only	049	GT-S119	7.9	See Note 6.	014	11.9	See Note 9.	--	--	--	--	--	--
Rm. 151 - Hallway/Vestibule	Fountain	Public Access	064	GT-F100	1.1	None	--	--	--	--	--	--	--	--	--
Rm. 151 - Hallway/Vestibule	Sink	Public Access	066	GT-S101	2.3	None	--	--	--	--	--	--	--	--	--
Rm. 169 - Work Room	Sink	Secured - SCSD Staff Only	027	GT-S224	6.2	See Note 7.	010	11.0	See Note 9.	--	--	--	--	--	--
Rm. 170 - Audio/Video Storage	Sink	Secured - SCSD Staff Only	026	GT-S225	1.3	None	--	--	--	--	--	--	--	--	--
Rm. 182 - Classroom	Sink	Public Access	082	GT-S103	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 182A - Nurse's Waiting Room	Sink	Public Access	081	GT-S106	1.2	None	--	--	--	--	--	--	--	--	--
Rm. 182B - Classroom Office	Sink	Public Access	062	GT-S104	2.1	None	--	--	--	--	--	--	--	--	--
Rm. 182D - Examination Room	Sink	Public Access	059	GT-S108	1.3	None	--	--	--	--	--	--	---	--	--
Rm. 184 - Swimming Pool	Fountain	Public Access	048	GT-F101	14.4	See Note 6.	013	8.9	See Note 6.	--	--	--	---	--	--

SYRACUSE CITY SCHOOL DISTRICT  
GRANT MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/22/23 RESULTS (ppb)	12/22/23 ACTIONS	LAB SAMPLE I.D. No.	05/17/24 RE-SAMPLE RESULTS (ppb)	05/17/24 RE- SAMPLE ACTIONS	LAB SAMPLE I.D. No.	06/21/24 RE-SAMPLE RESULTS (ppb)	06/21/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. 182G - Sick/Rest Waiting Room	Sink	Public Access	061	GT-S105	1.3	None	--	--	--	--	--	--	--	--	--
Rm. 185C - Office	Sink	Secured - SCSD Staff Only	067	GT-S102	3.1	None	--	--	--	--	--	--	--	--	--
Rm. 203 - Classroom	Sink	Public Access	018	GT-S124	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 212 - Girl's Coach Office	Sink	Secured - SCSD Staff Only	015	GT-S129	12.7	See Note 6.	005	2.8	None	--	--	--	--	--	--
Rm. 227 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	006	GT-S142	1.2	None	--	--	--	--	--	--	--	--	--
Rm. 270 - Hallway/Vestibule	Fountain	Public Access	012	GT-F102	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 294 - Home & Careers Room	Sink	Public Access	020	GT-S125	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 294 - Home & Careers Room	Sink	Public Access	019	GT-S126	5.7	See Note 7.	004	8.2	See Note 6.	--	--	--	--	--	--
Rm. 296 - Home & Careers Room	Sink	Public Access	017	GT-S120	10.7	See Note 7.	003	10.5	See Note 6.	--	--	--	--	--	--
Rm. 296 - Home & Careers Room	Sink	Public Access	---	GT-S121	---	See Note 9.	--	--	See Note 6.	--	--	--	--	--	--
Rm. 296 - Home & Careers Room	Sink	Public Access	016	GT-S122	1.6	None	--	--	--	--	--	--	--	--	--
Rm. 131 - Serving Room	Ice Machine	Secured - SCSD Staff Only	083	GT-S1000	<1.0	None	012	<1.0	None	--	--	--	--	--	--
Rm. 152 - Vestibule	Fountain	Public Access	071	GT-F1000	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 152 - Vestibule	Sink	Public Access	069	GT-S1001	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 152 - Vestibule	Sink	Public Access	070	GT-S1002	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 120 - Hallway/ Corridor	Fountain	Public Access	021	GT-F1001	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 120 - Hallway/ Corridor	Fountain	Public Access	022	GT-F1002	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 139 - Hallway/ Corridor	Fountain	Public Access	043	GT-F1003	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 139 - Hallway/ Corridor	Fountain	Public Access	044	GT-F1003A	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 139 - Hallway/ Corridor	Fountain	Public Access	045	GT-F1004	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 151 - Vestibule	Sink	Public Access	065	GT-S1014	1.2	None	--	--	--	--	--	--	--	--	--
Rm. 218 - Hallway/ Corridor	Fountain	Public Access	001	GT-F1005	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 218 - Hallway/ Corridor	Fountain	Public Access	---	GT-F1006	---	See Note 8.	--	--	See Note 7.	001	<1.0	None	---	---	---
Rm. 262 - Vestibule	Sink	Public Access	039	GT-S1016	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 262 - Vestibule	Sink	Public Access	040	GT-S1017	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 262 - Vestibule	Fountain	Public Access	038	GT-F1007	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 208 - Hallway/ Corridor	Fountain	Public Access	004	GT-F1008	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 208 - Hallway/ Corridor	Fountain	Public Access	005	GT-F1009	<1.0	None	--	--	--	--	--	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT  
GRANT MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/22/23 RESULTS (ppb)	12/22/23 ACTIONS	LAB SAMPLE I.D. No.	05/17/24 RE-SAMPLE RESULTS (ppb)	05/17/24 RE- SAMPLE ACTIONS	LAB SAMPLE I.D. No.	06/21/24 RE-SAMPLE RESULTS (ppb)	06/21/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. 255 - Hallway/ Corridor	Fountain	Public Access	002	GT-F1010	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 255 - Hallway/ Corridor	Fountain	Public Access	003	GT-F1011	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 211 - Girl's Lockerroom	Sink	Public Access	013	GT-S1027	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 211 - Girl's Lockerroom	Sink	Public Access	014	GT-S1028	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 220 - Boy's Lockerroom	Sink	Public Access	009	GT-S1029	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 220 - Boy's Lockerroom	Sink	Public Access	008	GT-S1030	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 271 - Vestibule	Fountain	Public Access	011	GT-F1012	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 210 - Hallway/ Corridor	Fountain	Public Access	007	GT-F1013	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 315 - Hallway/ Corridor	Fountain	Public Access	030	GT-F1014	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 133A - Kitchen	Sink	Public Access	078	GT-S3000	5.5	See Note 7.	006	6.2	See Note 8.	002	3.7	None	---	---	---
Rm. 315 - Hallway/ Corridor	Fountain	Public Access	031	GT-F1015	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 347 - Vestibule	Sink	Public Access	033	GT-S1034	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 347 - Vestibule	Sink	Public Access	034	GT-S1035	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 347 - Vestibule	Fountain	Public Access	032	GT-F1016	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 308 - Hallway/ Corridor	Fountain	Public Access	035	GT-F1018	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 308 - Hallway/ Corridor	Fountain	Public Access	---	GT-F1017	---	See Note 8.	002	<1.0	None	--	--	--	--	--	--
Rm. 326 - Hallway/ Corridor	Fountain	Public Access	036	GT-F1019	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 326 - Hallway/ Corridor	Fountain	Public Access	037	GT-F1020	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 140E - Boy's Locker Room Bathroom	Sink	Public Access	051	GT-S1044	<1.0	None	--	--	--	--	--	--	--	--	--
Rm. 137 - Girls Locker Room Bathroom	Sink	Public Access	042	GT-S1045	1.6	None	--	--	--	--	--	--	--	--	--
Rm. 184 - Swimming Pool	Fountain	Public Access	050	GT-F1021	1.5	None	--	--	--	--	--	--	--	--	--
Rm. 372 - Art Room	Sink	Public Access	028	GT-S5000	1.5	None	--	--	--	--	--	--	--	--	--
Rm. 372 - Art Room	Sink	Public Access	029	GT-S5001	3.0	None	--	--	--	--	--	--	--	--	---
Rm. 133A - Kitchen	Convotherm (Oven)	Secured - SCSD Staff Only	079	GT-C1000	11.4	See Note 7.	007	7.2	See Note 7.	004	5.1	See Note 6.	002	3.5	None
Rm. 133A - Kitchen	Convotherm (Oven)	Secured - SCSD Staff Only	080	GT-C1001	1.4	None	--	--	--	--	--	--	--	--	--
Rm. 181 - Classroom	Sink	Public Access	063	GT-S3004	1.2	None	--	--	--	--	--	--	--	--	--
Rm. 238 - Classroom	Sink	Public Access	041	GT-S136A	3.9	None	--	--	--	--	--	--	--	--	--
Rm. 273 - Boy's Bathroom	Sink	Public Access	010	GT-S1031	3.5	None	--	--	--	--	--	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
GRANT MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	12/22/23 RESULTS (ppb)	12/22/23 ACTIONS	LAB SAMPLE I.D. No.	05/17/24 RE-SAMPLE RESULTS (ppb)	05/17/24 RE- SAMPLE ACTIONS	LAB SAMPLE I.D. No.	06/21/24 RE-SAMPLE RESULTS (ppb)	06/21/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. 132G - Medical Assistance Bathroom	Sink	Public Access	055	GT-S110	<1.0	None	--	--	--	--	--	--	---	--	--
Rm. 182E - Bathroom	Sink	Public Access	060	GT-S107	<1.0	None	--	--	--	--	--	--	---	--	--

Notes [December 22, 2023 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70282363.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture replaced by SCSD.
7. Fixture repaired by SCSD.
8. Fixture inoperative. SCSD to evaluate for repair or removal.
9. Fixture not accessible.

Notes [May 17, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70298418
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.
7. Fixture repaired by SCSD.
8. Fixture removed and replaced by SCSD.
9. Fixture signed by SCSD. No further action required.

Notes [June 21, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70302477
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

Notes [September 18, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70314321
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

