

SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	03/05/24 RESULT S (ppb)	03/05/24 ORIGINAL ACTIONS	LAB RE- SAMPLE I.D. No.	05/01/24 RE- SAMPLE RESULTS (ppb)	05/01/24 RE- SAMPLE ACTIONS	LAB RE- SAMPLE I.D. No.	06/26/24 RE- SAMPLE RESULTS (ppb)	06/26/24 RE- SAMPLE ACTIONS	LAB RE- SAMPLE I.D. No.	08/14/24 RE- SAMPLE RESULTS (ppb)	08/14/24 RE- SAMPLE ACTIONS
Rm. 008 - Classroom	Sink	Public Access	015	HR-S509 A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 008 - Classroom	Sink	Public Access	016	HR-S509 B	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 008 - Classroom	Sink	Public Access	017	HR-S509 C	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 017 - Storage Room	Sink	Secured - SCSD Staff Only	026	HR-S511	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 044 - Hallway/Corridor	Fountain	Public Access	022	HR-F504	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 044 - Hallway/Corridor	Fountain	Public Access	023	HR-F504 A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 044 - Hallway/Corridor	Fountain	Public Access	020	HR-F505 A	1.1	None	---	---	---	---	---	---	---	---	---
Rm. 044 - Hallway/Corridor	Fountain	Public Access	021	HR-F505	1.1	None	---	---	---	---	---	---	---	---	---
Rm. Rm. 047A - Hallway/Vestibule	Fountain	Public Access	019	HR-F503 A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. Rm. 047A - Hallway/Vestibule	Fountain	Public Access	018	HR-F503	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 047B - Hallway/Vestibule	Fountain	Public Access	025	HR-F501 A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 047B - Hallway/Vestibule	Fountain	Public Access	024	HR-F501	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 051 - Hallway/Corridor	Fountain	Public Access	---	HR-F502	---	See Note 6.	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	043	HR-S132	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 071A - Hallway/Corridor	Fountain	Public Access	066	HR-F108	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 071A - Hallway/Corridor	Fountain	Public Access	065	HR-F108 A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 103 - Classroom	Sink	Public Access	067	HR-S145	1.6	None	---	---	---	---	---	---	---	---	---
Rm. 103 - Classroom	Sink	Public Access	068	HR-S146	7.0	See Note 7.	004	6.9	See Note 6.	001	11.4	See Note 6.	001	<1.0	None
Rm. 103 - Classroom	Sink	Public Access	069	HR-S147	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 103 - Classroom	Sink	Public Access	070	HR-S148	2.3	None	---	---	---	---	---	---	---	---	---
Rm. 103A - Work Area	Sink	Public Access	---	HR-S143	---	See Note 8.	005	60.0	See Note 6.	002	3.1	None	---	---	---
Rm. 104 - Home & Careers Room	Sink	Public Access	062	HR-S140	2.7	None	---	---	---	---	---	---	---	---	---
Rm. 104 - Home & Careers Room	Sink	Public Access	064	HR-S141	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 104 - Home & Careers Room	Sink	Public Access	063	HR-S142	1.0	None	---	---	---	---	---	---	---	---	---
Rm. 132 - Hallway/Corridor	Fountain	Public Access	077	HR-F100	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 132 - Hallway/Corridor	Fountain	Public Access	078	HR-F101	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 149 - Health Service Room	Sink	Public Access	076	HR-S121	2.5	None	---	---	---	---	---	---	---	---	---
Rm. 163 - Hallway/Corridor	Fountain	Public Access	061	HR-F104	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 163 - Hallway/Corridor	Fountain	Public Access	060	HR-F104 A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 163 - Hallway/Corridor	Fountain	Public Access	058	HR-F105	<1.0	None	---	---	---	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	03/05/24 RESULT S (ppb)	03/05/24 ORIGINAL ACTIONS	LAB RE- SAMPLE I.D. No.	05/01/24 RE- SAMPLE RESULTS (ppb)	05/01/24 RE- SAMPLE ACTIONS	LAB RE- SAMPLE I.D. No.	06/26/24 RE- SAMPLE RESULTS (ppb)	06/26/24 RE- SAMPLE ACTIONS	LAB RE- SAMPLE I.D. No.	08/14/24 RE- SAMPLE RESULTS (ppb)	08/14/24 RE- SAMPLE ACTIONS
Rm. 163 - Hallway/Corridor	Fountain	Public Access	059	HR-F105 A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 190 - Hallway/Corridor	Fountain	Public Access	074	HR-F102	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 190 - Hallway/Corridor	Fountain	Public Access	075	HR-F103	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 205 - Classroom	Sink	Public Access	006	HR-S225	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 212 - Classroom	Sink	Public Access	009	HR-S226	5.9	See Note 7.	006	7.5	See Note 7.	---	---	---	---	---	---
Rm. 213 - Classroom	Sink	Public Access	---	HR-S222	---	See Note 9.	007	28.3	See Note 7.	---	---	---	---	---	---
Rm. 226C - Hallway/Corridor	Fountain	Public Access	008	HR-F523	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 240 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	005	HR-S209	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 259 - Hallway/Corridor	Fountain	Public Access	003	HR-F205	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 259 - Hallway/Corridor	Fountain	Public Access	004	HR-F206	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. N-42 - Pool	Fountain	Public Access	---	HR-F202	---	See Note 6.	---	---	---	---	---	---	---	---	---
Rm. 263 - Hallway/Corridor	Fountain	Public Access	001	HR-F4000	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 263 - Hallway/Corridor	Fountain	Public Access	002	HR-F4001	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 227 - Hallway/Corridor	Fountain	Public Access	003	HR-F4002	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. N-04 - Hallway/Corridor	Fountain	Public Access	010	HR-F2004	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. N-04 - Hallway/Corridor	Fountain	Public Access	011	HR-F2003	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. N-35 - Hallway/Corridor	Fountain	Public Access	012	HR-F2000	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. N-35 - Hallway/Corridor	Fountain	Public Access	013	HR-F2001	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Ice Machine	Secured - SCSD Staff Only	027	HR-S5000ABC	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	028	HR-S1000	1.9	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	029	HR-S1001	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	030	HR-S1002	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	031	HR-S1003	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	032	HR-S1004	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	033	HR-S1005	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Sink	Secured - SCSD Staff Only	034	HR-S1006	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Fountain	Public Access	035	HR-F1001	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Fountain	Public Access	036	HR-F1001A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 001 - Lower Cafeteria	Fountain	Public Access	037	HR-F1000	<1.0	None	---	---	---	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	03/05/24 RESULT S (ppb)	03/05/24 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	05/01/24 RE-SAMPLE RESULTS (ppb)	05/01/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/26/24 RE-SAMPLE RESULTS (ppb)	06/26/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	08/14/24 RE-SAMPLE RESULTS (ppb)	08/14/24 RE-SAMPLE ACTIONS
Rm. 069 - Upper Cafeteria	Fountain	Public Access	038	HR-F3000A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 069 - Upper Cafeteria	Fountain	Public Access	039	HR-F3000	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 069 - Upper Cafeteria	Fountain	Public Access	040	HR-F3001A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 069 - Upper Cafeteria	Fountain	Public Access	041	HR-F3001	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	056	HR-S3002	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	057	HR-S3000	2.3	None	---	---	---	---	---	---	---	---	---
Rm. 155 - Classroom	Sink	Public Access	071	HR-S3013	4.2	None	---	---	---	---	---	---	---	---	---
Rm. 161 - Hallway/Corridor	Fountain	Public Access	072	HR-F3002	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 161 - Hallway/Corridor	Fountain	Public Access	073	HR-F3003	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	042	HR-S3009	1.7	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	044	HR-S3012	1.5	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	045	HR-S3010	1.6	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	046	HR-S3011	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	047	HR-S3008A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	048	HR-S3008	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	049	HR-S3007	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	050	HR-S3007A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	051	HR-S3005	1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	052	HR-S3003	1.9	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	053	HR-S3004	1.2	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	054	HR-S3006	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	055	HR-S3001	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 068 - Kitchen	Convotherm	Secured - SCSD Staff Only	---	HR-C3002	---	See Note 8.	001	4.9	None	---	---	---	---	---	---
Rm. 068 - Kitchen	Convotherm	Secured - SCSD Staff Only	---	HR-C3001	---	---	002	<1.0	None	---	---	---	---	---	---
Rm. 068 - Kitchen	Convotherm	Secured - SCSD Staff Only	---	HR-C3000	---	---	003	<1.0	None	---	---	---	---	---	---

Field House

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/13/24 RESULT S (ppb)	06/13/24 ORIGINAL ACTIONS									
Field House - Concession Stand	Sink	Public Access	1	HFH-S157	1.1	None	---	---	---	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT HENNINGER HIGH SCHOOL

Notes (March 5, 2024 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70289476.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. Removed from service by SCSD.
7. Fixture repaired by SCSD.
8. Fixture inoperative. Repaired by SCSD.
9. Fixture inaccessible. Access restored by SCSD.

Notes (May 1, 2024 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70296231.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed and replaced by SCSD.
7. Fixture signed by SCSD. No further action required.

Notes (June 13, 2024 Event - Field House):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70301439.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Notes (June 26, 2024 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70303080.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

Notes (August 14, 2024 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70309136.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.