

SYRACUSE CITY SCHOOL DISTRICT  
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/13/23 RESULTS (ppb)	10/13/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/18/24 RE-SAMPLE RESULTS (ppb)	01/18/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	04/19/24 RE-SAMPLE RESULTS (ppb)	04/19/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/14/24 RE-SAMPLE RESULTS (ppb)	05/14/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/21/24 RE-SAMPLE RESULTS (ppb)	06/21/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. 002 - Music Room	Sink	Public Access	036	HS-S102	1.3	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 002 - Music Room	Fountain	Public Access	035	HS-F101	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 003 - Classroom	Sink	Public Access	034	HS-S104	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 003 - Classroom	Fountain	Public Access	033	HS-F103	30.6	See Note 7.	003	1.7	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 004 - Classroom	Sink	Public Access	031	HS-S103	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 004 - Classroom	Fountain	Public Access	032	HS-F102	1.6	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 007 - Home & Careers Room	Sink	Public Access	001	HS-S106	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 007 - Home & Careers Room	Sink	Public Access	002	HS-S107	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 008 - Classroom	Fountain	Public Access	003	HS-F104	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 009 - Classroom	Fountain	Public Access	004	HS-F105	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 010 - Classroom	Sink	Public Access	006	HS-S110	1.2	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 010 - Classroom	Fountain	Public Access	005	HS-F106	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 011 - Classroom	Sink	Public Access	008	HS-S111	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 011 - Classroom	Fountain	Public Access	007	HS-F107	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 012 - Classroom	Sink	Public Access	010	HS-S112	1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 012 - Classroom	Fountain	Public Access	009	HS-F108	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 013 - Classroom	Sink	Public Access	030	HS-S113	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 013 - Classroom	Fountain	Public Access	029	HS-F109	1.1	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 024 - Hallway/Corridor	Fountain	Public Access	057	HS-F114	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 024 - Hallway/Corridor	Fountain	Public Access	056	HS-F120	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 024 - Hallway/Corridor	Fountain	Public Access	055	HS-F120A	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT  
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/13/23 RESULTS (ppb)	10/13/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/18/24 RE-SAMPLE RESULTS (ppb)	01/18/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	04/19/24 RE-SAMPLE RESULTS (ppb)	04/19/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/14/24 RE-SAMPLE RESULTS (ppb)	05/14/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/21/24 RE-SAMPLE RESULTS (ppb)	06/21/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. 037C - Hallway/Corridor	Fountain	Public Access	037	HS-F100	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 050 - Hallway/Corridor	Fountain	Public Access	038	HS-F115	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 051 - Hallway/Corridor	Fountain	Public Access	052	HS-F119	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	011	HS-S162	1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	012	HS-S163	2.1	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	013	HS-S164	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	014	HS-S165	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 103X - Classroom	Sink	Public Access	018	HS-S114	1.2	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 106 - Classroom	Sink	Public Access	019	HS-S115	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 106 - Classroom	Fountain	Public Access	020	HS-F110	1.1	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 107 - Classroom	Sink	Public Access	021	HS-S116	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 108 - Classroom	Sink	Public Access	022	HS-S117	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 108 - Classroom	Fountain	Public Access	023	HS-F111	1.1	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 109 - Classroom	Sink	Public Access	024	HS-S118	1.7	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 109 - Classroom	Fountain	Public Access	025	HS-F112	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 110 - Classroom	Sink	Public Access	026	HS-S119	1.2	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 110 - Classroom	Fountain	Public Access	027	HS-F113	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 113 - Audiologist's Room	Sink	Public Access	059	HS-S121	5.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 114 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	058	HS-S122	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 123 - Classroom	Sink	Public Access	039	HS-S137	1.4	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 123 - Classroom	Sink	Public Access	041	HS-S138	5.5	See Note 7.	004	6.1	See Note 6.	002	4.4	None	---	---	---	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT  
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/13/23 RESULTS (ppb)	10/13/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/18/24 RE-SAMPLE RESULTS (ppb)	01/18/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	04/19/24 RE-SAMPLE RESULTS (ppb)	04/19/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/14/24 RE-SAMPLE RESULTS (ppb)	05/14/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/21/24 RE-SAMPLE RESULTS (ppb)	06/21/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. 123 - Classroom	Fountain	Public Access	040	HS-F118	1.2	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 124 - Classroom	Sink	Public Access	042	HS-S135	2.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 125 - Classroom	Sink	Public Access	045	HS-S133	2.9	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 125 - Classroom	Sink	Public Access	044	HS-S134	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 125 - Classroom	Fountain	Public Access	043	HS-F117	2.2	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 126 - Classroom	Sink	Public Access	048	HS-S131	3.9	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 126 - Classroom	Sink	Public Access	047	HS-S132	1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 126 - Classroom	Fountain	Public Access	046	HS-F116	18.6	See Note 7.	005	3.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 127 - Classroom	Sink	Public Access	050	HS-S129	1.9	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 127 - Classroom	Sink	Public Access	049	HS-S130	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 129 - Art Room	Sink	Public Access	---	HS-S140	---	See Note	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 129 - Art Room	Sink	Public Access	051	HS-S141	8.1	See Note 7.	009	4.6	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 137D - Hallway/Corridor	Fountain	Public Access	016	HS-F121	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 137D - Hallway/Corridor	Fountain	Public Access	017	HS-F121A	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 141 - Kitchen	Sink	Secured - SCSD Staff Only	053	HS-S148	2.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 141 - Kitchen	Sink	Secured - SCSD Staff Only	054	HS-S149	1.2	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm 142D - Main Office	Sink	Secured - SCSD Staff Only	---	HS-S152	See Note 6.	---	008	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 144 - Nurse's Office	Sink	Public Access	---	HS-S155	See Note 6.	---	006	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 144D - Exam Room	Sink	Public Access	---	HS-S153	See Note 6.	---	007	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 209 - Classroom	Sink	Public Access	062	HS-S171	1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 209 - Classroom	Fountain	Public Access	063	HS-F124	1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT  
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/13/23 RESULTS (ppb)	10/13/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/18/24 RE-SAMPLE RESULTS (ppb)	01/18/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	04/19/24 RE-SAMPLE RESULTS (ppb)	04/19/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/14/24 RE-SAMPLE RESULTS (ppb)	05/14/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/21/24 RE-SAMPLE RESULTS (ppb)	06/21/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. 211 - Classroom	Sink	Public Access	061	HS-S172	2.3	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 211 - Classroom	Fountain	Public Access	060	HS-F125	3.8	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 213A - Hallway/Corridor	Fountain	Public Access	028	HS-F122	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 213B - Hallway/Corridor	Fountain	Public Access	065	HS-F123	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 213B - Hallway/Corridor	Fountain	Public Access	064	HS-F123A	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Rm. 103 - Kitchen	Upstream Sample Port	Secured - SCSD Staff Only	---	HS-S3000A	---	---	---	---	---	---	---	---	002	6.6	---	002	3.9	None	002	5.1	See Note 6.
Rm. 103 - Kitchen	Convothorm Oven	Secured - SCSD Staff Only	015	HS-S3000	23.5	See Note 7.	001	12.1	See Note 7.	001	7.9	See Note 6.	001	6.3	See Note 6.	001	5.4	See Note 6.	001	19.9	See Note 6.
Rm. 103 - Kitchen	Convothorm Oven	Secured - SCSD Staff Only	---	HS-S3001	---	---	002	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---

Notes [October 13, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70274109.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixtures not sampled on 10/13/2023.
7. Fixture removed and replaced by SCSD.

Notes [January 18, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70284677.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed and replaced by SCSD.
7. Fixture repaired by SCSD.
8. Fixture removed by SCSD.

Notes [April 19, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70294977
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Upstream sample port installed by SCSD.

# SYRACUSE CITY SCHOOL DISTRICT HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

## Notes [May 14, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70297922.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

## Notes [June 21, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70302479.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD. Resample pending.

## Notes [September 18, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70314318.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.