

SYRACUSE CITY SCHOOL DISTRICT  
JOHNSON VOCATIONAL CENTER SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/25/23 RESULTS (ppb)	10/25/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	04/04/24 RE-SAMPLE RESULTS (ppb)	04/04/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	06/18/24 RE-SAMPLE RESULTS (ppb)	06/18/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	09/18/24 RE-SAMPLE RESULTS (ppb)	09/18/24 RE-SAMPLE ACTIONS
Rm. 104 - Principal's Office	Sink	Secured - SCSD Staff Only	013	JN-S312	1.3	None	---	---	---	---	---	---	---	---	---
Rm. 105 - Main Office	Sink	Secured - SCSD Staff Only	012	JN-S311	2.6	None	---	---	---	---	---	---	---	---	---
Rm. 115 - Classroom	Sink	Public Access	008	JN-S315	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 115 - Classroom	Sink	Public Access	009	JN-S316	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 115E - Classroom Bathroom	Sink	Public Access	010	JN-S317	82.5	See Note 6.	---	---	---	---	---	---	---	---	---
Rm. 115E - Classroom Bathroom	Sink	Public Access	011	JN-S318	12.6	See Note 6.	---	---	---	---	---	---	---	---	---
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	006	JN-S320	2.1	None	---	---	---	---	---	---	---	---	---
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	007	JN-S321	2.2	None	---	---	---	---	---	---	---	---	---
Rm. 125 - Hallway/Corridor	Fountain	Public Access	003	JN-F323	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 125 - Hallway/Corridor	Fountain	Public Access	004	JN-F323A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 128 - Technology Shop	Sink	Public Access	---	JN-S324	---	See Note 6.	---	---	---	---	---	---	---	---	---
Rm. 141 - Auto Shop	Fountain	Public Access	---	JN-F329	---	See Note 7.	---	---	---	---	---	---	---	---	---
Rm. 141 - Auto Shop	Sink	Public Access	005	JN-S328	8.6	See Note 7.	---	---	---	---	---	---	---	---	---
Rm. 142 - Welding Shop	Sink	Public Access	001	JN-S326	15.7	See Note 7.	---	---	---	---	---	---	---	---	---
Rm. 142 - Welding Shop	Sink	Public Access	002	JN-S327	18.1	See Note 7.	---	---	---	---	---	---	---	---	---
Rm. 207 - Hallway/Vestibule	Sink	Public Access	022	JN-S304	1.4	None	---	---	---	---	---	---	---	---	---
Rm. 207 - Hallway/Vestibule	Sink	Public Access	023	JN-S305	2.0	None	---	---	---	---	---	---	---	---	---
Rm. 213 - Laundry Room	Sink	Secured - SCSD Staff Only	025	JN-S303	34.6	See Note 7.	---	---	---	---	---	---	---	---	---
Rm. 214 - Nurse's Office	Sink	Public Access	024	JN-S301	4.3	None	---	---	---	---	---	---	---	---	---
Rm. 218A - Cosmetology Room	Sink	Public Access	017	JN-S308	19.7	See Note 9.	001	8.9	See Note 6.	001	4.9	None			
Rm. 218C - Classroom	Sink	Public Access	020	JN-S307	157	See Note 7.	---	---	---	---	---	---	---	---	---
Rm. 219 - Hallway/Corridor	Fountain	Public Access	021	JN-F306	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 222A - Lounge	Sink Spray Nozzle	Secured - SCSD Staff Only	---	JN-S310A	---	See Note 6.	---	---	---	---	---	---	---	---	---
Rm. 227 - Classroom	Sink	Public Access	016	JN-S309	111	See Note 7.	---	---	---	---	---	---	---	---	---
Rm. 218A - Cosmetology Room	Sink	Public Access	---	JN-S2000	---	See Note 8.	002	8.7	See Note 7.	002	8.1	See Note 6.	001	12.8	See Note 6.
Rm. 218A - Cosmetology Room	Sink	Public Access	018	JN-S2001	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 218A - Cosmetology Room	Sink Spray Nozzle	Public Access	019	JN-S2002	1.0	None	---	---	---	---	---	---	---	---	---
Rm. 227 - Classroom	Sink	Public Access	015	JN-S2003	827.0	See Note 7.	---	---	---	---	---	---	---	---	---

Notes [October 25, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-037
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70275341
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed from service by SCSD.
7. Fixture repaired and signed by SCSD. No further action required.
8. Fixture not sampled on 10/25/23.
9. Fixture repaired by SCSD.



# SYRACUSE CITY SCHOOL DISTRICT JOHNSON VOCATIONAL CENTER SCHOOL

## Notes [April 4, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-037.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70293144.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture replaced by SCSD.

## Notes [June 18, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-037.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70302037.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

## Notes [September 18, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-037.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70314316.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.