

SYRACUSE CITY SCHOOL DISTRICT  
ELMWOOD ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/10/23 RESULTS (ppb)	08/10/23 ORIGINAL ACTIONS	LAB SAMPLE I.D. No.	05/10/24 RE-SAMPLE RESULTS (ppb)	05/10/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	06/26/24 RE-SAMPLE RESULTS (ppb)	06/26/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	10/11/24 RE-SAMPLE RESULTS (ppb)	10/11/24 RE-SAMPLE ACTIONS
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	029	ED-S202	3.4	None	---	---	---	---	---	---	---	---	---
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	030	ED-S203	3.1	None	---	---	---	---	---	---	---	---	---
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	028	ED-S204	9.0	See Note 9.	001	5.2	See Note 6.	001	2.2	None	---	---	---
Rm. 40 - Hallway/Vestibule	Fountain	Public Access	003	ED-F201	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 40 - Hallway/Vestibule	Sink	Public Access	002	ED-S206	1.4	None	---	---	---	---	---	---	---	---	---
Rm. 40 - Hallway/Vestibule	Sink	Public Access	001	ED-S207	1.6	None	---	---	---	---	---	---	---	---	---
Rm. 59 - Classroom	Sink	Public Access	006	ED-S100	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 59 - Classroom	Sink	Public Access	007	ED-S101	12.2	See Note 8.	002	<1.0	None	---	---	---	---	---	---
Rm. 61 - Classroom	Sink	Public Access	005	ED-S102	4.6	None	---	---	---	---	---	---	---	---	---
Rm. 63 - Classroom	Sink	Public Access	004	ED-S107	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 68 - Storage Room	Sink	Secured - SCSD Staff Only	008	ED-S105	35.4	See Note 8.	003	18.3	See Note 7.	---	---	---	---	---	---
Rm. 105 - Resource Room	Sink	Public Access	010	ED-S125	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 106 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	009	ED-S122	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 124 - Hallway/Vestibule	Fountain	Public Access	---	ED-F101	---	See Note 6.	---	---	See Note 7.	---	---	---	---	---	---
Rm. 124 - Hallway/Vestibule	Sink	Public Access	036	ED-S115	1.0	None	---	---	---	---	---	---	---	---	---
Rm. 124 - Hallway/Vestibule	Sink	Public Access	035	ED-S116	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 124 - Hallway/Vestibule	Sink	Public Access	034	ED-S117	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 135 - Classroom	Sink	Public Access	---	ED-S212	---	---	004	<1.0	None	---	---	---	---	---	---
Rm. 136 - Classroom	Sink	Public Access	022	ED-S214	3.6	None	---	---	---	---	---	---	---	---	---
Rm. 137 - Classroom	Sink	Public Access	023	ED-S215	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 138 - Classroom	Sink	Public Access	---	ED-S217	---	See Note 6.	005	2.1	None	---	---	---	---	---	---
Rm. 139 - Hallway/Corridor	Fountain	Public Access	033	ED-F102	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 139 - Hallway/Corridor	Fountain	Public Access	031	ED-F103	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 139 - Hallway/Corridor	Fountain (Sensor)	Public Access	032	ED-F103A	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 142A - Classroom	Fountain	Public Access	027	ED-F100	1.4	None	---	---	---	---	---	---	---	---	---
Rm. 142B - Resource Room	Sink	Public Access	037	ED-S110	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 146 - Classroom	Sink	Public Access	025	ED-S111	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 146 - Classroom	Sink	Public Access	026	ED-S112	1.6	None	---	---	---	---	---	---	---	---	---
Rm. 208 - Classroom	Sink	Public Access	017	ED-S232	4.5	None	---	---	---	---	---	---	---	---	---
Rm. 212 - Work Room	Sink	Secured - SCSD Staff Only	018	ED-S237	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 215 - Hallway/Vestibule	Sink	Public Access	019	ED-S233	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 215 - Hallway/Vestibule	Sink	Public Access	020	ED-S235	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 215 - Hallway/Vestibule	Sink	Public Access	021	ED-S236	1.2	None	---	---	---	---	---	---	---	---	---
Rm. 215 - Hallway/Vestibule	Fountain	Public Access	---	ED-F203	---	See Note 6.	---	---	See Note 7.	---	---	---	---	---	---
Rm. 224 - Classroom	Sink	Public Access	---	ED-S223	---	See Note 6.	---	---	See Note 7.	---	---	---	---	---	---
Rm. 228 - Classroom	Sink	Public Access	038	ED-S121	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 229 - Classroom	Sink	Public Access	011	ED-S222	1.0	None	---	---	---	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
ELMWOOD ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/10/23 RESULTS (ppb)	08/10/23 ACTIONS	LAB SAMPLE I.D. No.	05/10/24 RE-SAMPLE RESULTS (ppb)	05/10/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	06/26/24 RE-SAMPLE RESULTS (ppb)	06/26/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	10/11/24 RE-SAMPLE RESULTS (ppb)	10/11/24 RE-SAMPLE ACTIONS
Rm. 230 - Hallway/Vestibule	Fountain	Public Access	012	ED-F202	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 230 - Hallway/Vestibule	Sink	Public Access	013	ED-S224	1.1	None	---	---	---	---	---	---	---	---	---
Rm. 230 - Hallway/Vestibule	Sink	Public Access	014	ED-S225	1.6	None	---	---	---	---	---	---	---	---	---
Rm. 230 - Hallway/Vestibule	Sink	Public Access	015	ED-S226	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 230 - Hallway/Vestibule	Sink	Public Access	016	ED-S227	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 04 - Kitchen	Convotherm Oven Sprayer	Secured - SCSD Staff Only	---	ED-C1000	---	See Note 6.	---	---	See Note 8.	---	---	See Note 6.	001	4.3	None

Notes [August 10, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-039.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70266565.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture inaccessible.
8. Fixture replaced by SCSD.
9. Fixture repaired by SCSD.

Notes [May 10, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-039.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70297477.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed by SCSD.
8. Fixture inoperative. SCSD to evaluate for repair or removal.

Notes [June 26, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-039.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70303079.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.

# SYRACUSE CITY SCHOOL DISTRICT ELMWOOD ELEMENTARY SCHOOL

## Notes [October 11, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-039.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70317755.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.