

SYRACUSE CITY SCHOOL DISTRICT
NOTTINGHAM HIGH SCHOOL FIELD HOUSE

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/13/2024 ORIGINAL RESULTS (ppb)	06/13/2024 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	08/08/2024 RE-SAMPLE RESULTS (ppb)	08/08/2024 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/11/2024 RE-SAMPLE RESULTS (ppb)	10/11/2024 RE-SAMPLE ACTIONS
Outside Perimeter	Fountain	Public Access	001	NMFH-F100	1.1	None	---	---	---	---	---	---
Concessions Stand	Ice Machine	Secured - SCSD Staff Only	006	NFH-S100	<1.0	None	---	---	---	---	---	---
Outside Perimeter	Fountain	Public Access	002	NMFH-F101	1.0	None	---	---	---	---	---	---
Outside Perimeter	Hose Bib	Public Access	007	NMFH-S105	1.4	None	---	---	---	---	---	---
Concessions Stand	Sink	Secured - SCSD Staff Only	003	NMFH-S107	23.2	See Note 6.	001	13.4	See Note 6.	001	4.8	None
Concessions Stand	Sink	Secured - SCSD Staff Only	004	NMFH-S108	5.6	See Note 6.	002	6.2	See Note 6.	002	2.3	None
Concessions Stand	Sink	Secured - SCSD Staff Only	005	NMFH-S109	3.0	None	---	---	---	---	---	---

Notes: [June 13, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-044
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70301435
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed and replaced by SCSD.

Notes: [August 8, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-044
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70308210
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

Notes: [October 11, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-044
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70317757
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.